

CHOK CHAI, Thailand

WMO: 484340

Lat: 14.738N

Lon: 102.168E

Elev: 634

StdP: 14.36

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.6	62.1	50.9	56.5	67.5	53.5	62.3	68.3	13.8	76.7	12.0	77.7	0.3	N/A	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.5	99.9	78.4	98.1	78.1	96.3	78.0	81.7	93.6	80.9	92.2	80.3	91.0	3.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	153.9	86.6	78.2	150.1	85.5	77.7	147.6	84.8	46.1	94.0	45.2	92.6	44.5	91.4	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.0	8.4	DB	55.1	102.4	2.5	1.9	53.3	103.8	51.9	104.9	50.4	106.0	48.6	107.4	(4)
(5)			WB	52.5	83.2	2.3	1.6	50.9	84.3	49.5	85.3	48.3	86.2	46.6	87.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	76.6	81.1	84.8	86.9	86.3	85.7	84.5	84.0	82.9	81.8	79.5	76.6	(6)
(7)		DBStd	4.75	4.56	4.63	4.21	3.31	2.78	1.95	2.06	1.84	2.08	2.24	3.66	4.50	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11886	826	870	1080	1108	1124	1070	1070	1056	987	985	886	824	(10)
(11)		CDD65	6411	361	450	615	658	659	620	605	591	537	520	436	359	(11)
(12)		CDH74	71057	3314	4963	7589	8373	7910	7484	6994	6551	5475	5148	4090	3166	(12)
(13)		CDH80	31793	1351	2440	4004	4493	3801	3450	3007	2644	1985	1849	1573	1196	(13)
(14)	Wind	WSAvg	1.5	1.5	1.2	1.3	1.3	1.2	1.7	1.8	1.8	1.1	1.4	1.9	1.9	(14)
(15)	Precipitation	PrecAvg	43.9	0.4	0.6	1.6	3.1	6.0	4.5	5.2	6.4	8.9	6.2	1.0	0.2	(15)
(16)		PrecMax	57.1	3.7	1.8	4.3	7.3	11.9	8.3	9.6	11.5	15.1	14.6	3.4	1.3	(16)
(17)		PrecMin	31.5	0.0	0.0	0.0	0.6	2.8	1.3	1.1	3.4	4.2	0.5	0.0	0.0	(17)
(18)		PrecStd	6.5	0.8	0.5	1.1	1.9	2.1	2.0	2.1	1.7	2.5	3.0	0.9	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.5	98.6	101.9	103.2	100.7	97.3	96.8	94.9	94.2	93.5	94.3	93.6	(19)
(20)			MCWB	74.0	76.0	77.7	79.8	80.9	79.8	79.4	79.0	80.2	78.7	77.4	75.3	(20)
(21)		2%	DB	92.1	96.3	99.6	100.4	97.8	95.3	94.3	93.3	92.3	91.3	92.0	91.4	(21)
(22)			MCWB	73.6	75.4	76.9	79.0	79.9	79.3	78.4	78.6	79.5	78.3	77.1	75.2	(22)
(23)		5%	DB	90.0	94.4	97.4	98.3	95.6	93.8	92.6	91.7	90.6	89.9	90.2	89.1	(23)
(24)			MCWB	73.3	75.0	76.8	78.6	79.9	79.0	78.1	78.4	79.0	77.8	76.3	74.0	(24)
(25)		10%	DB	87.5	92.0	95.1	95.9	93.5	92.2	91.0	90.1	88.9	88.3	88.1	86.6	(25)
(26)			MCWB	72.3	74.7	76.8	78.4	79.6	78.8	77.9	78.1	78.6	77.4	75.7	73.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	78.7	80.6	82.0	83.0	82.3	81.8	81.4	81.6	80.6	79.9	78.1	(27)
(28)			MCD B	89.6	92.4	96.4	98.4	95.6	93.2	92.2	91.0	91.4	89.0	89.5	88.7	(28)
(29)		2%	WB	76.5	77.5	79.3	80.9	81.8	80.9	80.3	80.3	80.5	79.8	78.9	76.7	(29)
(30)			MCD B	86.6	90.8	94.1	96.1	94.0	91.6	90.0	89.6	89.5	87.8	88.4	87.1	(30)
(31)		5%	WB	75.1	76.8	78.5	80.0	80.9	80.1	79.5	79.6	79.8	79.1	78.1	75.6	(31)
(32)			MCD B	84.4	89.7	92.4	94.1	92.2	90.3	89.0	88.3	88.0	86.9	86.8	85.7	(32)
(33)		10%	WB	73.9	76.0	77.8	79.2	80.0	79.5	78.8	78.9	79.1	78.5	77.1	74.4	(33)
(34)			MCD B	83.8	88.1	90.9	92.3	90.4	89.2	88.0	87.3	86.7	85.8	84.9	84.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.8	21.8	20.0	18.5	15.4	14.3	13.7	13.4	12.8	13.4	16.7	19.9	(35)
(36)			MCDBR	23.6	23.7	23.0	21.2	17.9	16.0	15.7	15.2	14.9	15.4	18.8	21.2	(36)
(37)			MCWBR	7.6	6.3	5.6	5.4	5.0	4.5	4.4	4.6	4.6	4.5	5.9	6.8	(37)
(38)		5% WB	MCDBR	19.3	20.8	20.5	19.6	16.5	14.9	14.5	14.3	14.0	13.8	16.1	18.9	(38)
(39)			MCWBR	6.7	5.8	5.7	5.8	5.5	4.9	4.9	5.0	4.8	4.6	5.3	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.496	0.603	0.644	0.588	0.497	0.464	0.454	0.456	0.489	0.530	0.482	0.468	(40)	
(41)		taud	2.045	1.794	1.738	1.907	2.208	2.303	2.328	2.307	2.204	2.054	2.169	2.155	(41)	
(42)		Ebn at Noon	252	231	226	239	257	263	266	268	261	247	255	257	(42)	
(43)		Edh at Noon	52	70	75	64	46	42	41	42	47	53	46	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1567	1657	1696	1803	1736	1648	1562	1520	1466	1499	1538	1531	(44)	
(45)		RadStd	100	70	83	84	103	73	90	89	79	109	89	56	56	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.47	N/A	N/A	N/A	+0.38	+0.34	N/A	N/A	+196	+194

Nomenclature: See separate page