

CHOK CHAI, Thailand

WMO: 484340

Lat: 14.738N

Lon: 102.168E

Elev: 193

StdP: 99.02

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.3	16.7	10.5	8.1	19.7	11.9	8.9	20.2	6.2	24.8	5.3	25.4	0.2	N/A	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.3	37.7	25.8	36.7	25.6	35.7	25.6	27.6	34.2	27.2	33.4	26.8	32.8	1.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	22.0	30.3	25.7	21.4	29.7	25.4	21.1	29.3	89.4	34.4	87.3	33.7	85.7	33.0	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.9	3.8	12.8	39.1	1.4	1.1	11.8	39.9	11.0	40.5	10.2	41.1	9.2	41.9		
(5)			11.4	28.4	1.3	0.9	10.5	29.1	9.7	29.6	9.0	30.1	8.1	30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	24.8	27.3	29.4	30.5	30.1	29.8	29.2	28.9	28.3	27.6	26.4	24.8	(6)
(7)		DBStd	2.64	2.53	2.57	2.34	1.84	1.54	1.09	1.14	1.02	1.16	1.25	2.03	2.50	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6603	459	483	600	616	624	594	594	587	548	547	492	458	(10)
(11)		CDD18.3	3562	201	250	342	366	366	344	336	328	298	289	242	199	(11)
(12)		CDH23.3	39476	1841	2757	4216	4652	4394	4158	3886	3639	3042	2860	2272	1759	(12)
(13)		CDH26.7	17663	751	1356	2224	2496	2112	1917	1671	1469	1103	1027	874	664	(13)
(14)	Wind	WSAvg	0.7	0.7	0.5	0.6	0.6	0.5	0.7	0.8	0.8	0.5	0.6	0.9	0.9	(14)
(15)	Precipitation	PrecAvg	1116	10	14	40	78	153	115	133	162	226	157	25	4	(15)
(16)		PrecMax	1451	93	46	110	186	301	211	243	293	384	370	87	34	(16)
(17)		PrecMin	801	0	0	1	14	72	32	28	87	106	12	0	0	(17)
(18)		PrecStd	166	20	12	28	48	53	51	54	44	64	75	24	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	37.0	38.9	39.6	38.2	36.3	36.0	35.0	34.6	34.2	34.6	34.2	(19)
MCWB			23.3	24.5	25.4	26.6	27.2	26.6	26.3	26.1	26.8	26.0	25.2	24.0	(20)	
2%		DB	33.4	35.7	37.5	38.0	36.6	35.2	34.6	34.0	33.5	33.0	33.4	33.0	(21)	
		MCWB	23.1	24.1	25.0	26.1	26.6	26.3	25.8	25.9	26.4	25.7	25.0	24.0	(22)	
5%		DB	32.2	34.7	36.3	36.8	35.3	34.3	33.7	33.2	32.6	32.2	32.3	31.7	(23)	
		MCWB	22.9	23.9	24.9	25.9	26.6	26.1	25.6	25.8	26.1	25.4	24.6	23.4	(24)	
10%		DB	30.8	33.3	35.0	35.5	34.2	33.5	32.8	32.3	31.6	31.3	31.2	30.3	(25)	
		MCWB	22.4	23.7	24.9	25.8	26.4	26.0	25.5	25.6	25.9	25.2	24.3	22.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.0	27.0	27.8	28.3	28.0	27.7	27.5	27.5	27.0	26.6	25.6	(27)
MCD B			32.0	33.6	35.8	36.9	35.3	34.0	33.4	32.8	33.0	31.6	32.0	31.5	(28)	
2%		WB	24.7	25.3	26.3	27.2	27.7	27.2	26.8	26.8	27.0	26.5	26.1	24.8	(29)	
		MCD B	30.3	32.7	34.5	35.6	34.4	33.1	32.2	32.0	31.9	31.0	31.3	30.6	(30)	
5%		WB	23.9	24.9	25.8	26.7	27.2	26.7	26.4	26.4	26.6	26.2	25.6	24.2	(31)	
		MCD B	29.1	32.0	33.6	34.5	33.5	32.4	31.6	31.3	31.1	30.5	30.5	29.8	(32)	
10%		WB	23.3	24.5	25.4	26.2	26.7	26.4	26.0	26.1	26.2	25.8	25.1	23.6	(33)	
		MCD B	28.8	31.2	32.7	33.5	32.5	31.8	31.1	30.7	30.4	29.9	29.4	28.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.1	12.1	11.1	10.3	8.6	8.0	7.6	7.4	7.1	7.4	9.3	11.1	(35)
MCDBR			13.1	13.2	12.8	11.8	10.0	8.9	8.7	8.4	8.3	8.5	10.4	11.8	(36)	
MCWBR			4.2	3.5	3.1	3.0	2.8	2.5	2.4	2.5	2.6	2.5	3.3	3.8	(37)	
5% WB		MCD BR	10.7	11.6	11.4	10.9	9.2	8.3	8.1	7.9	7.8	7.7	9.0	10.5	(38)	
		MCWBR	3.7	3.2	3.1	3.2	3.0	2.7	2.7	2.8	2.7	2.6	2.9	3.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.496	0.603	0.644	0.588	0.497	0.464	0.454	0.456	0.489	0.530	0.482	0.468	(40)	
taud		2.045	1.794	1.738	1.907	2.208	2.303	2.328	2.307	2.204	2.054	2.169	2.155	(41)		
Ebn at Noon		796	728	711	752	811	829	840	846	823	778	805	810	(42)		
Edh at Noon		164	220	238	201	146	132	129	133	147	167	144	144	(43)		
(44)	All-Sky Solar Radiation	RadAvg	4.94	5.22	5.35	5.68	5.47	5.20	4.92	4.79	4.62	4.73	4.85	4.83	(44)	
(45)		RadStd	0.32	0.22	0.26	0.27	0.32	0.23	0.28	0.28	0.25	0.34	0.28	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.26	N/A	N/A	N/A	+0.21	+0.19	N/A	N/A	+109	+108

Nomenclature: See separate page