

PAKCHONG AGROMET, Thailand

WMO: 484350

Lat: 14.6439N

Lon: 101.3180E

Elev: 388

StdP: 96.75

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	15.3	16.9	7.6	6.8	19.1	9.5	7.7	20.3	14.7	20.9	12.4	22.8	4.6	100	0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.5	35.3	23.8	34.2	23.9	33.2	23.9	25.8	30.8	25.6	30.5	25.2	30.1	4.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	20.7	27.8	24.4	20.3	27.4	24.1	19.9	27.2	82.4	30.9	81.1	30.6	79.9	30.2	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.2	7.8	DB	12.9	36.2	1.6	1.4	11.7	37.2	10.8	38.0	9.9	38.7	8.8	39.7	(4)
(5)			WB	10.2	27.4	1.8	0.9	8.9	28.1	7.9	28.6	6.9	29.1	5.6	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	23.7	25.5	27.1	28.3	28.1	27.8	27.2	26.8	26.2	26.0	25.2	23.6
	DBStd	2.22	2.29	1.81	1.97	1.83	1.52	1.18	1.20	0.97	0.97	1.10	1.52	2.27
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	1	0	1	0	0	0	0	0	0	0	0	0
	CDD10.0	5949	424	434	529	548	563	535	534	522	487	497	456	421
	CDD18.3	2909	167	201	271	298	304	285	276	263	237	238	206	162
	CDH23.3	26023	1199	1804	2756	3218	3176	2965	2702	2303	1768	1684	1373	1076
CDH26.7	9129	369	727	1258	1507	1268	1001	798	601	459	454	384	303	
Wind	WSAvg	2.8	3.1	2.4	2.6	2.2	2.2	3.0	3.5	3.0	2.2	2.4	3.3	3.8
Precipitation	PrecAvg	1396	8	13	46	91	168	161	191	235	294	157	27	4
	PrecMax	1735	47	50	107	245	298	256	300	380	491	372	155	23
	PrecMin	1064	0	0	4	30	78	57	89	132	156	59	0	0
	PrecStd	163	12	12	29	51	56	39	45	63	76	66	32	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	34.4	36.0	37.1	35.8	34.5	33.2	32.1	31.9	32.2	32.0	32.2
		MCWB	21.5	22.7	22.9	24.1	24.6	24.4	24.2	24.7	24.9	24.1	23.2	22.6
	2%	DB	31.1	33.1	34.7	35.8	34.1	32.9	31.9	31.0	30.9	30.9	31.0	31.0
		MCWB	21.5	22.2	23.0	24.3	24.7	24.5	24.2	24.7	24.8	24.1	23.3	22.3
	5%	DB	30.2	32.1	33.6	34.5	32.9	31.8	31.0	30.2	30.1	30.2	30.1	29.9
		MCWB	21.2	22.2	23.2	24.3	24.8	24.6	24.2	24.5	24.7	24.0	23.2	22.0
	10%	DB	29.0	30.9	32.4	33.2	31.9	30.8	30.2	29.5	29.3	29.3	29.1	28.4
		MCWB	20.8	22.1	23.2	24.3	24.7	24.6	24.1	24.3	24.5	23.9	22.7	21.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	24.6	25.2	26.3	26.3	26.0	25.2	25.7	26.0	25.6	25.3	24.4
		MCDB	29.1	30.1	31.1	32.8	31.3	30.5	29.8	29.6	30.2	29.3	29.4	29.1
	2%	WB	23.5	24.1	24.7	25.7	25.8	25.5	25.0	25.2	25.5	25.1	24.7	23.6
		MCDB	28.3	29.8	30.8	32.2	30.9	30.1	29.7	29.3	29.4	28.9	28.8	28.5
	5%	WB	22.9	23.7	24.3	25.2	25.4	25.1	24.6	24.9	25.1	24.7	24.2	22.9
		MCDB	27.2	29.5	30.4	31.7	30.5	29.8	29.3	29.0	28.8	28.4	28.1	27.7
	10%	WB	22.1	23.2	24.0	24.9	25.1	24.8	24.3	24.6	24.7	24.4	23.6	22.1
		MCDB	26.4	28.9	30.0	31.2	30.1	29.4	28.9	28.5	28.1	27.8	27.2	26.8
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.9	10.3	9.5	7.5	6.4	5.9	5.9	6.2	6.7	7.6	9.1
		MCDBR	11.5	12.6	12.3	11.1	8.8	7.7	7.0	6.8	7.5	8.0	9.1	10.5
		MCWBR	4.0	4.1	3.6	3.3	2.4	2.2	2.2	2.4	2.8	2.8	3.1	3.7
	5% WB	MCDBR	9.2	10.6	10.3	9.6	7.9	6.8	6.4	6.5	6.8	7.2	8.2	9.6
MCWBR		3.7	3.6	3.4	3.2	2.8	2.4	2.3	2.5	2.8	2.8	3.2	3.9	
Clear-Sky Solar Irradiance	taub	0.485	0.575	0.616	0.566	0.487	0.452	0.442	0.444	0.471	0.518	0.464	0.452	
	taud	2.067	1.856	1.792	1.957	2.235	2.336	2.363	2.343	2.252	2.084	2.218	2.197	
	Ebn at Noon	806	750	732	768	819	839	850	857	838	789	822	827	
	Edh at Noon	161	207	226	191	142	127	124	128	140	162	137	138	
All-Sky Solar Radiation	RadAvg	4.89	5.22	5.40	5.73	5.40	5.12	4.85	4.74	4.59	4.67	4.83	4.80	
	RadStd	0.33	0.22	0.32	0.29	0.34	0.28	0.26	0.28	0.24	0.31	0.29	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.23	N/A	N/A	N/A	+0.30	+0.29	N/A	N/A	+118	+118

Nomenclature: See separate page