

KABINBURI, Thailand

WMO: 484390

Lat: 13.9861N

Lon: 101.7045E

Elev: 41

StdP: 14.67

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	64.4	66.5	53.0	59.8	71.4	56.0	67.0	72.2	23.1	76.8	16.4	75.6	1.6	N/A	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	19.7	100.1	80.0	98.2	79.6	96.6	79.3	83.2	93.1	82.5	92.0	81.9	91.0	2.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.4	88.1	80.1	156.4	87.0	79.7	154.1	86.4	47.3	93.4	46.4	92.4	45.7	91.2	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 11.8	8.6	6.9		60.2	102.6	2.4	2.0	58.4	104.0	57.0	105.2	55.6	106.3	53.8	107.8	
(5)			DB	55.8	85.2	2.6	1.7	53.9	86.4	52.4	87.4	50.9	88.3	49.1	89.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.6	79.8	83.2	86.1	87.4	86.4	84.8	83.4	83.3	83.4	83.4	81.9	79.6	
	DBStd	3.59	3.48	3.47	3.12	2.89	2.62	2.27	2.14	1.85	1.90	1.74	2.83	3.67	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	12248	925	930	1118	1123	1129	1045	1036	1032	1001	1036	956	917	
	CDD65	6773	460	510	653	673	664	595	571	567	551	571	506	452	
	CDH74	73668	4325	5564	7816	8268	7918	6732	6074	5990	5738	5972	5062	4209	
	CDH80	32419	1914	2729	4050	4411	3807	2844	2276	2194	2107	2287	2064	1736	
Wind	WSAvg	0.9	1.1	0.7	0.9	0.7	0.6	0.6	0.5	0.7	0.4	0.7	1.6	1.7	
Precipitation	PrecAvg	62.3	0.4	0.7	2.0	3.9	6.9	7.3	9.6	10.9	12.6	6.6	1.2	0.2	
	PrecMax	78.8	1.7	3.3	7.2	12.1	12.2	13.6	15.7	16.7	19.9	18.3	5.6	1.1	
	PrecMin	48.8	0.0	0.0	0.3	1.1	2.4	3.5	4.8	5.3	5.9	2.9	0.0	0.0	
	PrecStd	8.2	0.4	0.9	1.7	2.4	2.7	2.3	2.6	3.0	3.5	3.2	1.3	0.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.4	98.8	101.6	103.0	100.8	97.2	94.9	93.6	93.9	94.5	95.6	95.1	
		MCWB	75.9	78.5	79.0	80.8	81.4	80.4	80.5	81.0	81.1	80.6	79.0	77.8	
	2%	DB	93.7	96.8	99.3	100.8	98.0	95.2	92.9	92.1	92.3	92.7	93.6	93.1	
		MCWB	75.6	77.5	78.7	80.7	80.8	80.6	80.6	80.9	80.9	80.1	78.2	76.7	
	5%	DB	91.9	95.1	97.4	98.7	96.1	93.2	91.2	90.7	90.9	91.3	91.6	91.2	
		MCWB	75.1	77.2	78.5	80.3	80.6	80.8	80.5	80.6	80.7	79.8	77.8	75.8	
	10%	DB	89.8	93.0	95.4	96.5	94.0	91.2	89.5	89.0	89.2	89.7	89.7	88.8	
		MCWB	74.7	76.3	78.4	80.2	80.7	80.3	80.2	80.4	80.4	79.4	77.2	74.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	81.2	82.2	84.5	85.1	83.5	82.8	82.7	82.8	82.7	81.8	80.5
			MCDB	90.3	93.7	95.2	97.4	94.6	92.0	90.3	90.7	90.8	91.0	91.3	91.6
2%		WB	78.4	79.9	81.0	82.8	83.1	82.5	81.8	81.8	81.9	81.6	80.6	79.0	
		MCDB	88.8	92.0	93.5	95.1	92.8	91.0	89.4	89.5	89.7	89.9	89.9	88.7	
5%		WB	77.4	79.0	80.2	81.9	82.2	81.8	81.2	81.2	81.3	80.8	79.6	77.9	
		MCDB	86.6	90.6	92.2	93.8	91.7	89.9	88.5	88.4	88.7	88.7	88.2	86.8	
10%		WB	76.4	78.2	79.5	81.0	81.4	81.0	80.6	80.6	80.7	80.1	78.6	76.7	
		MCDB	85.1	88.6	91.1	92.7	90.4	88.7	87.6	87.4	87.7	87.2	86.3	85.0	
Mean Daily Temperature Range	5% DB	MDBR	21.1	21.2	20.2	19.7	16.0	13.9	12.6	12.4	12.9	13.9	16.3	18.7	
		MCDBR	23.3	22.6	22.4	21.9	18.7	16.4	15.2	14.4	14.9	15.8	18.8	21.0	
		MCWBR	8.3	6.7	5.3	5.4	4.9	4.9	5.1	5.1	5.4	5.6	6.6	7.5	
	5% WB	MCDBR	20.1	20.8	20.2	19.9	16.4	14.6	13.5	13.1	13.8	14.4	16.7	18.9	
		MCWBR	7.8	6.5	6.1	6.6	6.0	5.6	5.6	5.5	5.7	5.6	6.7	7.4	
Clear-Sky Solar Irradiance	taub	0.537	0.633	0.662	0.601	0.514	0.490	0.481	0.482	0.505	0.554	0.496	0.486		
	taud	1.950	1.748	1.721	1.897	2.179	2.247	2.272	2.255	2.180	2.010	2.151	2.129		
	Ebn at Noon	241	224	222	235	252	256	259	262	257	241	252	253		
	Edh at Noon	58	73	77	64	48	44	43	44	48	56	47	47		
All-Sky Solar Radiation	RadAvg	1562	1634	1671	1765	1645	1572	1495	1483	1441	1479	1534	1533		
	RadStd	101	75	90	90	95	71	80	87	73	95	95	63		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	+0.43	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page