

KABINBURI, Thailand

WMO: 484390

Lat: 13.9861N

Lon: 101.7045E

Elev: 12

StdP: 101.18

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 18.0	(c) 19.2	(d) 11.6	(e) 8.5	(f) 21.9	(g) 13.4	(h) 9.6	(i) 22.3	(j) 10.3	(k) 24.9	(l) 7.3	(m) 24.2	(n) 0.7	(o) N/A	(p) 0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.9	37.8	26.7	36.8	26.5	35.9	26.3	28.5	33.9	28.1	33.3	27.7	32.8	1.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	31.2	26.7	22.3	30.6	26.5	22.0	30.2	92.0	34.1	90.1	33.6	88.5	32.9	31.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.3	3.8	3.1		15.7	39.2	1.4	1.1	14.7	40.0	13.9	40.7	13.1	41.3	12.1	42.1	
				DB	13.2	29.6	1.4	0.9	12.2	30.2	11.3	30.8	10.5	31.3	9.5	32.0
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	26.6	28.4	30.0	30.8	30.2	29.3	28.6	28.5	28.5	28.6	27.7	26.4
	DBStd	1.99	1.93	1.93	1.74	1.61	1.46	1.26	1.19	1.03	1.05	0.96	1.57	2.04
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6804	514	517	621	624	627	581	576	573	556	576	531	509
	CDD18.3	3763	256	283	363	374	369	331	317	315	306	317	281	251
	CDH23.3	40927	2403	3091	4342	4593	4399	3740	3374	3328	3188	3318	2812	2338
(14) Wind	WSAvg	0.4	0.5	0.3	0.4	0.3	0.3	0.3	0.2	0.3	0.2	0.3	0.7	0.8
	PrecAvg	1583	9	19	52	98	176	185	245	276	319	168	30	5
	PrecMax	2001	43	85	182	308	311	346	400	425	506	465	142	29
	PrecMin	1239	0	0	7	29	60	88	123	134	151	73	0	0
	PrecStd	209	11	22	42	60	69	59	67	75	90	81	34	7
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	37.1	38.7	39.5	38.2	36.2	35.0	34.2	34.4	34.7	35.3	35.0
		MCWB	24.4	25.9	26.1	27.1	27.4	26.9	27.0	27.2	27.3	27.0	26.1	25.4
	2%	DB	34.3	36.0	37.4	38.2	36.6	35.1	33.8	33.4	33.5	33.7	34.2	33.9
		MCWB	24.2	25.3	26.0	27.0	27.1	27.0	27.0	27.2	27.2	26.7	25.6	24.8
	5%	DB	33.3	35.0	36.4	37.1	35.6	34.0	32.9	32.6	32.7	32.9	33.1	32.9
		MCWB	23.9	25.1	25.8	26.8	27.0	27.1	26.9	27.0	27.1	26.6	25.4	24.3
	10%	DB	32.1	33.9	35.2	35.8	34.4	32.9	31.9	31.7	31.8	32.0	32.1	31.6
		MCWB	23.7	24.6	25.8	26.8	27.0	27.1	26.8	26.8	26.9	26.3	25.1	23.8
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	27.3	27.9	29.2	29.5	28.6	28.2	28.2	28.2	27.6	26.9
			MCDB	32.4	34.3	35.1	36.3	34.8	33.3	32.4	32.6	32.7	32.8	33.1
		2%	WB	25.8	26.6	27.2	28.2	28.4	28.1	27.7	27.7	27.6	27.0	26.1
			MCDB	31.5	33.3	34.2	35.1	33.8	32.8	31.9	31.9	32.1	32.2	31.5
		5%	WB	25.2	26.1	26.8	27.7	27.9	27.7	27.3	27.3	27.4	27.1	26.5
			MCDB	30.3	32.5	33.4	34.3	33.2	32.2	31.4	31.3	31.5	31.2	30.4
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	11.8	11.2	10.9	8.9	7.7	7.0	6.9	7.2	7.7	9.1	10.4
		MCDBR	12.9	12.6	12.4	12.2	10.4	9.1	8.4	8.0	8.3	8.8	10.4	11.6
		MCWBR	4.6	3.7	3.0	3.0	2.7	2.7	2.8	2.8	3.0	3.1	3.7	4.2
		MCWBR	11.2	11.6	11.2	11.1	9.1	8.1	7.5	7.3	7.6	8.0	9.3	10.5
	5% WB	MCWBR	4.3	3.6	3.4	3.7	3.4	3.1	3.1	3.1	3.1	3.1	3.7	4.1
(40) Clear-Sky Solar Irradiance	taub		0.537	0.633	0.662	0.601	0.514	0.490	0.481	0.482	0.505	0.554	0.496	0.486
	taud		1.950	1.748	1.721	1.897	2.179	2.247	2.272	2.255	2.180	2.010	2.151	2.129
	Ebn at Noon		761	706	699	742	796	807	817	825	810	760	794	797
	Edh at Noon		182	231	243	203	151	139	136	140	151	176	148	149
(44) All-Sky Solar Radiation	RadAvg		4.92	5.15	5.27	5.56	5.19	4.96	4.71	4.67	4.54	4.66	4.84	4.83
	RadStd		0.32	0.24	0.28	0.28	0.30	0.23	0.25	0.28	0.23	0.30	0.30	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	N/A	N/A	N/A	N/A	+0.24	+0.26	N/A	N/A	N/A	N/A