

KANCHANA BURI, Thailand

WMO: 484500

Lat: 14.0225N

Lon: 99.5358E

Elev: 94

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	63.6	66.3	50.8	55.3	76.6	54.1	62.4	77.6	12.0	81.1	10.2	81.9	0.3	30	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.5	101.9	77.2	100.0	77.1	98.2	77.2	81.2	92.9	80.7	92.0	80.1	91.0	3.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.9	84.7	78.2	146.8	84.3	77.7	144.3	83.9	45.0	93.3	44.4	92.1	43.9	91.4	94.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	7.8	7.0	59.7	104.9	3.9	2.3	57.0	106.6	54.7	108.0	52.5	109.3	49.7	111.0		
(5)			55.6	83.3	3.7	2.7	53.0	85.2	50.9	86.8	48.8	88.3	46.1	90.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.3	80.1	83.8	86.8	89.3	87.5	86.1	85.0	84.8	84.3	83.0	81.4	79.2
	DBStd	4.29	3.81	3.70	3.73	3.40	3.50	2.50	2.49	2.27	2.31	2.35	3.09	4.11
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12510	933	947	1142	1178	1163	1084	1084	1078	1030	1024	941	906
	CDD65	7035	468	527	677	728	698	634	619	613	580	559	491	441
	CDH74	82787	4814	6229	8760	9933	8993	7794	7273	7078	6440	6091	5080	4302
	CDH80	39147	2154	3167	4769	5797	4725	3650	3150	2975	2646	2377	2004	1733
Wind	WSAvg	1.3	1.1	1.3	1.6	1.6	1.4	1.4	1.4	1.5	1.3	1.0	1.3	1.4
Precipitation	PrecAvg	43.1	0.3	0.7	1.5	3.2	6.5	3.2	3.7	4.1	8.8	8.2	2.5	0.6
	PrecMax	62.2	3.1	3.5	8.4	5.7	11.3	7.0	7.6	7.8	16.3	14.4	7.7	3.0
	PrecMin	33.7	0.0	0.0	0.0	0.2	2.3	1.3	1.1	0.4	2.3	3.5	0.0	0.0
	PrecStd	8.7	0.8	1.2	2.0	1.9	2.0	1.5	1.6	2.2	3.7	2.8	2.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.4	100.1	103.1	105.7	103.9	99.9	97.4	97.1	96.5	94.5	95.0	95.1
		MCWB	74.1	73.8	73.9	77.5	79.5	78.6	78.6	78.8	78.7	79.5	77.8	76.2
	2%	DB	94.2	98.0	100.6	102.6	100.4	96.7	95.0	94.6	94.4	92.6	92.7	92.6
		MCWB	73.9	74.7	74.9	77.8	79.2	79.1	78.5	78.6	78.7	79.1	77.4	75.4
	5%	DB	92.3	96.2	98.8	100.5	97.8	94.5	93.1	92.7	92.5	91.1	90.9	90.6
		MCWB	73.7	74.9	75.7	78.1	79.2	78.9	78.1	78.4	78.5	78.6	76.5	74.5
	10%	DB	90.1	94.0	96.8	98.3	95.2	92.5	91.2	90.8	90.6	89.6	89.0	88.5
		MCWB	73.1	74.9	75.9	77.9	79.1	78.7	77.9	78.0	78.3	78.2	75.8	73.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	79.4	80.6	81.9	82.3	81.4	80.9	80.8	81.0	81.0	80.6	79.1
		MCDB	89.7	93.3	93.7	96.5	96.0	92.6	91.5	91.0	90.5	89.5	90.2	89.4
	2%	WB	77.1	78.3	79.3	80.9	81.0	80.5	79.9	79.9	80.1	80.5	79.5	77.5
		MCDB	88.2	91.4	91.8	94.5	93.8	91.5	90.1	89.8	89.5	88.9	88.2	87.6
	5%	WB	76.2	77.5	78.7	80.1	80.4	79.9	79.1	79.1	79.6	79.8	78.8	76.5
		MCDB	86.6	89.5	91.0	93.2	92.5	90.2	89.1	89.0	88.7	88.0	86.8	86.3
	10%	WB	75.3	76.7	78.0	79.5	79.8	79.2	78.6	78.6	78.9	79.2	77.9	75.4
		MCDB	84.9	88.0	89.9	92.3	91.2	88.9	88.2	88.1	87.8	87.0	85.4	84.9
Mean Daily Temperature Range	5% DB	MDBR	20.2	20.7	19.5	18.5	15.1	13.5	12.9	13.0	13.4	12.8	14.6	17.6
		MCDBR	22.1	22.8	22.1	21.0	18.2	16.0	15.4	15.4	15.7	14.8	17.0	19.2
		MCWBR	6.5	5.9	6.0	4.9	4.3	4.1	4.2	4.2	4.3	4.4	5.0	5.5
	5% WB	MCDBR	18.4	19.8	19.3	18.7	16.1	14.3	13.7	13.9	14.0	13.5	14.6	17.3
		MCWBR	6.0	5.4	5.4	5.1	4.5	4.2	4.4	4.3	4.6	4.7	4.8	5.2
Clear-Sky Solar Irradiance	taub	0.536	0.602	0.647	0.565	0.481	0.444	0.439	0.439	0.459	0.573	0.525	0.516	
	taud	1.956	1.824	1.748	1.991	2.279	2.385	2.399	2.385	2.316	1.950	2.057	2.025	
	Ebn at Noon	242	232	225	244	261	268	270	273	269	236	243	243	
	Edh at Noon	57	68	75	59	43	38	38	39	42	59	51	52	
All-Sky Solar Radiation	RadAvg	1506	1663	1736	1892	1689	1538	1435	1430	1497	1422	1471	1464	
	RadStd	92	75	135	115	150	128	119	109	110	98	104	70	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.34	+0.43	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	+0.38	N/A	N/A	N/A	+0.47	+0.50	N/A	N/A	+180	+180

Nomenclature: See separate page