

BANGKOK DON MUEANG INTL, Thailand

WMO: 484560

Lat: 13.913N Lon: 100.607E Elev: 9 StdP: 14.69 Time Zone: 7.00 (E07) Period: 94-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	67.2	69.8	52.0	57.6	77.2	55.4	65.4	78.3	14.4	81.5	13.2	82.0	5.2	20	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	16.0	98.9	79.7	97.4	79.8	96.5	79.8	85.3	92.9	84.3	91.7	83.4	90.4	8.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.5	175.5	89.6	82.5	169.6	88.4	81.7	165.0	87.6	49.6	92.5	48.5	92.3	47.5	90.3	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.5	14.4	12.8	DB	62.6	101.3	3.8	2.0	59.8	102.7	57.6	103.9	55.5	105.1	52.7	106.5	
			WB	56.8	86.0	3.9	2.4	54.0	87.8	51.7	89.2	49.5	90.5	46.6	92.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.8	81.3	84.0	86.6	88.2	87.2	86.2	85.5	85.3	84.5	84.3	83.3	81.0
	DBStd	3.60	3.49	3.19	3.13	2.99	3.03	2.24	2.25	2.13	2.08	2.37	3.17	4.14
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12698	971	953	1134	1146	1154	1087	1101	1095	1036	1062	998	961
	CDD65	7224	506	533	669	696	689	637	636	630	586	597	548	497
	CDH74	89409	5517	6447	8751	9569	9147	8293	8005	7815	6903	7022	6460	5480
	CDH80	42729	2298	3033	4591	5413	4871	4151	3766	3609	2984	2974	2776	2263
(14) Wind	WSAvg	6.1	5.0	5.9	6.9	6.8	6.5	7.0	7.5	7.3	6.1	4.7	5.0	5.1
(15) Precipitation	PrecAvg	59.2	0.7	0.6	2.0	3.5	8.2	7.3	7.0	7.9	12.3	9.3	1.6	0.4
	PrecMax	80.3	4.4	2.2	6.4	9.8	17.9	13.9	12.1	14.6	19.4	17.4	5.0	1.7
	PrecMin	39.8	0.0	0.0	0.1	0.2	3.0	1.9	1.6	2.8	7.8	2.3	0.0	0.0
	PrecStd	9.6	1.0	0.6	1.9	2.7	3.9	3.0	2.8	3.3	2.9	3.3	1.5	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.7	97.4	99.7	101.4	100.7	98.7	96.8	96.5	95.4	95.4	95.3	94.6
		MCWB	75.7	77.9	79.1	79.2	79.6	78.7	80.6	81.7	82.0	80.5	78.0	76.2
	2%	DB	92.9	95.2	97.2	99.0	98.5	95.9	94.7	94.6	93.6	93.3	93.4	92.5
		MCWB	75.5	77.3	78.6	79.9	80.4	80.3	80.1	80.4	80.6	79.4	77.7	75.7
	5%	DB	91.3	93.5	96.1	97.8	96.6	94.2	93.1	93.0	92.2	91.7	91.7	91.1
		MCWB	74.8	77.1	78.7	80.1	80.3	80.3	79.6	80.0	80.1	78.9	77.5	75.2
	10%	DB	89.6	92.0	94.7	96.4	94.6	92.8	91.5	91.4	91.0	90.0	90.0	89.4
		MCWB	74.5	76.6	78.6	80.3	80.3	80.1	79.3	79.4	79.7	78.6	76.9	74.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	83.0	84.8	86.4	85.5	85.6	84.9	84.5	86.3	85.6	83.0	80.7
		MCDB	87.6	91.8	94.5	95.1	93.3	93.2	92.3	91.6	92.7	91.4	88.9	86.6
	2%	WB	79.8	81.4	83.3	84.8	84.1	84.1	83.5	83.1	84.0	83.1	81.0	79.1
		MCDB	86.7	89.8	92.0	93.3	92.1	91.4	90.1	90.0	89.7	87.7	87.5	86.4
	5%	WB	78.8	80.1	81.8	83.6	83.0	82.8	82.4	81.9	82.5	81.6	80.0	78.1
		MCDB	85.2	88.0	89.8	91.5	90.4	88.9	88.3	88.5	88.1	86.7	86.7	85.9
	10%	WB	77.8	79.2	80.7	82.6	82.0	81.7	81.3	81.0	81.2	80.5	79.1	77.1
		MCDB	84.4	86.2	88.5	89.9	89.2	87.8	87.5	87.6	87.0	86.1	85.9	85.3
(35) Mean Daily Temperature Range	5% DB	MDBR	16.4	16.6	16.0	16.0	14.5	13.6	12.9	12.9	13.4	12.7	13.6	15.3
		MCDBR	17.7	17.7	18.0	17.3	16.4	15.5	14.6	14.5	15.2	14.3	14.7	16.0
	5% WB	MCWBR	6.0	5.9	6.2	6.0	5.6	5.8	5.5	5.5	6.3	5.4	5.3	5.1
		MCWBR	15.3	16.4	16.5	16.3	14.7	14.0	13.6	13.7	14.5	13.3	13.5	13.8
(40) Clear-Sky Solar Irradiance	taub	0.544	0.615	0.645	0.583	0.504	0.467	0.459	0.460	0.486	0.578	0.522	0.509	0.509
		1.954	1.811	1.772	1.959	2.236	2.336	2.361	2.344	2.261	1.962	2.096	2.076	2.076
	Ebn at Noon	240	229	226	240	255	262	265	267	262	235	245	246	246
		57	69	73	61	45	40	40	41	44	58	49	50	50
(44) All-Sky Solar Radiation	RadAvg	1600	1734	1787	1918	1762	1678	1598	1607	1557	1524	1563	1548	1548
	RadStd	93	71	130	114	123	89	79	102	86	85	102	72	72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	N/A	N/A	N/A	N/A	+0.41	+0.45	N/A	N/A	N/A	N/A

Nomenclature: See separate page