

CHON BURI SATTAHIP, Thailand

WMO: 484590

Lat: 13.3556N

Lon: 100.9824E

Elev: 8

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	67.8	70.2	51.7	56.9	75.8	55.0	64.3	77.9	17.6	76.6	15.6	78.7	5.7	60	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	13.4	96.7	79.0	95.3	78.7	94.3	78.4	82.2	91.9	81.6	90.9	80.9	89.9	7.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.9	155.2	86.8	79.1	151.3	86.3	78.7	148.8	85.9	46.1	92.1	45.3	91.0	44.7	90.4	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.3	14.4	13.1	DB	63.2	99.4	3.5	1.8	60.7	100.7	58.6	101.8	56.7	102.7	54.1	104.0
			WB	56.2	84.2	3.4	1.7	53.8	85.4	51.8	86.4	49.9	87.3	47.5	88.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.6	81.5	83.7	85.7	87.6	86.9	86.0	85.2	85.0	84.2	84.2	83.5	81.5
	DBStd	3.10	2.99	2.39	2.63	2.57	2.60	1.93	2.03	1.78	1.83	1.95	2.84	3.84
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12623	977	943	1107	1127	1144	1081	1091	1086	1027	1059	1004	977
	CDD65	7148	512	523	642	677	679	631	626	621	577	594	554	512
	CDH74	87944	5415	6106	8132	9150	9156	8365	7966	7813	6891	6959	6460	5531
	CDH80	40383	2135	2587	3902	4933	4779	4131	3640	3496	2849	2870	2778	2283
(14) Wind	WSAvg	5.1	4.7	5.4	5.9	5.5	5.1	5.2	5.2	5.1	4.4	4.3	4.8	5.2
(15) Precipitation	PrecAvg	52.1	0.4	0.7	1.2	3.0	6.2	4.7	5.3	7.0	12.1	8.4	2.6	0.5
	PrecMax	68.6	3.5	3.1	2.9	11.9	12.6	8.9	8.6	13.6	25.9	21.9	8.0	2.4
	PrecMin	35.4	0.0	0.0	0.1	0.3	0.6	1.6	2.2	2.4	6.3	3.6	0.1	0.0
	PrecStd	8.8	0.9	0.8	0.7	2.8	3.3	2.3	1.8	2.8	5.1	4.6	2.3	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.7	95.1	96.4	98.8	98.3	96.1	94.7	94.2	93.6	94.4	95.4	94.9
		MCWB	73.7	74.2	77.3	79.2	79.7	79.3	79.0	78.7	78.7	78.3	77.2	76.3
	2%	DB	92.4	93.1	94.6	96.8	96.4	93.9	93.0	92.7	92.1	92.9	93.4	92.9
		MCWB	73.5	75.1	77.6	79.5	79.8	79.2	78.7	78.7	78.6	78.1	76.8	75.4
	5%	DB	90.4	91.5	93.2	95.3	94.7	92.8	91.6	91.4	91.1	91.5	91.8	91.3
		MCWB	73.6	75.7	78.0	79.5	79.7	79.2	78.6	78.6	78.5	78.0	76.6	75.0
	10%	DB	88.8	89.9	91.8	93.9	93.0	91.4	90.3	90.0	89.6	89.9	90.3	89.4
		MCWB	73.9	76.1	77.9	79.4	79.5	78.9	78.3	78.2	78.3	77.8	76.3	74.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.5	80.9	81.8	83.2	83.3	81.9	81.7	81.8	81.4	81.8	81.4	80.5
		MCDB	87.8	89.8	92.4	94.6	93.2	90.5	89.5	89.4	89.4	89.6	89.6	88.6
	2%	WB	78.9	79.8	80.8	82.1	82.0	81.0	80.7	80.5	80.4	80.6	80.0	79.1
		MCDB	86.4	88.7	90.9	93.0	91.4	89.5	88.5	88.5	88.3	88.5	88.2	87.3
	5%	WB	78.0	79.0	80.0	81.4	81.3	80.5	80.0	79.8	79.8	79.9	79.1	77.8
		MCDB	85.4	87.7	89.6	91.7	90.3	88.9	87.8	87.7	87.4	87.4	87.2	86.3
	10%	WB	77.0	78.2	79.3	80.7	80.6	79.9	79.3	79.2	79.2	79.2	78.2	76.7
		MCDB	84.4	86.5	88.3	90.5	89.3	88.2	87.1	86.9	86.5	86.4	86.3	85.5
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	14.4	13.3	13.4	12.3	11.8	11.3	11.4	11.8	12.8	14.4	16.2
		MCDBR	17.9	15.9	14.4	14.4	13.9	13.2	12.7	12.8	13.4	14.4	15.8	17.0
		MCWBR	7.4	6.5	5.8	5.9	5.7	5.1	5.2	5.2	5.4	5.5	5.9	6.6
	5% WB	MCDBR	13.5	13.1	13.2	13.5	13.0	12.4	12.0	12.1	12.4	13.1	14.0	15.2
		MCWBR	6.7	5.9	5.7	5.8	5.8	5.5	5.7	5.7	5.5	5.8	6.1	6.8
(40) Clear-Sky Solar Irradiance	taub	0.544	0.612	0.629	0.569	0.496	0.470	0.465	0.467	0.486	0.563	0.511	0.496	
	taud	1.961	1.820	1.815	1.999	2.257	2.329	2.341	2.322	2.259	2.000	2.128	2.123	
	Ebn at Noon	240	230	230	243	257	261	263	266	263	239	248	251	
	Edh at Noon	57	69	70	58	44	41	40	42	44	56	48	48	
(44) All-Sky Solar Radiation	RadAvg	1602	1712	1746	1851	1676	1606	1541	1564	1519	1507	1558	1557	
(45)	RadStd	97	80	120	114	108	77	81	97	83	88	107	75	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.77	N/A	+0.49	N/A	N/A	N/A	N/A
Regional (30 neighbors)	N/A	N/A	N/A	N/A	+0.36	+0.38	N/A	N/A	+126	+126

Nomenclature: See separate page