

KO SICHANG, Thailand

WMO: 484600

Lat: 13.1627N

Lon: 100.8029E

Elev: 90

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.7	71.8	55.3	65.3	74.7	57.9	71.8	76.0	16.6	76.1	14.3	77.6	5.6	60	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.6	92.7	81.0	91.8	80.6	90.8	80.3	83.4	89.2	82.6	88.6	82.0	88.0	5.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.9	166.5	86.6	81.1	162.0	86.3	80.5	158.7	86.1	47.4	89.2	46.6	88.7	46.0	88.4	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.5	10.8	DB	66.3	96.7	2.1	3.6	64.8	99.3	63.5	101.5	62.3	103.5	60.8	106.1
			WB	59.0	84.6	3.0	1.6	56.9	85.7	55.1	86.7	53.5	87.6	51.3	88.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.4	80.2	82.1	84.2	86.1	85.9	85.2	84.5	84.1	83.1	82.7	82.0	80.4
	DBStd	2.94	2.65	2.17	2.34	2.39	2.39	1.76	1.84	1.68	1.69	1.71	2.34	3.35
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12187	935	900	1061	1084	1114	1056	1068	1058	994	1014	961	942
	CDD65	6712	470	480	596	634	649	606	603	593	544	549	511	477
	CDH74	80055	4583	5289	7275	8418	8703	8006	7629	7412	6418	6081	5502	4739
CDH80	32308	1333	1775	3009	4177	4304	3739	3248	3047	2322	2045	1816	1493	
Wind	WSAvg	3.3	3.2	2.8	3.1	3.0	3.0	3.6	4.0	3.8	2.6	2.5	4.0	4.4
Precipitation	PrecAvg	48.0	0.2	0.9	1.3	1.4	7.6	3.6	3.9	5.0	11.1	10.0	2.3	0.6
	PrecMax	74.5	1.4	3.7	4.8	4.2	15.4	7.8	5.9	16.9	21.0	28.8	7.7	5.4
	PrecMin	35.5	0.0	0.0	0.0	0.0	1.1	0.8	1.3	0.4	2.2	4.4	0.0	0.0
	PrecStd	10.7	0.5	1.0	1.4	1.5	3.9	2.5	1.4	3.8	4.7	5.8	2.2	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.0	91.4	92.5	94.2	94.1	91.8	90.6	90.5	90.5	91.3	92.2	91.6
		MCWB	76.7	76.9	79.6	81.8	81.3	80.8	80.1	79.7	80.1	80.5	79.7	79.2
	2%	DB	89.1	89.5	90.7	92.7	92.6	90.6	89.6	89.2	88.9	89.8	90.1	89.8
		MCWB	76.2	77.8	80.0	81.6	81.3	80.5	79.6	79.7	79.8	79.8	79.0	78.3
	5%	DB	87.3	88.1	89.7	91.8	91.4	89.7	88.7	88.4	87.9	88.7	88.7	88.2
		MCWB	75.8	77.9	79.8	81.4	80.9	80.3	79.5	79.5	79.7	79.6	78.5	77.3
	10%	DB	85.9	87.0	88.7	90.7	90.1	88.8	87.9	87.6	87.0	87.5	87.4	86.6
		MCWB	75.7	77.7	79.6	81.0	80.5	80.0	79.4	79.3	79.5	79.4	78.2	76.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.3	83.3	84.1	83.7	82.8	82.7	83.3	83.5	82.8	83.8	82.6
		MCDB	87.5	87.7	89.1	91.8	90.8	88.5	87.4	86.3	86.9	88.0	88.2	88.1
	2%	WB	79.8	80.3	81.8	82.9	82.8	81.9	81.8	81.9	81.9	81.7	81.8	80.7
		MCDB	85.3	86.7	88.3	90.4	89.5	87.8	86.7	85.8	86.1	87.0	86.7	86.6
	5%	WB	78.8	79.7	81.0	82.3	82.1	81.4	81.0	81.0	81.0	80.9	80.6	79.4
		MCDB	84.3	85.8	87.7	89.6	88.7	87.4	86.3	85.8	85.6	86.3	86.3	85.3
	10%	WB	78.0	79.0	80.4	81.7	81.5	80.9	80.4	80.3	80.4	80.3	79.6	78.4
		MCDB	83.3	85.0	87.1	88.8	88.2	87.0	85.9	85.7	85.2	85.5	84.9	84.2
Mean Daily Temperature Range	5% DB	MDBR	11.5	10.0	8.6	8.6	7.9	7.2	6.8	7.1	7.9	9.5	10.0	11.2
		MCDBR	13.5	11.4	9.6	9.1	8.8	7.9	7.5	7.8	8.7	11.0	12.0	12.9
		MCWBR	6.0	4.9	3.9	3.7	3.3	3.4	3.3	3.3	3.6	4.6	5.0	5.4
	5% WB	MCDBR	10.9	9.2	8.6	8.5	8.5	7.8	7.3	7.6	8.6	10.1	11.4	11.8
		MCWBR	5.5	4.4	4.0	4.0	3.7	3.7	3.5	3.8	4.3	4.7	5.1	5.4
Clear-Sky Solar Irradiance	taub	0.537	0.596	0.611	0.553	0.484	0.460	0.456	0.458	0.474	0.556	0.511	0.495	
	taud	1.994	1.869	1.871	2.055	2.302	2.374	2.381	2.363	2.305	2.032	2.140	2.141	
	Ebn at Noon	243	234	234	247	260	264	266	268	266	241	249	251	
	Edh at Noon	56	65	66	55	42	39	39	40	43	55	48	47	
All-Sky Solar Radiation	RadAvg	1605	1741	1776	1883	1704	1626	1567	1594	1544	1507	1557	1558	
	RadStd	98	82	133	120	116	82	85	101	87	91	114	79	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	+1.15	+0.94	+1.30	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.36	N/A	N/A	N/A	N/A	+0.36	+0.36	N/A	N/A	+130	+130

Nomenclature: See separate page