

KO SICHANG, Thailand

WMO: 484600

Lat: 13.1627N

Lon: 100.8029E

Elev: 27

StdP: 101.00

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	22.1	12.9	9.3	23.7	14.4	10.3	24.5	7.4	24.5	6.4	25.3	2.5	60	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	4.8	33.7	27.2	33.2	27.0	32.7	26.8	28.5	31.8	28.1	31.4	27.8	31.1	2.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.8	30.3	27.3	23.1	30.2	26.9	22.7	30.1	92.4	31.8	90.5	31.5	89.1	31.3	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.5	5.6	4.8	DB	19.1	35.9	1.2	2.0	18.2	37.4	17.5	38.6	16.8	39.7	16.0	41.2	
			WB	15.0	29.2	1.7	0.9	13.8	29.8	12.8	30.4	11.9	30.9	10.7	31.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.6	26.8	27.9	29.0	30.1	30.0	29.6	29.1	29.0	28.4	28.2	27.8	26.9
	DBStd	1.63	1.47	1.21	1.30	1.33	1.33	0.98	1.02	0.93	0.94	0.95	1.30	1.86
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6771	519	500	589	602	619	587	593	588	552	563	534	523
	CDD18.3	3729	261	267	331	352	361	337	335	329	302	305	284	265
	CDH23.3	44475	2546	2938	4042	4677	4835	4448	4238	4118	3566	3378	3057	2633
CDH26.7	17949	741	986	1672	2321	2391	2077	1804	1693	1290	1136	1009	829	
Wind	WSAvg	1.5	1.4	1.3	1.4	1.3	1.3	1.6	1.8	1.7	1.2	1.1	1.8	2.0
Precipitation	PrecAvg	1218	6	23	34	36	194	91	98	128	281	254	58	16
	PrecMax	1892	36	94	121	106	392	197	151	430	534	731	196	138
	PrecMin	902	0	0	0	0	29	20	32	10	57	111	0	0
	PrecStd	272	13	25	36	38	99	64	36	96	120	148	57	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	33.0	33.6	34.6	34.5	33.2	32.6	32.5	32.5	32.9	33.4	33.1
		MCWB	24.8	24.9	26.4	27.7	27.4	27.1	26.7	26.5	26.7	26.9	26.5	26.2
	2%	DB	31.7	31.9	32.6	33.7	33.6	32.5	32.0	31.8	31.6	32.1	32.3	32.1
		MCWB	24.6	25.5	26.7	27.6	27.4	26.9	26.5	26.5	26.6	26.6	26.1	25.7
	5%	DB	30.7	31.1	32.0	33.2	33.0	32.0	31.5	31.3	31.1	31.5	31.5	31.2
		MCWB	24.3	25.5	26.6	27.4	27.2	26.8	26.4	26.4	26.5	26.5	25.9	25.1
	10%	DB	29.9	30.6	31.5	32.6	32.3	31.6	31.0	30.9	30.6	30.8	30.8	30.4
		MCWB	24.3	25.4	26.4	27.2	27.0	26.7	26.4	26.3	26.4	26.3	25.6	24.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.4	28.5	28.9	28.7	28.2	28.2	28.5	28.6	28.2	28.8	28.1
		MCDB	30.8	30.9	31.7	33.2	32.7	31.4	30.8	30.2	30.5	31.1	31.2	31.2
	2%	WB	26.6	26.9	27.7	28.3	28.2	27.7	27.7	27.7	27.7	27.6	27.6	27.0
		MCDB	29.6	30.4	31.3	32.5	32.0	31.0	30.4	29.9	30.0	30.6	30.4	30.3
	5%	WB	26.0	26.5	27.2	27.9	27.8	27.4	27.2	27.2	27.2	27.2	27.0	26.3
		MCDB	29.0	29.9	30.9	32.0	31.5	30.8	30.1	29.9	29.8	30.2	30.1	29.6
	10%	WB	25.5	26.1	26.9	27.6	27.5	27.1	26.9	26.8	26.9	26.8	26.4	25.8
		MCDB	28.5	29.4	30.6	31.5	31.2	30.5	30.0	29.8	29.6	29.7	29.4	29.0
Mean Daily Temperature Range	5% DB	MDBR	6.4	5.6	4.8	4.8	4.4	4.0	3.8	3.9	4.4	5.3	5.6	6.2
		MCDBR	7.5	6.3	5.3	5.0	4.9	4.4	4.2	4.3	4.8	6.1	6.7	7.2
		MCWBR	3.4	2.7	2.2	2.1	1.8	1.9	1.8	1.9	2.0	2.5	2.8	3.0
	5% WB	MCDBR	6.0	5.1	4.8	4.7	4.7	4.4	4.1	4.2	4.8	5.6	6.3	6.6
MCWBR		3.1	2.4	2.2	2.2	2.1	2.1	2.0	2.1	2.4	2.6	2.8	3.0	
Clear-Sky Solar Irradiance	taub		0.537	0.596	0.611	0.553	0.484	0.460	0.456	0.458	0.474	0.556	0.511	0.495
	taud		1.994	1.869	1.871	2.055	2.302	2.374	2.381	2.363	2.305	2.032	2.140	2.141
	Ebn at Noon		765	738	739	779	820	831	837	845	838	761	784	792
	Edh at Noon		175	206	209	173	133	122	122	126	134	172	150	148
All-Sky Solar Radiation	RadAvg		5.06	5.49	5.60	5.94	5.37	5.13	4.94	5.02	4.87	4.75	4.91	4.91
	RadStd		0.31	0.26	0.42	0.38	0.37	0.26	0.27	0.32	0.28	0.29	0.36	0.25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.64	+0.52	+0.72	N/A	N/A	N/A	N/A
Regional (30 neighbors)	+0.20	N/A	N/A	N/A	+0.20	+0.20	N/A	N/A	+72	+72

Nomenclature: See separate page