

PHETCHABURI, Thailand

WMO: 484650

Lat: 12.9994N

Lon: 100.0606E

Elev: 4

StdP: 101.28

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	20.5	13.1	9.4	21.7	14.7	10.4	22.8	8.5	26.4	7.7	26.3	2.0	330	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.3	34.6	27.8	34.0	27.5	33.4	27.3	29.0	33.0	28.6	32.6	28.2	32.2	3.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.9	24.0	32.1	27.4	23.3	31.7	27.0	22.8	31.4	94.7	33.1	92.5	32.7	90.7	32.3	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.2	7.1	6.0		DB	16.7	36.4	2.2	1.0	15.1	37.1	13.9	37.7	12.7	38.3	11.1	39.0
				WB	14.2	29.5	2.1	0.7	12.7	30.0	11.5	30.4	10.3	30.8	8.8	31.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	26.1	27.4	28.7	29.9	30.0	29.7	29.2	29.2	28.8	28.4	27.6	26.3
	DBStd	1.81	1.57	1.43	1.40	1.13	1.19	0.92	1.01	0.92	0.98	1.11	1.44	1.93
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6727	498	488	580	596	619	590	594	595	564	569	529	504
	CDD18.3	3685	239	255	322	346	361	340	336	337	314	311	279	246
	CDH23.3	43635	2291	2886	4033	4709	4721	4299	4084	4061	3631	3539	3019	2361
	CDH26.7	17924	681	1018	1734	2370	2284	1933	1681	1647	1375	1312	1104	783
Wind	WSAvg	1.9	1.7	2.3	2.9	2.6	1.9	1.7	1.5	1.5	1.2	1.3	1.7	2.0
Precipitation	PrecAvg	1187	22	19	55	70	139	142	110	103	220	238	58	11
	PrecMax	1555	85	70	211	200	283	334	243	251	382	389	182	43
	PrecMin	923	0	0	1	5	32	21	22	44	108	106	2	0
	PrecStd	168	25	18	47	47	70	72	61	51	69	76	47	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	33.3	33.8	35.1	35.5	34.7	34.5	34.3	34.2	33.8	33.3	32.9
		MCWB	25.1	27.1	27.6	28.5	28.4	27.5	27.0	26.9	27.3	27.4	25.9	25.4
	2%	DB	31.2	32.1	33.0	34.2	34.6	33.8	33.3	33.2	33.1	32.7	32.5	31.9
		MCWB	24.9	26.4	27.2	28.1	28.1	27.3	26.8	26.8	27.1	26.8	25.8	25.2
	5%	DB	30.5	31.2	32.3	33.6	33.9	33.0	32.6	32.5	32.4	32.1	31.8	31.1
		MCWB	24.7	26.0	27.0	27.8	27.7	27.1	26.7	26.7	26.8	26.6	25.7	24.8
	10%	DB	29.8	30.6	31.7	32.9	33.0	32.3	31.9	31.8	31.6	31.4	31.2	30.3
		MCWB	24.4	25.7	26.8	27.5	27.4	26.9	26.5	26.5	26.6	26.4	25.4	24.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	28.2	28.6	29.9	29.5	28.8	28.6	28.5	28.5	28.1	27.7	27.2
		MCDB	30.6	32.1	32.5	33.6	34.1	32.8	32.5	32.3	32.7	32.6	31.4	31.0
	2%	WB	26.6	27.5	28.1	29.1	28.9	28.2	27.8	27.7	27.7	27.5	27.0	26.5
		MCDB	29.6	31.1	31.8	32.8	33.4	32.4	31.7	31.7	31.8	31.7	30.9	30.3
	5%	WB	26.1	27.0	27.7	28.6	28.4	27.8	27.4	27.3	27.3	27.1	26.6	25.9
		MCDB	29.2	30.3	31.3	32.3	32.8	32.0	31.4	31.4	31.3	31.2	30.4	29.8
	10%	WB	25.6	26.5	27.3	28.1	27.9	27.3	27.0	26.9	26.9	26.7	26.1	25.3
		MCDB	28.7	29.8	30.8	32.0	32.3	31.5	31.0	31.0	30.8	30.5	29.9	29.2
Mean Daily Temperature Range	5% DB	MDBR	7.6	6.7	6.0	6.3	6.1	5.8	5.6	5.7	5.9	5.9	6.7	7.7
		MCDBR	8.4	7.3	6.8	6.8	7.1	6.6	6.5	6.5	6.9	6.9	7.5	8.1
		MCWBR	4.3	4.1	3.7	3.7	3.4	3.2	3.2	3.1	3.1	2.7	2.9	3.5
	5% WB	MCDBR	6.7	6.3	6.0	6.4	6.6	6.1	6.0	6.0	6.4	6.5	6.7	7.4
		MCWBR	4.0	3.9	3.6	3.8	3.5	3.4	3.4	3.3	3.2	2.8	2.9	3.7
Clear-Sky Solar Irradiance	taub	0.533	0.580	0.598	0.538	0.471	0.446	0.443	0.444	0.457	0.551	0.523	0.509	
	taud	2.004	1.910	1.902	2.100	2.337	2.415	2.419	2.401	2.354	2.040	2.093	2.089	
	Ebn at Noon	770	752	749	791	831	843	848	857	853	765	773	779	
	Edh at Noon	173	197	203	166	128	117	117	121	127	171	157	156	
All-Sky Solar Radiation	RadAvg	4.96	5.48	5.61	5.96	5.30	4.90	4.67	4.74	4.76	4.53	4.74	4.79	
	RadStd	0.32	0.26	0.47	0.39	0.45	0.33	0.32	0.35	0.32	0.32	0.39	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.29	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	+142	+142
(47)	Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.20	N/A	N/A	N/A	N/A

Nomenclature: See separate page