

CHANTHABURI, Thailand

WMO: 484800

Lat: 12.6101N

Lon: 102.1040E

Elev: 12

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	67.5	69.6	52.8	59.4	73.3	55.9	66.7	74.4	17.4	70.9	14.4	75.3	4.9	40	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	13.9	94.2	79.6	93.2	79.3	92.3	79.1	82.3	90.7	81.8	89.7	81.3	88.9	3.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.2	157.0	85.8	79.8	154.9	85.5	79.3	152.1	85.1	46.2	90.9	45.6	90.4	45.1	89.1	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.7	9.7	8.0	DB	63.0	96.2	3.1	1.5	60.8	97.3	59.0	98.1	57.3	98.9	55.0	100.0	
			WB	56.4	83.8	2.9	1.5	54.3	84.9	52.5	85.8	50.9	86.6	48.8	87.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	80.8	82.0	83.6	84.9	84.2	83.3	82.6	82.6	82.1	82.6	82.2	80.5
	DBStd	2.65	2.69	2.16	2.05	2.02	2.34	2.12	2.12	2.00	1.90	1.98	2.63	3.59
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11904	954	896	1040	1046	1061	999	1012	1012	962	1012	965	945
	CDD65	6429	489	476	575	596	596	549	547	547	512	547	515	480
	CDH74	70253	4920	5136	6715	7201	7064	6307	6044	6037	5221	5528	5336	4744
CDH80	27350	1970	2063	2905	3328	2972	2391	2108	2059	1624	1964	2076	1890	
Wind	WSAvg	1.9	2.5	1.8	1.5	1.2	1.1	1.3	1.6	1.5	1.0	1.7	3.4	3.9
Precipitation	PrecAvg	113.7	0.8	1.5	2.7	4.7	14.5	18.7	17.7	19.1	20.2	11.3	2.8	0.4
	PrecMax	161.3	6.2	7.0	9.6	18.3	30.2	34.5	37.0	35.0	37.9	32.7	17.2	3.1
	PrecMin	74.7	0.0	0.0	0.0	0.1	3.8	0.7	1.0	8.7	8.9	3.0	0.0	0.0
	PrecStd	19.5	1.2	1.4	2.2	3.1	6.5	7.2	7.4	5.8	7.0	6.2	3.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	93.5	94.0	95.3	95.4	92.7	91.7	91.5	91.9	93.3	93.9	94.1
		MCWB	74.9	75.6	79.0	81.1	81.8	81.5	80.7	80.8	80.5	79.1	77.8	76.7
	2%	DB	91.8	91.6	92.6	94.1	93.5	91.1	90.0	89.8	90.0	91.7	92.4	92.2
		MCWB	74.8	76.4	79.1	80.9	81.4	80.9	80.2	80.1	80.2	78.9	77.9	76.3
	5%	DB	90.4	90.3	91.5	92.9	92.1	89.9	88.8	88.6	88.5	90.2	91.1	90.8
		MCWB	75.0	77.0	79.1	80.6	81.1	80.4	79.9	79.8	79.7	78.9	77.6	75.9
	10%	DB	88.8	89.0	90.4	91.8	90.4	88.5	87.6	87.4	87.0	88.6	89.5	89.0
		MCWB	75.2	77.1	79.0	80.4	80.8	80.1	79.5	79.5	79.3	78.7	77.4	75.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.8	81.7	82.8	83.2	82.6	81.9	81.8	81.8	81.7	81.1	80.2
		MCDB	88.2	89.8	91.2	92.4	91.8	89.3	88.7	88.7	88.9	89.3	89.5	89.1
	2%	WB	79.1	79.9	80.9	81.9	82.4	81.8	81.0	81.0	80.9	80.7	80.2	79.1
		MCDB	86.8	88.4	90.1	91.2	90.9	88.5	87.3	87.1	87.5	88.5	88.6	87.9
	5%	WB	78.3	79.2	80.2	81.4	81.8	81.2	80.6	80.5	80.3	80.0	79.4	78.0
		MCDB	85.6	87.1	88.9	90.5	89.6	87.5	86.6	86.2	86.4	87.3	87.6	86.8
	10%	WB	77.5	78.7	79.7	80.9	81.2	80.7	80.1	80.0	79.8	79.3	78.5	76.9
		MCDB	84.5	86.3	88.0	89.6	88.4	86.7	85.7	85.4	85.4	86.1	86.3	85.7
Mean Daily Temperature Range	5% DB	MDBR	17.0	15.3	14.0	13.9	11.7	10.1	9.4	9.4	10.1	12.5	14.1	15.9
		MCDBR	18.7	16.8	15.4	15.2	14.3	11.8	11.1	11.0	12.4	14.7	16.2	17.8
		MCWBR	7.2	6.3	5.4	4.9	4.6	4.2	4.0	3.8	4.4	5.2	5.7	6.5
	5% WB	MCDBR	15.2	14.2	14.2	14.4	12.7	10.9	10.3	10.1	11.1	13.1	14.7	16.2
MCWBR		6.1	5.2	5.2	5.1	4.7	4.5	4.2	3.9	4.5	5.1	5.6	6.4	
Clear-Sky Solar Irradiance	taub		0.569	0.615	0.615	0.549	0.478	0.469	0.468	0.468	0.473	0.517	0.480	0.478
	taud		1.906	1.813	1.863	2.059	2.299	2.343	2.339	2.332	2.303	2.147	2.236	2.201
	Ebn at Noon		234	230	234	248	262	261	262	266	266	252	259	257
	Edh at Noon		61	69	67	55	42	40	40	41	43	49	43	44
All-Sky Solar Radiation	RadAvg		1586	1657	1680	1736	1545	1478	1427	1435	1396	1472	1551	1553
	RadStd		105	83	104	109	106	82	93	105	89	108	109	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	+0.52	N/A	N/A	N/A	+0.45	+0.47	N/A	N/A	+211	+211
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page