

CHANTHABURI, Thailand

WMO: 484800

Lat: 12.6101N

Lon: 102.1040E

Elev: 4

StdP: 101.28

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 19.7	(c) 20.9	(d) 11.6	(e) 8.5	(f) 22.9	(g) 13.3	(h) 9.5	(i) 23.5	(j) 7.8	(k) 21.6	(l) 6.4	(m) 24.1	(n) 2.2	(o) 40	(p) 0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 7.7	(c) 34.5	(d) 26.5	(e) 34.0	(f) 26.3	(g) 33.5	(h) 26.2	(i) 28.0	(j) 32.6	(k) 27.7	(l) 32.0	(m) 27.4	(n) 31.6	(o) 1.8	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.8	(b) 22.4	(c) 29.9	(d) 26.6	(e) 22.1	(f) 29.7	(g) 26.3	(h) 21.7	(i) 29.5	(j) 89.5	(k) 32.7	(l) 88.1	(m) 32.4	(n) 87.0	(o) 31.7	(p) 32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.2	(b) 4.3	(c) 3.6	(e) 17.2	(f) 35.7	(g) 1.7	(h) 0.8	(i) 16.0	(j) 36.3	(k) 15.0	(l) 36.7	(m) 14.0	(n) 37.2	(o) 12.8	(p) 37.8		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			13.5	28.8	1.6	0.9	12.4	29.4	11.4	29.9	10.5	30.4	9.3	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.1	27.8	28.6	29.4	29.0	28.5	28.1	28.1	27.8	28.1	27.9	26.9		
	DBStd	1.47	1.49	1.20	1.14	1.12	1.30	1.18	1.18	1.11	1.06	1.10	1.46	1.99		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6613	530	498	578	581	589	555	562	562	534	562	536	525		
	CDD18.3	3572	272	264	319	331	331	305	304	304	284	304	286	267		
	CDH23.3	39029	2733	2853	3731	4001	3924	3504	3358	3354	2901	3071	2964	2636		
(13)	CDH26.7	15194	1094	1146	1614	1849	1651	1328	1171	1144	902	1091	1153	1050		
(14)	Wind	WSAvg	0.8	1.1	0.8	0.7	0.6	0.5	0.6	0.7	0.5	0.8	1.5	1.7		
(15) Precipitation	PrecAvg	2889	21	38	68	120	369	476	449	484	512	286	70	11		
	PrecMax	4097	158	178	243	464	766	877	940	890	963	830	437	80		
	PrecMin	1897	0	0	0	2	96	19	25	222	226	76	0	0		
	PrecStd	496	30	35	56	80	164	184	188	148	178	157	76	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	34.2	34.5	35.2	35.2	33.7	33.1	33.1	33.3	34.1	34.4	34.5		
		MCWB	23.9	24.2	26.1	27.3	27.7	27.5	27.0	27.1	26.9	26.2	25.4	24.8		
	2%	DB	33.2	33.1	33.7	34.5	34.2	32.8	32.2	32.1	32.2	33.1	33.6	33.4		
		MCWB	23.8	24.7	26.2	27.2	27.4	27.1	26.8	26.7	26.8	26.0	25.5	24.6		
	5%	DB	32.4	32.4	33.1	33.9	33.4	32.1	31.6	31.4	31.4	32.4	32.8	32.6		
		MCWB	23.9	25.0	26.2	27.0	27.3	26.9	26.6	26.5	26.5	26.0	25.4	24.4		
	10%	DB	31.6	31.7	32.4	33.2	32.4	31.4	30.9	30.8	30.6	31.5	31.9	31.6		
		MCWB	24.0	25.1	26.1	26.9	27.1	26.7	26.4	26.4	26.3	26.0	25.2	24.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.1	27.6	28.2	28.5	28.1	27.7	27.7	27.7	27.6	27.3	26.8		
		MCDB	31.2	32.1	32.9	33.5	33.2	31.8	31.5	31.5	31.6	31.8	32.0	31.7		
	2%	WB	26.2	26.6	27.1	27.7	28.0	27.7	27.2	27.2	27.2	27.1	26.8	26.1		
		MCDB	30.4	31.3	32.3	32.9	32.7	31.4	30.7	30.6	30.8	31.4	31.4	31.1		
	5%	WB	25.7	26.2	26.8	27.5	27.6	27.3	27.0	26.9	26.8	26.7	26.4	25.5		
		MCDB	29.8	30.6	31.6	32.5	32.0	30.9	30.3	30.1	30.2	30.7	30.9	30.4		
	10%	WB	25.3	26.0	26.5	27.1	27.3	27.1	26.7	26.7	26.5	26.3	25.9	25.0		
		MCDB	29.2	30.1	31.1	32.0	31.4	30.4	29.8	29.7	29.6	30.0	30.1	29.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	8.5	7.8	7.7	6.5	5.6	5.2	5.2	5.6	6.9	7.8	8.8		
		MCDBR	10.4	9.3	8.6	8.4	7.9	6.6	6.2	6.1	6.9	8.2	9.0	9.9		
		MCWBR	4.0	3.5	3.0	2.7	2.6	2.3	2.2	2.1	2.4	2.9	3.1	3.6		
	5% WB	MCDBR	8.5	7.9	7.9	8.0	7.0	6.1	5.7	5.6	6.2	7.3	8.2	9.0		
		MCWBR	3.4	2.9	2.9	2.9	2.6	2.5	2.3	2.2	2.5	2.9	3.1	3.5		
(40) Clear-Sky Solar Irradiance	taub	0.569	0.615	0.615	0.549	0.478	0.469	0.468	0.468	0.468	0.473	0.517	0.480	0.478		
	taud	1.906	1.813	1.863	2.059	2.299	2.343	2.339	2.332	2.303	2.147	2.236	2.201			
	Ebn at Noon	739	724	737	782	825	823	827	837	839	796	815	811			
	Edh at Noon	192	218	211	173	133	126	127	130	134	154	137	140			
(44) All-Sky Solar Radiation	RadAvg	5.00	5.22	5.29	5.47	4.87	4.66	4.50	4.53	4.40	4.64	4.89	4.90			
	RadStd	0.33	0.26	0.33	0.34	0.33	0.26	0.29	0.33	0.28	0.34	0.34	0.26			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.29	N/A	N/A	N/A	+0.25	+0.26	N/A	N/A	+117	+117
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.20	N/A	N/A	N/A	N/A

Nomenclature: See separate page