

PHLIU AGROMET, Thailand

WMO: 484810

Lat: 12.5105N

Lon: 102.1700E

Elev: 24

StdP: 101.03

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.5	19.9	13.0	9.4	22.7	14.7	10.4	24.0	5.5	28.2	4.5	28.7	0.4	N/A	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.9	33.8	26.2	33.3	26.1	32.8	26.1	28.1	31.7	27.7	31.2	27.5	30.8	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.6	26.9	22.6	29.3	26.6	22.3	29.1	90.2	31.4	88.5	31.5	87.3	31.0	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
4.3	3.4	2.9	DB	16.2	35.1	1.6	0.9	15.1	35.7	14.2	36.2	13.3	36.7	12.1	37.3	37.3
			WB	14.2	29.3	1.4	1.3	13.2	30.2	12.4	31.0	11.6	31.7	10.6	32.6	32.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.5	27.2	28.1	28.8	28.7	28.1	27.8	27.8	27.5	27.7	27.7	26.6
	DBStd	1.37	1.56	1.27	1.09	1.09	1.08	1.03	1.03	0.92	1.03	0.98	1.12	1.72
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6466	511	482	561	564	581	543	551	552	524	549	531	516
	CDD18.3	3424	253	248	302	314	323	293	292	293	274	291	281	258
	CDH23.3	35016	2307	2415	3195	3556	3692	3212	3082	3064	2624	2724	2737	2407
Wind	WSAvg	0.6	0.6	0.6	0.6	0.5	0.4	0.5	0.7	0.7	0.5	0.4	0.6	0.7
	PrecAvg	2999	24	39	81	124	367	486	513	464	554	282	57	8
Precipitation	PrecMax	3829	147	100	230	446	724	833	1001	717	923	785	199	52
	PrecMin	2255	0	2	4	24	139	177	241	240	233	130	0	0
	PrecStd	399	32	29	61	88	149	157	174	129	182	124	54	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	33.8	33.6	34.3	34.2	32.9	32.1	32.2	32.7	33.6	34.1	34.2
		MCWB	24.1	23.8	25.8	27.1	27.6	27.3	26.7	26.9	27.0	26.3	25.6	25.8
	2%	DB	32.6	32.5	32.7	33.6	33.3	32.1	31.4	31.5	31.6	32.8	33.3	33.1
		MCWB	23.9	24.4	26.2	27.1	27.5	27.1	26.6	26.7	26.9	26.2	25.4	25.0
	5%	DB	31.9	31.7	32.1	32.9	32.7	31.4	30.9	30.8	31.0	31.9	32.6	32.3
		MCWB	23.9	25.0	26.2	27.0	27.4	26.9	26.5	26.5	26.7	26.4	25.4	24.8
	10%	DB	31.0	30.9	31.5	32.2	31.8	30.8	30.3	30.2	30.1	31.1	31.7	31.4
		MCWB	24.1	25.0	26.1	26.8	27.2	26.8	26.4	26.4	26.4	26.3	25.4	24.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	26.9	27.6	28.3	28.6	28.1	27.6	27.7	27.8	27.8	27.4	27.5
		MCDB	30.9	31.2	31.6	32.7	32.3	31.0	30.4	30.7	31.1	31.5	31.2	31.9
	2%	WB	26.3	26.5	27.1	27.7	28.1	27.7	27.2	27.3	27.4	27.2	27.0	26.6
		MCDB	30.0	30.5	31.2	31.8	31.8	30.4	29.9	30.1	30.5	31.0	31.1	31.1
	5%	WB	25.8	26.1	26.7	27.5	27.7	27.4	27.0	27.0	27.0	26.9	26.6	25.9
		MCDB	29.2	29.8	30.6	31.4	31.2	30.0	29.6	29.7	30.0	30.6	30.6	30.2
	10%	WB	25.3	25.8	26.5	27.1	27.4	27.1	26.7	26.7	26.7	26.5	26.0	25.2
		MCDB	28.5	29.2	30.0	30.9	30.7	29.7	29.2	29.2	29.2	29.9	30.0	29.4
Mean Daily Temperature Range	5% DB	MDBR	9.7	8.1	7.0	7.0	5.9	5.2	4.8	5.0	5.3	6.8	8.3	9.6
		MCDBR	10.7	9.4	7.9	7.7	7.2	6.1	5.5	5.7	6.5	8.2	9.5	10.4
	5% WB	MCWBR	3.8	3.3	2.6	2.4	2.5	2.1	1.9	2.1	2.4	3.0	3.3	3.9
		MCDBR	8.0	7.1	7.0	7.0	6.6	5.6	5.1	5.3	5.9	7.2	8.0	8.9
		MCWBR	3.4	2.6	2.5	2.6	2.6	2.3	2.1	2.2	2.5	3.1	3.3	4.0
Clear-Sky Solar Irradiance	taub		0.567	0.611	0.610	0.544	0.475	0.467	0.466	0.465	0.469	0.511	0.477	0.475
	taud		1.913	1.825	1.876	2.073	2.311	2.353	2.346	2.340	2.315	2.165	2.248	2.211
	Ebn at Noon		741	728	741	786	828	825	828	839	842	801	818	815
	Edh at Noon		191	215	208	170	132	125	126	129	132	151	135	139
All-Sky Solar Radiation	RadAvg		5.00	5.21	5.28	5.43	4.82	4.60	4.45	4.46	4.35	4.61	4.88	4.89
	RadStd		0.33	0.26	0.33	0.35	0.34	0.26	0.29	0.34	0.28	0.35	0.35	0.26

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.20	N/A	N/A	N/A

Nomenclature: See separate page