

SURAT THANI AGROMET, Thailand

WMO: 485550

Lat: 9.143N

Lon: 99.636E

Elev: 37

StdP: 100.88

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.4	21.4	19.0	13.9	24.2	19.8	14.6	25.5	4.9	29.1	4.3	29.4	0.0	N/A	0.276

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.3	35.0	26.2	34.2	26.0	33.5	25.9	27.5	31.9	27.1	31.7	26.8	31.4	1.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.9	29.4	26.0	21.5	29.2	25.7	21.0	28.9	87.2	32.1	85.7	32.1	84.4	31.5	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.4	3.7	3.2	DB	18.8	35.9	1.4	1.2	17.7	36.8	16.9	37.5	16.1	38.2	15.1	39.1	(4)
(5)			WB	18.5	27.8	1.4	0.6	17.5	28.2	16.6	28.6	15.8	28.9	14.8	29.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	26.1	26.8	27.8	28.5	28.6	28.3	28.1	28.0	27.7	27.2	26.6	26.1	(6)	
	DBStd	1.35	1.18	0.98	1.07	1.27	1.06	0.95	0.92	0.85	0.82	0.91	1.03	1.10	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6384	498	470	552	556	578	549	562	558	530	534	498	499	(10)	
	CDD18.3	3343	239	237	294	306	319	299	303	299	280	276	248	241	(11)	
	CDH23.3	31402	1889	2246	3047	3264	3230	3079	3043	2923	2528	2362	1955	1836	(12)	
(13)	CDH26.7	11805	553	856	1356	1502	1337	1223	1167	1114	880	776	556	485	(13)	
(14)	Wind	WSAvg	0.6	0.5	0.8	0.6	0.5	0.7	0.7	0.7	0.6	0.4	0.3	0.4	(14)	
(15) Precipitation	PrecAvg	2112	61	31	85	87	204	206	219	223	245	281	300	170	(15)	
	PrecMax	2576	293	196	772	238	310	306	333	523	390	621	638	576	(16)	
	PrecMin	1667	3	0	1	3	110	134	106	105	123	130	113	52	(17)	
	PrecStd	236	62	42	149	61	52	50	57	77	62	115	143	117	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	33.1	35.1	36.4	36.3	34.5	34.2	34.4	33.7	33.1	32.6	32.1	(19)	
		MCWB	25.6	24.8	25.8	26.1	26.7	26.5	25.9	24.8	26.0	26.1	26.0	26.1	(20)	
	2%	DB	31.2	32.4	34.2	35.2	34.6	33.6	33.3	33.2	32.7	32.2	31.7	31.2	(21)	
		MCWB	25.3	24.7	25.5	26.4	26.5	26.3	25.9	25.5	25.8	25.9	25.9	25.8	(22)	
	5%	DB	30.5	31.7	33.4	34.2	33.5	32.8	32.5	32.4	32.0	31.4	30.9	30.5	(23)	
		MCWB	25.0	24.7	25.4	26.2	26.4	26.1	25.8	25.6	25.8	25.8	25.9	25.6	(24)	
	10%	DB	29.7	31.1	32.5	33.2	32.5	32.0	31.6	31.6	31.0	30.6	30.0	29.5	(25)	
		MCWB	24.8	24.6	25.3	26.1	26.3	26.0	25.7	25.6	25.6	25.8	25.8	25.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.4	27.0	27.7	27.7	27.5	27.6	27.4	27.2	27.5	27.2	27.1	(27)	
		MCDB	30.0	30.8	32.8	33.4	32.4	31.9	31.6	31.2	31.5	30.9	30.4	30.3	(28)	
	2%	WB	26.1	25.8	26.5	27.2	27.2	27.0	26.9	26.7	26.7	26.9	26.7	26.5	(29)	
		MCDB	29.7	30.2	32.1	33.1	32.2	31.9	31.2	30.7	30.9	30.6	29.9	29.9	(30)	
	5%	WB	25.7	25.4	26.0	26.7	26.9	26.6	26.4	26.3	26.3	26.4	26.3	26.1	(31)	
		MCDB	29.1	29.8	31.5	32.5	31.9	31.3	30.6	30.4	30.4	30.1	29.6	29.3	(32)	
	10%	WB	25.2	25.0	25.6	26.4	26.6	26.2	26.0	25.9	25.9	26.0	25.9	25.6	(33)	
		MCDB	28.5	29.4	30.8	31.8	31.2	30.8	30.2	30.0	29.8	29.6	29.2	28.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	9.4	9.7	9.3	8.6	7.9	7.7	7.9	7.6	7.1	6.3	6.4	(35)	
		MCDBR	8.7	10.2	11.3	10.9	9.8	9.1	8.9	9.1	8.8	8.4	8.4	8.4	(36)	
	5% WB	MCWBR	3.4	3.6	3.6	3.3	3.1	2.9	2.9	2.9	2.9	3.0	3.4	3.5	(37)	
		MCWBR	7.5	9.2	10.2	10.0	9.0	8.3	8.0	7.9	8.0	7.5	7.1	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.481	0.488	0.495	0.467	0.441	0.436	0.437	0.430	0.423	0.444	0.469	0.477	(40)	
		taud	2.205	2.179	2.198	2.282	2.399	2.445	2.429	2.435	2.445	2.381	2.292	2.234	(41)	
	Ebn at Noon		831	839	836	849	854	848	851	869	886	868	837	825	(42)	
		Edh at Noon	145	153	152	138	120	113	116	117	117	123	132	139	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.52	5.46	5.75	5.73	5.12	4.88	4.79	4.91	4.87	4.36	3.88	3.85	(44)	
	RadStd		0.42	0.35	0.49	0.34	0.30	0.25	0.30	0.27	0.22	0.38	0.38	0.40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.19	+0.35	N/A	N/A	+0.20	+0.23	N/A	N/A	N/A	N/A

Nomenclature: See separate page