

PHRASANG, Thailand

WMO: 485560

Lat: 8.5721N

Lon: 99.2552E

Elev: 14

StdP: 101.16

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.8	21.7	18.7	13.6	27.0	19.5	14.3	27.5	5.7	28.3	5.1	28.5	0.0	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.0	35.8	25.3	34.8	25.3	33.9	25.5	27.6	31.5	27.2	31.4	26.8	31.2	1.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	30.0	26.1	21.5	29.5	25.7	21.0	29.0	87.9	31.3	85.9	31.5	84.4	31.3	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.6	3.5	3.2	DB	18.6	36.6	1.3	1.6	17.6	37.8	16.9	38.7	16.2	39.6	15.3	40.8	(4)
(5)			WB	18.1	28.5	1.3	0.7	17.2	29.0	16.4	29.4	15.7	29.8	14.8	30.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.9	27.6	28.4	29.0	28.4	28.0	27.7	27.6	27.5	27.3	26.9	(6)	
(7)		DBStd	1.22	1.06	0.96	1.17	1.20	1.21	0.98	0.96	0.93	0.98	0.92	1.09	1.10	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6477	524	492	572	570	571	541	548	546	528	543	518	524	(10)
(11)		CDD18.3	3435	266	258	313	320	313	291	290	288	278	285	268	266	(11)
(12)		CDH23.3	32134	2318	2638	3293	3351	3047	2835	2713	2627	2438	2430	2246	2199	(12)
(13)		CDH26.7	12201	834	1221	1588	1572	1199	1039	946	907	812	759	661	664	(13)
(14)	Wind	WSAvg	0.5	0.6	0.6	0.6	0.5	0.5	0.6	0.6	0.5	0.4	0.4	0.5	0.6	(14)
(15)	Precipitation	PrecAvg	1796	68	41	96	113	186	158	185	177	201	218	215	141	(15)
(16)		PrecMax	2101	261	149	222	202	251	265	357	242	273	311	342	399	(16)
(17)		PrecMin	1465	4	0	0	34	96	70	94	98	119	129	111	41	(17)
(18)		PrecStd	204	68	40	71	48	39	46	59	40	42	46	73	97	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.4	35.2	36.8	37.6	36.5	34.0	33.7	33.7	33.6	33.3	33.2	33.0	(19)
(20)			MCWB	25.4	24.5	24.9	25.7	26.4	26.3	25.6	25.7	26.1	26.0	26.0	26.0	(20)
(21)		2%	DB	32.5	34.2	35.6	36.1	34.4	33.1	32.8	32.8	32.7	32.2	32.2	32.2	(21)
(22)			MCWB	25.2	24.5	24.9	25.4	26.4	26.2	26.0	25.8	26.0	26.1	26.0	25.6	(22)
(23)		5%	DB	31.7	33.4	34.7	34.8	33.2	32.4	32.0	32.0	31.9	31.5	31.4	31.2	(23)
(24)			MCWB	25.1	24.6	24.9	25.8	26.6	26.2	26.0	25.9	26.0	26.0	26.0	25.6	(24)
(25)		10%	DB	30.8	32.5	33.5	33.4	32.1	31.5	31.1	31.1	30.9	30.6	30.3	30.2	(25)
(26)			MCWB	25.1	24.7	25.1	25.8	26.5	26.2	26.0	25.9	25.9	26.0	25.9	25.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.9	27.2	28.2	28.5	27.7	27.4	27.4	27.6	27.5	27.4	27.0	(27)
(28)			MCD B	30.5	31.9	32.1	32.7	32.4	31.3	30.8	30.5	30.9	30.5	30.8	30.9	(28)
(29)		2%	WB	26.1	26.2	26.4	27.1	27.4	27.1	26.7	26.7	26.8	26.8	26.7	26.2	(29)
(30)			MCD B	30.5	31.3	31.8	32.6	32.1	31.1	30.6	30.5	30.9	30.6	30.5	30.2	(30)
(31)		5%	WB	25.7	25.7	26.0	26.6	27.0	26.7	26.5	26.4	26.4	26.4	26.3	26.0	(31)
(32)			MCD B	30.0	30.8	31.5	32.1	31.8	30.8	30.4	30.3	30.4	30.2	30.0	29.9	(32)
(33)		10%	WB	25.4	25.4	25.7	26.2	26.6	26.4	26.1	26.1	26.1	26.0	26.0	25.6	(33)
(34)			MCD B	29.5	30.4	31.0	31.5	31.0	30.4	30.1	30.1	30.1	29.9	29.6	29.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	11.1	10.8	10.0	8.2	7.4	7.2	7.3	7.2	7.0	6.5	7.1	(35)
(36)			MCDBR	9.9	12.3	12.8	12.0	9.8	8.7	8.6	8.7	8.5	8.2	8.2	8.7	(36)
(37)			MCWBR	3.5	4.1	3.6	3.1	3.1	2.8	2.8	2.9	2.8	2.9	2.9	3.0	(37)
(38)		5% WB	MCDBR	8.7	10.6	10.6	10.3	8.9	7.8	7.6	7.6	7.7	7.5	7.3	7.7	(38)
(39)			MCWBR	3.5	4.2	3.6	3.4	3.5	3.2	3.2	3.2	3.2	3.2	3.1	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.469	0.480	0.489	0.471	0.446	0.446	0.447	0.440	0.431	0.441	0.458	0.467	(40)	
(41)		taud	2.221	2.176	2.185	2.237	2.347	2.384	2.366	2.376	2.395	2.353	2.296	2.247	(41)	
(42)		Ebn at Noon	844	847	842	845	849	839	841	860	879	871	849	837	(42)	
(43)		Edh at Noon	143	154	154	144	126	120	123	124	123	127	132	137	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.61	5.58	5.74	5.63	4.88	4.72	4.61	4.72	4.64	4.31	4.00	3.97	(44)	
(45)		RadStd	0.41	0.41	0.53	0.33	0.30	0.28	0.27	0.28	0.20	0.37	0.32	0.38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.18	+0.33	N/A	N/A	+0.19	+0.21	N/A	N/A	N/A	N/A

Nomenclature: See separate page