

CHAWANG, Thailand

WMO: 485570

Lat: 8.424N

Lon: 99.506E

Elev: 30

StdP: 100.96

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.3	21.3	18.3	13.2	26.8	19.2	14.0	26.5	4.7	29.3	4.0	31.5	0.0	N/A	0.281

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.6	36.6	26.0	35.3	25.9	34.4	26.0	27.7	32.8	27.4	32.4	27.2	32.1	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.1	30.2	26.2	21.6	29.9	25.9	21.3	29.7	88.6	33.0	87.2	32.4	86.0	32.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 4.0	3.2	2.5		18.6	37.3	1.2	1.7	17.7	38.5	17.0	39.5	16.3	40.4	15.4		
(5)				18.2	28.6	1.3	0.5	17.3	29.0	16.6	29.3	15.8	29.5	14.9	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	26.8	27.5	28.5	29.2	28.8	28.3	27.9	27.9	27.7	27.7	27.3	26.8		
	DBStd	1.33	1.20	0.97	1.28	1.39	1.28	1.00	0.95	0.89	1.05	0.99	1.20	1.08		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6524	521	489	574	577	583	548	554	554	532	549	519	522		
	CDD18.3	3482	263	256	316	327	325	298	296	296	282	291	269	263		
	CDH23.3	33115	2281	2643	3457	3503	3274	2973	2786	2746	2477	2509	2292	2174		
	CDH26.7	13486	886	1275	1775	1719	1370	1171	1023	1023	874	867	757	745		
(14) Wind	WSAvg	0.3	0.4	0.5	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.3		
(15) Precipitation	PrecAvg	2122	102	55	101	114	195	163	189	202	211	233	322	235		
	PrecMax	2532	307	248	273	227	261	298	446	312	266	321	537	537		
	PrecMin	1466	12	2	0	14	126	68	108	144	131	154	175	83		
	PrecStd	238	79	64	84	59	39	48	72	47	40	50	116	130		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	35.4	37.5	38.7	37.7	34.5	34.2	34.3	34.1	34.0	33.8	33.5		
		MCWB	25.3	24.5	25.8	26.6	26.7	27.0	26.7	26.3	26.8	26.4	26.4	25.9		
	2%	DB	33.0	34.5	36.4	36.9	35.1	33.7	33.1	33.4	33.2	33.0	33.0	32.4		
		MCWB	25.0	24.5	25.5	26.3	27.3	26.7	26.5	26.3	26.5	26.5	26.2	25.5		
	5%	DB	32.2	33.7	35.3	35.3	33.9	33.0	32.5	32.5	32.3	32.1	32.0	31.6		
		MCWB	24.8	24.5	25.2	26.3	27.1	26.6	26.4	26.2	26.4	26.4	26.1	25.4		
	10%	DB	31.2	32.8	34.1	34.0	32.7	32.1	31.5	31.5	31.2	31.1	30.8	30.7		
		MCWB	24.7	24.5	25.3	26.5	26.9	26.5	26.3	26.2	26.1	26.2	26.0	25.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	26.6	27.2	28.0	28.1	28.0	27.7	27.7	27.6	27.7	27.3	27.1		
		MCDB	31.6	32.2	33.6	34.3	33.8	32.8	32.0	32.0	32.4	32.0	31.6	31.2		
	2%	WB	26.2	25.9	26.6	27.4	27.7	27.5	27.2	27.1	27.1	27.1	26.9	26.5		
		MCDB	30.8	31.3	33.0	33.7	33.0	32.1	31.5	31.4	31.9	31.5	31.1	30.6		
	5%	WB	25.7	25.5	26.2	27.0	27.3	27.1	26.8	26.7	26.6	26.7	26.5	26.1		
		MCDB	30.0	31.0	32.5	33.3	32.5	31.6	31.0	30.9	31.1	30.9	30.5	30.1		
	10%	WB	25.2	25.1	25.8	26.6	27.0	26.7	26.5	26.4	26.3	26.3	26.2	25.6		
		MCDB	29.3	30.7	32.0	32.5	32.0	30.9	30.5	30.4	30.4	30.3	29.9	29.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	11.7	11.7	10.6	8.8	8.0	7.7	7.9	7.6	7.7	7.2	8.0		
		MCDBR	10.8	12.8	13.7	12.4	10.3	9.3	9.1	9.5	9.1	9.1	9.3	9.7		
		MCWBR	3.5	3.9	4.0	3.4	3.5	3.2	3.3	3.4	3.2	3.3	3.3	3.5		
	5% WB	MCDBR	9.4	11.0	11.7	10.9	9.4	8.5	8.3	8.3	8.5	8.3	8.1	8.4		
		MCWBR	3.6	3.8	3.7	3.6	3.6	3.3	3.4	3.4	3.4	3.4	3.3	3.5		
(40) Clear-Sky Solar Irradiance	taub	0.489	0.498	0.507	0.484	0.458	0.458	0.458	0.459	0.453	0.443	0.454	0.472	0.482		
	taud	2.161	2.122	2.133	2.201	2.311	2.344	2.326	2.336	2.357	2.321	2.253	2.199			
	Ebn at Noon	826	831	827	835	839	828	830	849	869	860	835	822			
	Edh at Noon	152	162	162	150	131	125	128	129	128	131	138	144			
(44) All-Sky Solar Radiation	RadAvg	4.48	5.50	5.66	5.56	4.89	4.74	4.62	4.75	4.65	4.26	3.85	3.83			
	RadStd	0.42	0.42	0.54	0.33	0.28	0.26	0.26	0.26	0.16	0.34	0.32	0.38			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.18	+0.27	N/A	N/A	+0.18	+0.20	N/A	N/A	+61	+61

Nomenclature: See separate page