

KRABI, Thailand

WMO: 485630

Lat: 8.1036N

Lon: 98.9753E

Elev: 102

StdP: 14.64

Time Zone: 7.00 (E07)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.2	72.3	64.2	90.2	86.7	65.9	95.8	84.7	13.8	82.6	12.2	82.1	1.5	N/A	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	16.4	95.8	77.5	94.3	77.5	92.7	77.7	81.5	89.3	80.9	88.5	80.5	87.9	5.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	154.3	84.7	79.1	151.3	84.2	78.6	148.8	83.7	45.3	89.7	44.7	88.9	44.2	88.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.7	8.5	68.3	98.0	2.3	3.0	66.7	100.1	65.3	101.8	64.1	103.5	62.4	105.6		
(5)			66.8	83.0	2.4	0.7	65.0	83.5	63.6	84.0	62.3	84.4	60.5	84.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	80.9	82.3	83.8	84.1	83.2	82.0	81.3	81.1	80.9	80.9	81.0	80.6		
	DBStd	2.17	1.66	1.57	2.15	2.15	1.98	1.85	1.79	1.67	1.85	1.74	1.76	1.61		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11623	958	905	1047	1024	1028	959	970	965	927	959	931	950		
	CDD65	6148	493	485	582	574	563	509	505	500	477	494	481	485		
	CDH74	58922	4372	5037	6472	6345	5888	5083	4749	4584	4135	4128	4066	4063		
(13)	CDH80	22379	1636	2347	3205	2947	2307	1778	1539	1450	1290	1303	1279	1298		
(14)	Wind	WSAvg	2.1	3.3	3.0	2.3	1.8	1.3	1.5	1.4	1.6	1.6	2.4	3.6		
(15) Precipitation	PrecAvg	88.9	2.5	1.5	4.8	5.9	8.4	9.5	9.1	11.6	12.4	12.0	7.7	3.2		
	PrecMax	109.1	14.4	5.0	20.6	10.6	17.3	13.9	15.6	19.3	18.1	18.0	12.9	5.8		
	PrecMin	73.7	0.0	0.0	0.1	1.7	4.4	5.2	3.7	5.1	9.4	5.6	4.0	0.8		
	PrecStd	9.2	3.2	1.3	4.9	2.5	3.1	2.4	2.4	3.5	2.6	3.5	2.5	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.0	95.2	98.0	97.5	95.4	91.8	91.2	91.3	91.5	91.6	91.3	91.1		
		MCWB	76.4	74.3	76.3	78.2	80.4	80.1	78.2	77.9	78.8	78.0	78.0	77.4		
	2%	DB	90.7	93.6	96.1	95.6	92.6	90.7	89.9	89.7	89.7	89.7	89.9	89.8		
		MCWB	76.1	75.1	76.7	79.0	80.1	79.6	78.4	78.2	78.7	78.5	78.1	77.1		
	5%	DB	89.4	92.3	94.6	93.9	91.2	89.5	88.7	88.4	88.3	88.2	88.5	88.4		
		MCWB	75.8	75.3	76.7	79.3	80.1	79.2	78.5	78.3	78.5	78.5	78.2	76.9		
	10%	DB	87.9	90.9	92.8	91.9	89.7	88.2	87.2	87.0	86.8	86.8	86.9	86.8		
		MCWB	75.8	75.4	77.0	79.2	79.9	79.3	78.7	78.4	78.3	78.4	78.1	76.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	80.1	81.1	81.9	82.4	81.8	80.8	80.8	80.9	80.8	80.8	80.1		
		MCDB	86.9	88.3	90.7	90.8	90.7	88.5	86.4	86.7	87.6	87.1	87.5	87.1		
	2%	WB	78.4	78.6	80.2	81.1	81.5	81.0	80.0	80.0	80.0	79.8	79.7	79.0		
		MCDB	85.6	86.7	89.4	90.1	89.5	87.5	85.8	85.9	86.7	86.3	86.3	86.0		
	5%	WB	77.7	77.6	79.4	80.6	80.8	80.5	79.6	79.3	79.3	79.1	79.0	78.2		
		MCDB	84.9	86.2	88.5	89.6	88.6	86.9	85.4	85.2	85.7	85.6	85.5	84.8		
	10%	WB	77.0	76.9	78.6	80.0	80.2	79.9	79.1	78.9	78.7	78.6	78.4	77.4		
		MCDB	84.3	85.8	87.6	88.5	87.4	85.8	85.0	84.8	84.9	84.9	84.5	83.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.8	18.9	19.1	16.4	13.5	11.9	11.5	11.7	11.8	12.4	12.4	12.8		
		MCDBR	17.1	20.4	21.8	18.9	16.0	14.1	14.0	14.2	14.4	14.8	15.0	15.4		
		MCWBR	4.7	5.3	5.9	5.2	5.1	4.7	4.6	4.7	4.6	5.1	4.8	4.7		
	5% WB	MCDBR	14.4	18.3	19.0	16.7	14.5	12.5	12.1	12.1	12.9	13.3	13.4	13.3		
		MCWBR	5.0	5.6	6.0	5.5	5.3	5.1	5.0	4.8	5.1	5.2	5.0	4.9		
(40) Clear-Sky Solar Irradiance	taub		0.462	0.477	0.489	0.475	0.451	0.455	0.456	0.449	0.437	0.442	0.450	0.457		
	taud		2.278	2.212	2.216	2.258	2.365	2.380	2.360	2.372	2.402	2.380	2.342	2.306		
	Ebn at Noon		271	270	267	267	268	264	264	270	277	276	272	269		
	Edh at Noon		43	47	47	45	39	38	39	40	39	39	40	41		
(44) All-Sky Solar Radiation	RadAvg		1586	1876	1901	1831	1575	1522	1498	1532	1500	1438	1383	1378		
	RadStd		123	118	177	110	106	100	85	84	67	120	101	127		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.32	+0.59	N/A	N/A	+0.34	+0.38	N/A	N/A	N/A	N/A

Nomenclature: See separate page