

YALA AGROMET, Thailand

WMO: 485810

Lat: 6.5154N

Lon: 101.2740E

Elev: 118

StdP: 14.63

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	69.7	71.3	65.4	94.4	81.6	66.9	99.4	80.9	15.6	85.6	12.2	84.5	0.7	N/A	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.0	96.6	78.3	95.0	78.3	93.6	78.4	81.0	90.4	80.5	90.0	80.0	89.3	4.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	149.6	85.2	78.1	146.6	84.6	77.5	143.7	84.0	44.8	90.9	44.2	90.5	43.7	89.6	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	10.9	9.4	66.4	98.2	2.4	2.6	64.7	100.1	63.3	101.7	62.0	103.1	60.3	105.0		
(5)			65.7	83.0	2.6	1.1	63.8	83.8	62.3	84.4	60.8	85.0	59.0	85.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	79.4	80.9	82.6	84.6	84.6	84.1	83.2	83.2	82.6	82.0	80.6	79.4	(6)
(7)		DBStd	2.59	2.04	2.04	2.13	2.14	1.89	1.62	1.67	1.55	1.46	1.63	2.16	2.09	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11778	911	866	1011	1039	1073	1022	1029	1029	978	992	917	911	(10)
(11)		CDD65	6303	446	446	546	589	608	572	564	564	528	527	467	446	(11)
(12)		CDH74	60034	3581	4168	5506	6431	6518	6070	5676	5434	4903	4632	3793	3322	(12)
(13)	CDH80	23822	1096	1664	2471	3027	2858	2609	2321	2290	1847	1645	1121	873	(13)	
(14)	Wind	WSAvg	2.4	2.3	2.9	2.6	2.6	2.4	2.4	2.6	2.3	2.0	1.8	2.0	(14)	
(15)	Precipitation	PrecAvg	79.4	3.2	1.6	2.9	3.2	5.3	4.6	4.8	5.9	9.4	15.9	16.6	(15)	
(16)		PrecMax	109.2	13.2	11.9	11.6	9.3	11.8	8.9	8.1	11.6	10.0	17.7	36.1	38.9	(16)
(17)		PrecMin	54.9	0.0	0.0	0.0	0.1	1.7	1.2	2.0	3.2	2.6	4.3	5.6	1.8	(17)
(18)		PrecStd	15.2	3.3	2.6	3.0	2.4	2.2	1.9	1.5	2.3	1.7	2.8	7.7	9.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.7	93.7	97.1	99.3	97.9	96.1	95.1	96.2	93.5	92.5	91.5	90.5	(19)
MCWB			77.5	76.0	77.6	78.4	78.7	78.4	77.6	77.6	78.7	78.7	78.7	78.3	(20)	
2%		DB	89.0	92.0	95.3	97.0	95.3	94.2	93.4	93.7	92.0	91.0	89.8	88.7	(21)	
		MCWB	76.8	76.1	77.1	78.6	79.4	78.7	78.2	78.1	78.7	78.8	78.7	77.8	(22)	
5%		DB	87.5	90.3	93.3	94.9	93.5	92.6	91.7	92.0	90.6	89.6	88.3	87.0	(23)	
		MCWB	76.3	76.0	77.0	78.7	79.5	78.9	78.3	78.2	78.6	78.5	78.4	77.4	(24)	
10%		DB	85.9	88.7	91.3	92.8	91.7	91.0	90.1	90.2	89.0	88.1	86.4	85.1	(25)	
		MCWB	76.0	75.7	76.9	78.8	79.4	78.9	78.2	78.2	78.3	78.5	78.3	77.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	79.2	80.1	81.4	81.8	81.8	80.9	80.8	80.7	80.4	80.1	(27)	
MCDWB			86.0	88.5	91.5	92.3	91.6	90.3	89.4	90.0	89.7	88.5	87.9	86.4	(28)	
2%		WB	78.5	78.2	79.2	80.5	80.9	80.7	79.9	79.8	79.9	79.9	79.7	79.1	(29)	
		MCDWB	85.6	87.3	89.9	91.8	90.8	90.0	89.1	89.3	88.9	87.7	86.9	85.5	(30)	
5%		WB	77.7	77.4	78.5	79.9	80.2	80.0	79.2	79.1	79.2	79.2	79.1	78.3	(31)	
		MCDWB	84.4	86.2	88.7	90.7	89.9	89.2	88.2	88.7	88.2	87.1	85.9	84.3	(32)	
10%		WB	76.9	76.8	77.9	79.2	79.7	79.3	78.6	78.5	78.6	78.7	78.5	77.6	(33)	
		MCDWB	83.2	85.2	87.4	89.7	89.1	88.2	87.4	87.8	87.3	86.4	84.7	82.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	13.1	17.1	17.9	18.0	16.2	15.9	15.5	16.3	14.9	13.9	11.6	10.7	(35)	
5% DB		MCDBR	15.8	19.4	21.7	20.5	18.2	17.8	17.4	18.2	16.7	15.9	15.0	14.4	(36)	
		MCWBR	5.2	5.6	6.1	5.3	5.0	5.2	5.2	5.5	5.4	5.2	5.1	4.9	(37)	
		MCDBR	13.5	16.4	18.2	18.3	16.6	16.4	15.9	16.8	15.7	14.5	13.4	11.9	(38)	
(39)		MCWBR	5.2	5.4	5.8	5.8	5.4	5.7	5.6	5.9	5.7	5.4	5.3	4.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.451	0.454	0.464	0.454	0.451	0.461	0.465	0.464	0.456	0.455	0.445	0.454	(40)	
taud		2.305	2.272	2.265	2.292	2.324	2.324	2.304	2.293	2.309	2.313	2.350	2.317	(41)		
Ebn at Noon		275	277	274	272	267	261	261	266	272	273	275	272	(42)		
Edh at Noon		42	45	45	43	41	40	41	43	43	42	40	41	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1444	1762	1826	1847	1652	1587	1562	1627	1586	1457	1269	1203	(44)	
(45)		RadStd	107	123	155	76	84	56	75	45	55	96	98	126	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.36	N/A	N/A	+0.54	+0.47	+0.36	N/A	N/A	+140	+142

Nomenclature: See separate page