

KUALA LUMPUR SUBANG, Malaysia

WMO: 486470

Lat: 3.1307N

Lon: 101.5530E

Elev: 90

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	73.3	74.1	66.5	97.8	88.2	68.1	103.4	86.5	14.0	85.1	12.3	85.7	2.8	320	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.4	95.0	79.4	93.6	79.2	93.1	79.1	82.6	90.5	81.8	89.5	81.1	88.7	7.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.6	87.3	79.4	153.2	85.8	79.1	151.3	85.4	46.6	90.8	45.7	89.9	44.9	89.4	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.1	11.6	10.1	71.0	96.7	1.6	1.3	69.8	97.6	68.9	98.4	68.0	99.1	66.8	100.0		
			69.0	84.5	1.9	1.9	67.6	85.8	66.5	86.9	65.5	88.0	64.1	89.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.6	82.7	83.7	84.3	84.5	84.8	84.3	83.5	83.6	83.3	83.1	82.7	82.5
	DBStd	1.93	1.83	1.71	1.89	1.79	1.75	1.89	1.88	1.84	1.72	1.75	1.57	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12254	1015	942	1063	1035	1078	1030	1039	1040	999	1027	980	1006
	CDD65	6779	550	522	598	585	613	580	574	575	549	562	530	541
	CDH74	72282	5449	5494	6451	6352	7122	6746	6480	6402	5865	5708	5002	5211
	CDH80	28837	2056	2248	2708	2628	3080	2920	2659	2585	2292	2148	1715	1798
(14) Wind	WSAvg	3.7	3.4	3.5	3.7	3.7	3.8	3.9	4.0	4.1	3.9	3.9	3.4	3.4
(15) Precipitation	PrecAvg	100.2	7.5	6.6	9.5	11.0	8.0	5.0	5.7	6.3	8.1	10.7	12.3	10.0
	PrecMax	136.1	18.3	17.6	21.5	24.1	20.9	11.1	15.0	13.7	19.6	19.8	19.6	21.4
	PrecMin	70.9	1.8	0.3	3.5	1.7	0.0	0.0	1.1	0.9	2.3	2.3	3.6	3.6
	PrecStd	15.7	3.6	3.5	3.5	4.4	5.0	2.9	2.7	3.2	3.2	4.1	4.1	4.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	95.1	95.6	95.4	95.4	95.2	94.4	94.6	93.6	93.6	93.2	93.1
		MCWB	77.9	77.1	77.9	80.3	80.4	79.9	79.2	79.1	78.4	79.3	79.8	79.4
	2%	DB	92.0	93.4	93.6	93.6	93.8	93.4	92.9	92.9	92.4	91.8	91.4	91.4
		MCWB	77.7	77.8	78.8	80.2	80.2	79.4	78.8	78.8	78.4	78.7	78.9	78.5
	5%	DB	91.0	91.8	92.8	92.6	92.9	92.2	91.4	91.4	91.2	91.0	89.8	89.8
		MCWB	77.6	77.8	78.8	80.0	80.0	79.2	78.4	78.3	78.3	78.5	78.7	78.3
	10%	DB	89.4	90.5	91.2	91.1	91.3	91.1	89.9	89.8	89.6	89.4	88.1	88.1
		MCWB	77.4	77.7	78.7	79.7	79.5	79.0	78.1	78.0	77.9	78.3	78.6	78.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	81.9	82.7	83.4	83.5	82.8	82.2	82.1	81.5	81.7	81.9	81.6
		MCDB	89.1	89.7	91.1	91.9	91.7	91.0	90.7	90.0	89.7	89.9	89.3	88.8
	2%	WB	80.0	80.7	81.2	82.2	82.2	81.5	80.9	80.8	80.3	80.4	80.7	80.3
		MCDB	87.7	88.8	89.4	89.9	89.6	89.4	88.8	88.6	87.8	88.0	87.5	87.4
	5%	WB	79.2	79.8	80.3	81.2	81.2	80.6	79.9	79.8	79.6	79.7	79.8	79.6
		MCDB	86.4	87.4	88.2	88.6	88.6	88.4	87.5	87.3	86.8	87.0	86.3	86.3
	10%	WB	78.5	79.0	79.6	80.3	80.4	79.9	79.2	79.0	78.9	79.0	79.1	78.9
		MCDB	85.4	86.2	87.0	87.4	87.7	87.3	86.5	86.2	86.0	86.0	85.4	85.3
(35) Mean Daily Temperature Range	5% DB	MDBR	14.4	15.5	15.2	14.8	14.4	14.2	13.9	13.8	14.1	14.0	13.6	13.3
		MCDBR	16.3	16.9	16.7	16.1	15.8	15.5	15.2	15.3	15.5	15.6	15.0	15.1
		MCWBR	5.4	6.0	5.7	5.7	5.5	5.4	5.4	5.3	5.5	5.5	5.3	5.3
	5% WB	MCDBR	14.7	15.6	15.4	15.2	14.8	14.5	14.1	14.1	14.4	14.5	14.0	13.7
		MCWBR	5.5	6.2	5.8	6.0	5.8	5.6	5.7	5.6	5.6	5.6	5.5	5.5
(40) Clear-Sky Solar Irradiance	taub		0.470	0.511	0.518	0.508	0.490	0.522	0.513	0.535	0.546	0.568	0.480	0.457
	taud		2.273	2.135	2.135	2.167	2.227	2.130	2.157	2.086	2.057	1.983	2.257	2.328
	Ebn at Noon		272	263	260	258	256	243	247	247	249	245	267	274
	Edh at Noon		44	52	52	49	45	48	48	52	55	59	44	41
(44) All-Sky Solar Radiation	RadAvg		1477	1682	1692	1654	1592	1547	1519	1542	1506	1485	1431	1361
	RadStd		133	125	108	64	70	66	64	67	108	124	70	86

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.61	N/A	N/A	+1.12	+0.83	+0.70	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.63	+0.36	N/A	+0.79	+0.99	+0.94	N/A	N/A	+236	+236

Nomenclature: See separate page