

KUALA LUMPUR SUBANG, Malaysia

WMO: 486470

Lat: 3.1307N

Lon: 101.5530E

Elev: 27

StdP: 101.00

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 22.9	(c) 23.4	(d) 19.2	(e) 14.0	(f) 31.2	(g) 20.0	(h) 14.8	(i) 30.3	(j) 6.3	(k) 29.5	(l) 5.5	(m) 29.8	(n) 1.3	(o) 320	(p) 0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.0	35.0	26.3	34.2	26.2	34.0	26.2	28.1	32.5	27.6	32.0	27.3	31.5	3.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	30.7	26.3	21.9	29.9	26.1	21.6	29.6	90.4	32.6	88.3	32.1	86.7	31.9	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.9	(b) 5.2	(c) 4.5	(e) 21.7	(f) 35.9	(g) 0.9	(h) 0.7	(i) 21.0	(j) 36.4	(k) 20.5	(l) 36.9	(m) 20.0	(n) 37.3	(o) 19.3	(p) 37.8		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			20.6	29.2	1.0	1.0	19.8	29.9	19.2	30.5	18.6	31.1	17.8	31.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.7	28.2	28.7	29.0	29.2	29.3	29.1	28.6	28.6	28.5	28.4	28.2	28.0
	DBStd	1.07	1.01	0.95	1.05	0.99	0.97	1.05	1.04	1.02	0.95	0.97	0.87	0.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6808	564	523	591	575	599	572	577	578	555	571	544	559
	CDD18.3	3766	306	290	332	325	341	322	319	319	305	312	294	301
	CDH23.3	40157	3027	3052	3584	3529	3957	3748	3600	3557	3258	3171	2779	2895
	CDH26.7	16021	1142	1249	1504	1460	1711	1622	1477	1436	1273	1193	953	999
(14) Wind	WSAvg	1.7	1.5	1.6	1.6	1.6	1.7	1.7	1.8	1.8	1.7	1.7	1.5	1.5
(15) Precipitation	PrecAvg	2545	190	167	241	279	202	126	144	159	207	273	313	255
	PrecMax	3457	464	447	546	612	531	281	382	349	497	503	498	544
	PrecMin	1800	45	7	89	44	0	0	29	22	59	59	91	92
	PrecStd	399	92	90	88	113	128	73	68	82	82	104	103	109
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	35.1	35.4	35.2	35.2	35.1	34.7	34.8	34.2	34.2	34.0	33.9
		MCWB	25.5	25.1	25.5	26.9	26.9	26.6	26.2	26.2	25.8	26.3	26.6	26.3
	2%	DB	33.3	34.1	34.2	34.2	34.3	34.1	33.8	33.8	33.6	33.2	33.0	33.0
		MCWB	25.4	25.5	26.0	26.8	26.8	26.4	26.0	26.0	25.8	26.0	26.1	25.8
	5%	DB	32.8	33.2	33.8	33.6	33.9	33.4	33.0	33.0	32.9	32.8	32.1	32.1
		MCWB	25.3	25.4	26.0	26.7	26.7	26.2	25.8	25.7	25.7	25.8	26.0	25.7
	10%	DB	31.9	32.5	32.9	32.8	33.0	32.8	32.1	32.1	32.0	31.9	31.2	31.2
		MCWB	25.2	25.4	26.0	26.5	26.4	26.1	25.6	25.6	25.5	25.7	25.9	25.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.7	28.2	28.6	28.6	28.2	27.9	27.8	27.5	27.6	27.7	27.5
		MCDB	31.7	32.0	32.9	33.3	33.2	32.8	32.6	32.2	32.1	32.2	31.8	31.5
	2%	WB	26.7	27.0	27.3	27.9	27.9	27.5	27.1	27.1	26.9	26.9	27.0	26.8
		MCDB	30.9	31.5	31.9	32.1	32.0	31.9	31.6	31.4	31.0	31.1	30.8	30.8
	5%	WB	26.2	26.5	26.8	27.3	27.4	27.0	26.6	26.6	26.4	26.5	26.6	26.4
		MCDB	30.2	30.8	31.2	31.5	31.5	31.3	30.8	30.7	30.5	30.5	30.2	30.2
	10%	WB	25.8	26.1	26.5	26.9	26.9	26.6	26.2	26.1	26.1	26.1	26.2	26.1
		MCDB	29.6	30.1	30.6	30.8	31.0	30.7	30.3	30.1	30.0	30.0	29.6	29.6
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	8.6	8.5	8.2	8.0	7.9	7.7	7.7	7.8	7.8	7.5	7.4
		MCDBR	9.0	9.4	9.3	9.0	8.8	8.6	8.4	8.5	8.6	8.7	8.4	8.4
		MCWBR	3.0	3.3	3.1	3.2	3.1	3.0	3.0	3.0	3.1	3.0	3.0	3.0
	5% WB	MCDBR	8.2	8.7	8.5	8.4	8.2	8.1	7.8	7.8	8.0	8.1	7.8	7.6
		MCWBR	3.1	3.5	3.2	3.4	3.2	3.1	3.2	3.1	3.1	3.1	3.1	3.0
(40) Clear-Sky Solar Irradiance	taub		0.470	0.511	0.518	0.508	0.490	0.522	0.513	0.535	0.546	0.568	0.480	0.457
	taud		2.273	2.135	2.135	2.167	2.227	2.130	2.157	2.086	2.057	1.983	2.257	2.328
	Ebn at Noon		857	829	820	812	806	767	779	779	786	771	842	863
	Edh at Noon		139	163	163	154	141	152	150	165	173	187	140	130
(44) All-Sky Solar Radiation	RadAvg		4.66	5.30	5.33	5.21	5.02	4.88	4.79	4.86	4.75	4.68	4.51	4.29
	RadStd		0.42	0.39	0.34	0.20	0.22	0.21	0.20	0.21	0.34	0.39	0.22	0.27

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.34	N/A	N/A	+0.62	+0.46	+0.39	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.35	+0.20	N/A	+0.44	+0.55	+0.52	N/A	N/A	+131	+131

Nomenclature: See separate page