

KUALA LUMPUR INTL, Malaysia

WMO: 486500

Lat: 2.746N

Lon: 101.710E

Elev: 69

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 73.1	(c) 73.5	(d) 66.1	(e) 96.5	(f) 84.2	(g) 67.9	(h) 102.6	(i) 83.4	(j) 14.5	(k) 82.2	(l) 12.2	(m) 83.0	(n) 3.8	(o) 10	(p) 0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.1	93.5	78.2	92.8	78.4	91.6	78.7	82.4	89.0	81.7	88.4	81.0	87.8	7.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	159.6	87.7	79.2	152.1	86.0	79.1	151.2	85.8	46.3	88.7	45.4	89.2	44.8	88.5	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	11.3	9.8	71.2	95.9	0.7	1.9	70.7	97.3	70.3	98.4	69.8	99.4	69.3	100.8
			68.9	85.3	1.1	2.3	68.2	87.0	67.5	88.4	66.9	89.7	66.1	91.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	82.3	83.3	83.6	83.6	83.6	83.3	82.4	82.3	82.3	82.4	81.8	81.9
	DBStd	1.91	2.02	1.82	2.05	1.77	1.64	1.93	1.76	1.68	1.79	1.68	1.48	1.80
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11945	1000	932	1041	1009	1041	998	1003	1003	969	1004	955	990
	CDD65	6470	535	512	576	559	576	548	538	538	519	539	505	525
	CDH74	68059	5278	5463	6181	6109	6562	6268	5913	5820	5451	5424	4653	4937
	CDH80	25264	1869	2194	2479	2415	2594	2473	2163	2116	1967	1917	1473	1604
Wind	WSAvg	4.1	4.5	4.5	4.0	3.8	4.0	4.0	4.3	4.4	4.0	3.8	3.6	3.9
Precipitation	PrecAvg	88.1	5.9	4.5	6.2	6.7	6.7	5.7	6.9	7.2	8.2	10.0	11.2	8.5
	PrecMax	107.0	10.6	10.7	12.1	15.2	14.7	9.3	11.1	12.9	11.5	14.8	18.3	15.0
	PrecMin	69.4	1.1	0.0	3.0	0.9	2.8	1.9	3.4	4.4	4.5	6.9	6.0	4.6
	PrecStd	10.3	2.8	3.2	2.5	3.7	3.1	1.9	1.9	2.0	1.9	2.1	3.7	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.3	94.8	95.3	94.2	93.6	93.5	91.7	92.0	92.9	92.7	91.6	91.8
		MCWB	77.7	75.9	76.0	79.7	80.1	78.5	78.0	78.0	77.6	78.8	79.8	78.6
	2%	DB	91.5	93.1	93.3	92.8	91.8	91.7	90.0	91.0	91.1	91.1	89.8	90.1
		MCWB	77.4	77.1	77.7	79.8	80.2	79.1	78.4	78.3	78.1	78.9	79.5	78.6
	5%	DB	89.9	91.5	91.5	91.3	91.1	90.7	89.6	89.6	89.7	89.7	88.5	89.3
		MCWB	77.6	77.6	78.6	79.9	80.2	79.3	78.5	78.6	78.6	78.9	79.6	78.6
	10%	DB	88.1	89.8	89.9	89.7	89.6	89.5	88.1	88.1	88.1	88.1	87.5	87.7
		MCWB	77.8	77.9	78.8	79.9	79.8	79.5	78.9	78.7	78.9	79.1	79.6	78.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	82.6	82.3	82.8	83.4	82.3	81.4	82.1	82.1	81.9	82.5	81.4
		MCDB	88.4	89.5	89.5	89.8	89.9	89.2	87.8	87.4	87.1	87.9	88.7	88.1
	2%	WB	80.0	80.8	81.0	81.8	81.9	81.3	80.5	80.7	80.6	80.6	80.9	80.1
		MCDB	87.0	88.1	88.4	88.9	88.7	88.3	87.1	87.1	87.1	87.4	87.2	86.7
	5%	WB	79.3	79.8	80.1	81.0	81.1	80.6	79.9	79.9	79.9	79.9	80.1	79.6
		MCDB	86.1	87.2	87.4	87.9	87.9	87.5	86.3	86.3	86.3	86.5	86.2	86.0
	10%	WB	78.6	79.0	79.5	80.3	80.4	79.9	79.3	79.2	79.2	79.4	79.5	79.0
		MCDB	85.3	86.3	86.7	86.9	87.0	86.5	85.6	85.6	85.6	85.8	85.3	85.1
Mean Daily Temperature Range	5% DB	MDBR	13.6	15.2	14.4	13.7	13.1	12.7	12.4	12.6	13.0	13.2	12.7	12.6
		MCDBR	15.3	16.6	16.0	15.0	14.4	14.0	13.4	13.9	14.3	14.3	13.9	14.4
		MCWBR	6.1	6.8	6.3	6.1	5.8	5.7	5.7	5.8	6.0	5.8	6.0	6.1
	5% WB	MCDBR	14.0	15.2	14.4	13.8	13.3	12.8	12.4	12.7	12.9	13.3	13.0	13.2
		MCWBR	6.2	7.1	6.4	6.4	6.1	5.9	6.0	6.1	6.2	5.9	6.1	6.1
Clear-Sky Solar Irradiance	taub	0.472	0.515	0.523	0.507	0.487	0.522	0.509	0.537	0.550	0.575	0.481	0.457	
	taud	2.271	2.126	2.124	2.172	2.236	2.134	2.173	2.083	2.044	1.965	2.252	2.328	
	Ebn at Noon	272	262	259	258	256	243	248	247	248	243	267	274	
	Edh at Noon	44	52	52	49	44	48	47	52	56	60	45	41	
All-Sky Solar Radiation	RadAvg	1475	1702	1709	1667	1584	1534	1514	1545	1517	1505	1445	1365	
	RadStd	135	133	112	68	65	62	73	68	111	120	79	92	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.68	+0.38	N/A	+0.83	+0.74	+0.68	N/A	N/A	+247	+247

Nomenclature: See separate page