

PAHANG, Malaysia

WMO: 486570

Lat: 3.7727N

Lon: 103.2120E

Elev: 58

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.3	72.0	68.1	103.3	76.8	69.4	108.3	77.5	14.8	83.7	13.0	83.2	3.3	350	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	15.3	93.4	80.9	92.6	80.8	91.6	80.5	83.6	90.4	82.8	89.7	82.1	89.0	6.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.5	163.9	88.8	80.8	160.4	88.1	80.4	158.1	87.6	47.6	91.1	46.9	90.2	46.1	88.9	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.1	9.8	68.4	96.0	3.2	2.0	66.1	97.4	64.2	98.5	62.3	99.6	60.0	101.0		
(5)			67.3	84.6	3.2	1.8	65.0	85.9	63.1	86.9	61.4	88.0	59.1	89.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	79.2	80.2	81.9	83.3	83.8	83.2	82.8	82.6	82.4	82.0	80.8	79.5
	DBStd	2.30	1.97	1.72	1.84	1.65	1.58	1.65	1.61	1.53	1.47	1.67	2.04	2.19
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11610	904	845	988	999	1049	996	1016	1012	972	992	924	913
	CDD65	6135	439	425	523	549	584	546	551	547	522	527	474	448
	CDH74	57292	3224	3554	4985	5705	6239	5692	5574	5391	5008	4793	3850	3277
	CDH80	21265	833	1147	1859	2350	2647	2336	2215	2125	1957	1769	1181	846
Wind	WSAvg	3.8	4.6	4.8	4.2	3.4	3.4	3.6	3.9	3.9	3.6	3.1	3.1	4.0
Precipitation	PrecAvg	115.9	12.4	5.3	6.7	6.0	7.4	6.0	6.3	7.5	8.3	10.9	13.5	24.5
	PrecMax	168.0	36.8	18.7	25.9	14.3	15.4	15.0	15.9	14.4	16.3	23.3	48.2	57.9
	PrecMin	62.9	0.4	0.0	0.2	0.1	1.1	0.0	1.5	2.2	0.5	2.8	5.6	5.7
	PrecStd	23.1	8.8	4.9	6.2	3.5	3.5	2.9	3.0	3.2	3.3	4.3	8.4	13.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	91.1	92.8	94.4	95.1	93.6	93.4	93.4	93.2	93.0	91.5	90.0
		MCWB	79.9	78.4	80.1	80.9	80.1	80.9	80.8	80.6	80.4	80.7	80.6	80.1
	2%	DB	87.9	89.4	91.3	93.0	93.2	92.5	91.7	91.7	91.6	91.4	89.8	88.1
		MCWB	79.4	78.7	79.9	80.9	81.3	80.9	80.3	80.1	80.3	80.6	80.3	79.7
	5%	DB	86.2	87.9	89.8	91.5	91.7	91.3	90.8	90.6	90.4	89.9	88.1	86.4
		MCWB	78.2	78.4	79.4	80.5	81.2	80.7	80.0	79.9	80.0	80.2	79.9	78.9
	10%	DB	84.5	86.3	88.2	89.9	90.5	89.8	89.4	89.3	89.2	88.3	86.4	84.7
		MCWB	77.3	77.8	79.1	80.1	80.9	80.4	79.7	79.7	79.7	79.8	79.3	78.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.4	82.4	82.8	83.5	84.1	84.2	83.7	83.4	83.6	84.1	82.9	82.5
		MCDB	87.1	87.8	90.1	91.9	91.5	91.0	90.6	90.7	90.3	89.9	88.7	87.5
	2%	WB	80.6	80.5	81.5	82.5	83.1	82.7	82.4	82.1	82.2	82.3	81.6	80.8
		MCDB	86.0	86.4	88.8	90.4	90.5	89.6	89.2	89.1	89.0	88.9	87.4	85.9
	5%	WB	79.2	79.3	80.4	81.5	82.2	81.8	81.4	81.1	81.0	81.1	80.4	79.6
		MCDB	84.1	85.3	87.5	89.0	89.5	88.6	88.0	87.9	87.8	87.6	86.2	84.6
	10%	WB	78.2	78.4	79.6	80.6	81.4	81.0	80.4	80.1	80.1	80.1	79.4	78.7
		MCDB	82.8	84.3	86.1	87.6	88.3	87.6	86.8	86.6	86.6	86.3	84.9	83.5
Mean Daily Temperature Range	5% DB	MDBR	11.4	13.3	14.1	15.1	15.3	14.9	14.8	15.0	15.0	14.4	12.3	10.7
		MCDBR	14.0	15.5	16.0	16.7	16.6	16.2	16.0	16.3	16.4	16.2	14.9	13.6
		MCWBR	6.5	6.7	6.4	6.5	6.9	7.1	6.8	6.9	7.1	7.0	6.7	6.5
	5% WB	MCDBR	12.3	13.8	14.5	15.7	15.8	15.4	15.2	15.6	15.7	15.4	13.8	12.6
		MCWBR	6.8	7.0	6.8	7.1	7.5	7.6	7.5	7.6	7.8	7.8	7.0	6.9
Clear-Sky Solar Irradiance	taub	0.458	0.455	0.463	0.454	0.478	0.506	0.508	0.540	0.538	0.536	0.450	0.461	
	taud	2.318	2.306	2.295	2.317	2.260	2.176	2.171	2.068	2.075	2.075	2.353	2.326	
	Ebn at Noon	275	278	275	272	259	248	249	246	251	252	275	272	
	Edh at Noon	42	43	44	42	43	46	47	53	54	54	40	41	
All-Sky Solar Radiation	RadAvg	1350	1623	1704	1733	1638	1574	1564	1620	1614	1481	1307	1196	
	RadStd	130	138	134	65	75	65	83	54	95	96	85	120	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.56	N/A	N/A	+0.59	+1.66	+1.55	N/A	N/A	+214	+214
(47) Regional (3 neighbors)	+0.58	N/A	N/A	+0.86	+1.44	+1.42	N/A	N/A	+212	+214

Nomenclature: See separate page