

PAHANG, Malaysia

WMO: 486570

Lat: 3.7727N

Lon: 103.2120E

Elev: 18

StdP: 101.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.8	22.2	20.0	14.8	24.9	20.8	15.5	25.3	6.6	28.7	5.8	28.4	1.5	350	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.5	34.1	27.1	33.7	27.1	33.1	27.0	28.6	32.4	28.2	32.0	27.8	31.7	3.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.4	31.5	27.1	22.9	31.2	26.9	22.6	30.9	92.9	32.8	91.2	32.3	89.5	31.6	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	5.0	4.4	20.2	35.5	1.8	1.1	18.9	36.3	17.9	37.0	16.9	37.6	15.6	38.4		
(5)			19.6	29.2	1.8	1.0	18.3	29.9	17.3	30.5	16.3	31.1	15.0	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.2	26.8	27.7	28.5	28.8	28.4	28.2	28.1	28.0	27.8	27.1	26.4	(6)
(7)		DBStd	1.28	1.10	0.95	1.02	0.92	0.88	0.92	0.90	0.85	0.82	0.93	1.14	1.22	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6450	502	469	549	555	583	553	564	562	540	551	513	507	(10)
(11)		CDD18.3	3408	244	236	291	305	324	303	306	304	290	293	263	249	(11)
(12)		CDH23.3	31829	1791	1974	2769	3169	3466	3162	3097	2995	2782	2663	2139	1821	(12)
(13)		CDH26.7	11814	463	637	1033	1306	1471	1298	1231	1181	1087	983	656	470	(13)
(14)	Wind	WSAvg	1.7	2.1	2.1	1.9	1.5	1.5	1.6	1.7	1.8	1.6	1.4	1.4	1.8	(14)
(15)	Precipitation	PrecAvg	2943	315	134	171	152	189	153	161	190	212	276	344	622	(15)
(16)		PrecMax	4268	935	475	657	362	390	380	404	367	413	591	1224	1471	(16)
(17)		PrecMin	1597	9	1	4	2	28	0	37	57	13	71	141	146	(17)
(18)		PrecStd	586	223	124	157	90	89	74	75	81	83	108	213	329	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.8	33.8	34.7	35.0	34.2	34.1	34.1	34.0	33.9	33.1	32.2	(19)
(20)			MCWB	26.6	25.8	26.7	27.2	26.7	27.2	27.1	27.0	26.9	27.1	27.0	26.7	(20)
(21)		2%	DB	31.0	31.9	32.9	33.9	34.0	33.6	33.2	33.1	33.1	33.0	32.1	31.2	(21)
(22)			MCWB	26.3	26.0	26.6	27.2	27.4	27.2	26.8	26.7	26.8	27.0	26.8	26.5	(22)
(23)		5%	DB	30.1	31.0	32.1	33.0	33.2	32.9	32.7	32.5	32.4	32.2	31.2	30.2	(23)
(24)			MCWB	25.7	25.8	26.4	27.0	27.3	27.0	26.7	26.6	26.7	26.8	26.6	26.1	(24)
(25)		10%	DB	29.2	30.2	31.2	32.2	32.5	32.1	31.9	31.9	31.8	31.3	30.2	29.3	(25)
(26)			MCWB	25.2	25.4	26.2	26.7	27.2	26.9	26.5	26.5	26.5	26.6	26.3	25.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.0	28.2	28.6	28.9	29.0	28.7	28.6	28.7	28.9	28.3	28.1	(27)
(28)			MADB	30.6	31.0	32.3	33.3	33.1	32.8	32.5	32.6	32.4	32.2	31.5	30.8	(28)
(29)		2%	WB	27.0	27.0	27.5	28.0	28.4	28.2	28.0	27.8	27.9	28.0	27.5	27.1	(29)
(30)			MADB	30.0	30.2	31.6	32.4	32.5	32.0	31.8	31.7	31.7	31.6	30.8	30.0	(30)
(31)		5%	WB	26.2	26.3	26.9	27.5	27.9	27.7	27.4	27.3	27.2	27.3	26.9	26.5	(31)
(32)			MADB	29.0	29.6	30.8	31.6	31.9	31.4	31.1	31.0	31.0	30.9	30.1	29.2	(32)
(33)		10%	WB	25.7	25.8	26.4	27.0	27.4	27.2	26.9	26.7	26.7	26.7	26.4	25.9	(33)
(34)			MADB	28.2	29.1	30.1	30.9	31.3	30.9	30.4	30.3	30.3	30.2	29.4	28.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	7.4	7.8	8.4	8.5	8.3	8.2	8.3	8.4	8.0	6.8	5.9	(35)
(36)			MCDBR	7.8	8.6	8.9	9.3	9.2	9.0	8.9	9.1	9.1	9.0	8.3	7.6	(36)
(37)			MCWBR	3.6	3.7	3.6	3.6	3.8	3.9	3.8	3.9	3.9	3.9	3.7	3.6	(37)
(38)		5% WB	MCDBR	6.8	7.6	8.1	8.7	8.8	8.6	8.4	8.7	8.7	8.6	7.6	7.0	(38)
(39)			MCWBR	3.8	3.9	3.8	4.0	4.2	4.2	4.2	4.2	4.3	4.4	3.9	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.458	0.455	0.463	0.454	0.478	0.506	0.508	0.540	0.538	0.536	0.450	0.461	(40)	
(41)		taud	2.318	2.306	2.295	2.317	2.260	2.176	2.171	2.068	2.075	2.075	2.353	2.326	(41)	
(42)		Ebn at Noon	867	877	867	857	816	781	784	776	791	796	868	857	(42)	
(43)		Edh at Noon	133	137	139	133	136	146	148	168	170	170	127	130	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.26	5.12	5.37	5.46	5.16	4.96	4.93	5.11	5.09	4.67	4.12	3.77	(44)	
(45)		RadStd	0.41	0.43	0.42	0.21	0.23	0.21	0.26	0.17	0.30	0.30	0.27	0.38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.31	N/A	N/A	+0.33	+0.92	+0.86	N/A	N/A	+119	+119
(47) Regional (3 neighbors)		+0.32	N/A	N/A	+0.48	+0.80	+0.79	N/A	N/A	+118	+119

Nomenclature: See separate page