

DONG HOI, Viet Nam

WMO: 488480

Lat: 17.483N

Lon: 106.600E

Elev: 8

StdP: 101.23

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	13.9	9.3	7.3	14.6	10.7	8.0	15.2	8.0	17.7	7.1	17.4	3.2	320	0.287

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.9	36.7	26.7	35.6	26.5	34.7	26.5	28.0	32.8	27.6	32.3	27.2	31.9	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.8	22.5	30.4	26.5	22.0	30.0	26.1	21.5	29.6	90.0	33.0	88.1	32.5	86.5	32.1	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.3	6.2	5.3	DB	11.7	38.4	2.0	0.8	10.3	39.0	9.1	39.4	8.0	39.9	6.6	40.5	
			WB	10.0	29.1	2.0	0.6	8.5	29.6	7.4	30.0	6.3	30.3	4.8	30.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	19.3	20.2	22.3	25.8	28.7	30.7	30.3	29.6	27.7	25.8	23.4	20.4
	DBStd	4.68	2.82	3.26	3.05	2.98	2.66	2.04	1.95	1.76	1.84	1.61	2.43	2.63
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	58	23	18	6	0	0	0	0	0	0	0	1	11
	CDD10.0	5608	289	284	380	474	581	622	628	607	530	488	402	322
	CDD18.3	2625	54	69	127	224	323	372	370	348	280	230	153	74
	CDH23.3	26969	72	169	519	1893	3891	5137	4973	4455	3005	1861	813	181
(13)	CDH26.7	11506	5	31	91	588	1773	2790	2559	2098	1071	391	102	8
(14) Wind	WSAvg	2.1	2.2	2.0	1.8	1.8	1.9	2.3	2.3	2.0	1.8	2.2	2.5	2.7
(15) Precipitation	PrecAvg	2175	57	34	43	66	104	76	97	166	503	607	287	135
	PrecMax	2819	143	138	109	248	361	289	252	432	958	1334	646	273
	PrecMin	1527	15	6	7	4	0	12	21	43	169	65	68	43
	PrecStd	407	30	31	27	65	74	65	53	107	244	366	135	58
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	31.4	33.9	37.6	37.8	37.5	37.5	36.5	34.9	31.1	29.8	27.7
		MCWB	22.9	23.7	25.0	26.5	27.3	26.9	26.7	26.4	27.0	26.3	25.9	24.5
	2%	DB	24.9	26.1	28.7	34.6	36.0	36.3	35.9	35.0	33.3	30.2	28.7	26.3
		MCWB	22.4	23.3	24.9	26.6	26.8	26.4	26.4	26.4	26.9	25.9	25.3	23.7
	5%	DB	24.0	25.0	27.0	31.5	34.5	35.4	34.8	33.9	32.1	29.5	27.9	25.2
		MCWB	21.8	22.9	24.3	26.2	26.7	26.6	26.3	26.4	26.6	25.5	24.7	23.0
	10%	DB	23.2	24.1	25.7	29.5	33.0	34.3	33.7	32.8	31.0	28.8	27.0	24.2
		MCWB	21.4	22.5	23.7	25.8	26.6	26.5	26.1	26.3	26.4	25.2	24.4	22.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	24.3	25.8	27.6	28.6	28.5	28.2	28.3	28.2	27.2	26.4	25.0
		MCDB	25.4	27.5	29.5	33.8	33.6	33.2	33.0	32.3	32.4	29.9	28.9	26.8
	2%	WB	22.8	23.6	25.1	27.0	27.7	27.7	27.6	27.6	27.5	26.5	25.7	24.2
		MCDB	24.2	25.5	27.9	31.9	32.7	32.7	32.5	31.9	31.5	29.2	27.9	25.9
	5%	WB	22.2	23.2	24.5	26.4	27.2	27.4	27.1	27.2	27.0	26.1	25.3	23.4
		MCDB	23.6	24.7	26.7	30.4	32.0	32.6	32.0	31.4	30.8	28.6	27.2	24.9
	10%	WB	21.6	22.6	23.9	26.0	26.9	27.0	26.7	26.8	26.7	25.7	24.7	22.6
		MCDB	23.0	24.0	25.5	29.2	31.4	32.4	31.6	31.0	30.0	28.0	26.5	24.0
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.0	4.2	5.2	6.0	5.9	5.7	5.7	5.3	4.7	4.3	4.1
		MCDBR	5.1	5.2	6.2	9.2	8.0	7.0	7.0	6.8	6.6	5.8	5.5	5.5
		MCWBR	2.7	2.5	2.8	2.7	2.4	2.1	2.1	2.2	2.5	2.5	2.5	3.0
	5% WB	MCDBR	4.4	4.8	5.8	7.2	6.7	6.4	6.5	6.3	6.0	5.1	4.9	4.8
		MCWBR	2.6	2.3	2.7	2.6	2.7	2.5	2.5	2.6	2.6	2.5	2.6	2.9
(40) Clear-Sky Solar Irradiance	taub		0.564	0.602	0.708	0.652	0.525	0.475	0.457	0.477	0.546	0.615	0.576	0.606
	taud		1.879	1.827	1.645	1.800	2.152	2.306	2.353	2.284	2.065	1.844	1.903	1.786
	Ebn at Noon		721	720	661	704	789	821	838	828	772	700	706	668
	Edh at Noon		191	210	260	223	155	131	126	136	168	204	185	204
(44) All-Sky Solar Radiation	RadAvg		2.54	3.34	3.80	4.76	5.35	5.30	5.01	4.79	4.29	3.48	2.87	2.19
(45)	RadStd		0.44	0.57	0.40	0.45	0.44	0.40	0.62	0.35	0.49	0.54	0.48	0.48

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	+0.27	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.37	N/A	N/A	N/A	+0.54	+0.31	+0.22	N/A	N/A	+302	+298

Nomenclature: See separate page