

DA NANG INTL, Viet Nam

WMO: 488550

Lat: 16.0432N

Lon: 108.2070E

Elev: 33

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 62.2	(c) 63.8	(d) 55.1	(e) 64.8	(f) 65.1	(g) 56.9	(h) 69.2	(i) 66.1	(j) 18.8	(k) 70.0	(l) 16.0	(m) 70.8	(n) 3.3	(o) 320	(p) 0.286

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 15.2	(c) 98.0	(d) 79.5	(e) 96.2	(f) 79.4	(g) 94.6	(h) 79.4	(i) 82.6	(j) 91.3	(k) 81.8	(l) 90.2	(m) 81.1	(n) 89.4	(o) 7.1	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.5	158.6	87.1	79.6	153.8	86.2	79.0	150.8	85.6	46.5	91.4	45.7	90.5	45.0	89.8	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 16.6	(b) 14.0	(c) 12.0	(e) 57.6	(f) 101.3	(g) 4.7	(h) 1.8	(i) 54.3	(j) 102.6	(k) 51.5	(l) 103.7	(m) 48.9	(n) 104.7	(o) 45.5	(p) 106.0		
			DB	WB	56.1	84.1	2.5	1.7	54.4	85.3	52.9	86.4	51.5	87.3	49.7	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	71.7	73.4	76.8	81.0	84.5	86.6	85.9	85.3	82.5	79.6	76.8	72.7
	DBStd	6.08	3.50	4.04	3.98	3.22	3.05	2.85	2.78	2.76	2.56	2.42	3.19	4.01
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	5	1	1	0	0	0	0	0	0	0	0	0	3
	CDD50	10865	673	656	832	930	1069	1098	1112	1094	974	918	804	705
	CDD65	5395	209	237	367	480	604	648	647	629	524	453	354	243
	CDH74	52900	591	1032	2399	4511	7069	8406	8162	7755	5654	4042	2352	927
	CDH80	20896	34	134	500	1432	3092	4305	4023	3710	2161	1038	388	79
Wind	WSAvg	4.4	4.1	4.6	4.6	4.6	4.5	4.1	4.0	4.0	4.2	4.4	5.1	4.4
Precipitation	PrecAvg	109.3	4.0	1.5	1.5	2.6	5.3	4.4	4.3	7.4	15.7	30.2	22.3	12.5
	PrecMax	189.8	13.5	4.8	5.0	10.6	12.1	9.6	10.0	19.1	53.9	51.1	61.5	44.8
	PrecMin	77.0	0.9	0.1	0.2	0.3	2.1	1.5	1.3	2.5	4.1	13.7	7.2	3.5
	PrecStd	26.6	3.3	1.1	1.5	2.7	2.3	2.3	2.4	4.7	10.9	10.4	12.5	8.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.8	86.2	89.5	96.0	100.0	100.3	99.0	98.4	95.2	89.9	87.6	84.4
		MCWB	75.1	76.7	78.6	80.1	79.5	80.3	79.3	79.7	80.2	78.9	78.2	76.5
	2%	DB	80.6	83.4	86.3	90.9	96.3	97.6	96.8	96.1	92.9	88.0	85.8	82.3
		MCWB	73.5	75.1	77.3	79.4	79.7	79.5	79.1	79.5	79.6	78.2	77.2	74.8
	5%	DB	78.9	81.4	84.5	88.4	93.3	95.4	95.0	94.2	91.0	86.4	84.1	80.4
		MCWB	72.2	73.9	76.5	78.4	79.6	79.5	79.1	79.4	79.4	77.5	76.3	73.7
	10%	DB	77.2	79.2	82.7	86.9	91.1	93.6	93.0	92.1	89.1	85.2	82.3	78.7
		MCWB	71.5	72.9	75.5	78.0	79.4	79.4	79.1	79.2	79.1	77.1	75.6	73.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	78.0	79.5	81.9	82.9	84.0	83.4	82.8	82.1	80.7	79.6	77.8
		MCDB	81.1	83.9	86.5	91.1	92.2	93.5	92.1	91.7	90.2	86.8	84.6	82.3
	2%	WB	74.9	76.3	78.2	80.2	81.7	82.5	81.9	81.8	81.1	79.6	78.4	76.3
		MCDB	78.7	81.1	84.2	88.0	90.4	91.4	90.1	90.4	88.7	85.2	82.9	80.1
	5%	WB	73.9	75.2	77.4	79.3	80.9	81.6	81.1	81.0	80.4	78.9	77.7	75.1
		MCDB	77.3	79.3	82.5	85.8	89.0	90.3	89.4	89.5	87.6	84.1	82.0	78.8
	10%	WB	72.8	74.3	76.5	78.7	80.2	80.8	80.4	80.4	79.7	78.2	76.8	74.1
		MCDB	76.1	78.1	81.0	84.4	87.7	89.3	88.8	88.7	86.5	83.0	80.8	77.6
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.2	10.8	12.3	14.1	15.2	15.0	14.4	12.5	10.4	9.1	8.3
		MCDBR	11.4	12.4	12.7	14.5	17.6	17.3	17.3	16.7	15.8	12.9	11.7	10.9
	5% WB	MCWBR	5.6	5.8	5.6	6.0	6.4	6.4	6.7	6.6	6.3	5.6	5.4	5.3
		MCWBR	9.8	11.1	12.0	13.5	15.2	15.7	15.7	15.4	14.0	11.1	10.3	9.3
Clear-Sky Solar Irradiance	taub	0.494	0.521	0.629	0.576	0.491	0.456	0.440	0.449	0.496	0.546	0.520	0.536	
	taud	2.108	2.060	1.814	1.993	2.257	2.369	2.407	2.369	2.233	2.042	2.083	1.981	
	Ebn at Noon	252	252	229	241	259	265	270	271	259	241	242	234	
	Edh at Noon	49	53	70	58	44	39	38	40	45	53	49	54	
All-Sky Solar Radiation	RadAvg	1013	1349	1495	1744	1860	1807	1710	1661	1502	1244	1043	830	
	RadStd	144	231	137	139	121	114	161	129	172	161	181	186	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.72	N/A	N/A	+1.21	N/A	N/A	N/A	+360	+355
(47) Regional (2 neighbors)		+0.76	N/A	N/A	+1.42	N/A	N/A	N/A	+410	+407

Nomenclature: See separate page