

BUON MA THUOT, Viet Nam

WMO: 488750

Lat: 12.668N

Lon: 108.116E

Elev: 537

StdP: 95.04

Time Zone: 7.00 (E07)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	16.4	17.4	12.2	9.5	21.0	13.4	10.2	21.6	9.6	22.3	8.6	21.8	3.3	90	0.272

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.6	33.7	23.2	32.6	23.1	31.6	23.3	25.2	29.7	24.9	29.4	24.7	28.9	2.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.0	20.2	27.5	23.7	19.8	27.1	23.4	19.5	26.8	80.6	30.1	79.3	29.6	78.2	29.2	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.9	6.9	6.0	DB	13.5	35.4	1.9	1.0	12.1	36.1	11.0	36.7	10.0	37.3	8.6	38.1	
			WB	12.9	26.9	1.5	1.9	11.8	28.2	10.9	29.3	10.0	30.3	8.9	31.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	22.3	23.6	25.6	27.1	26.6	25.8	25.3	25.2	24.8	24.4	23.5	22.1
	DBStd	2.14	1.81	2.06	1.99	1.53	1.45	1.22	1.12	1.13	1.12	1.15	1.53	1.82
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	1	0	0	0	0	0	0	0	0	0	0	1
	CDD10.0	5361	381	382	484	513	514	473	473	470	444	447	404	376
	CDD18.3	2321	123	148	226	263	256	223	215	212	194	188	154	119
	CDH23.3	15813	507	986	1917	2506	2198	1667	1403	1342	1134	1044	729	379
(13)	CDH26.7	4454	76	295	751	1057	757	432	298	286	211	161	98	33
(14) Wind	WSAvg	2.7	3.9	3.7	3.1	2.4	2.0	2.0	2.1	2.0	1.9	2.4	3.1	3.5
(15) Precipitation	PrecAvg	1902	7	10	37	90	244	240	240	328	324	212	121	46
	PrecMax	2509	58	73	128	234	446	537	460	720	593	472	432	177
	PrecMin	1393	0	0	0	17	134	105	91	189	162	31	12	4
	PrecStd	293	13	16	34	64	82	104	88	132	102	122	95	47
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	32.9	34.3	35.5	34.4	32.0	31.0	31.0	30.6	30.2	29.7	28.8
		MCWB	21.9	21.7	22.4	23.3	24.2	24.8	24.6	24.6	24.7	23.6	23.3	22.4
	2%	DB	28.7	31.3	33.0	34.0	32.7	30.8	30.1	30.1	29.6	29.2	28.7	27.6
		MCWB	21.5	21.5	22.3	23.2	24.3	24.7	24.4	24.4	24.3	23.5	23.0	21.8
	5%	DB	27.4	29.9	31.9	32.9	31.5	29.9	29.2	29.3	28.8	28.4	27.9	26.4
		MCWB	21.0	21.2	22.3	23.2	24.3	24.5	24.2	24.2	24.1	23.4	22.7	21.4
	10%	DB	26.2	28.5	30.7	31.6	30.4	29.0	28.4	28.4	27.9	27.5	26.9	25.4
		MCWB	20.5	20.9	22.2	23.2	24.2	24.2	23.9	23.9	23.9	23.1	22.4	21.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	23.5	24.2	25.1	25.6	25.7	25.2	25.5	25.2	24.7	24.1	23.2
		MCDB	28.6	30.0	30.6	30.9	30.6	30.1	29.2	29.3	29.1	28.2	28.1	27.0
	2%	WB	22.2	22.6	23.7	24.6	25.1	25.2	24.7	24.8	24.7	24.2	23.5	22.6
		MCDB	26.8	28.7	29.7	30.5	30.2	29.4	28.6	28.7	28.4	27.7	27.3	25.9
	5%	WB	21.7	22.0	23.3	24.2	24.7	24.7	24.5	24.5	24.4	23.9	23.1	22.2
		MCDB	25.8	27.8	29.2	30.0	29.6	28.7	28.2	28.2	27.8	27.2	26.7	25.0
	10%	WB	21.1	21.5	22.8	23.9	24.5	24.4	24.1	24.1	24.0	23.5	22.7	21.7
		MCDB	24.8	26.9	28.6	29.6	29.1	28.2	27.6	27.6	27.3	26.6	25.9	24.4
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	9.3	10.0	9.6	7.8	6.6	6.2	6.3	5.9	6.0	5.6	5.5
		MCDBR	9.2	11.7	11.9	11.4	9.6	8.0	7.7	7.8	7.6	7.4	7.5	7.4
		MCWBR	3.0	3.1	2.7	2.5	2.6	2.9	2.9	3.0	3.1	2.7	2.7	2.7
	5% WB	MCDBR	7.8	10.7	10.5	9.6	8.2	7.2	6.9	7.0	6.8	6.4	6.2	5.8
		MCWBR	2.9	3.2	2.8	2.8	2.9	3.0	3.0	3.1	3.1	2.7	2.6	2.4
(40) Clear-Sky Solar Irradiance	taub		0.414	0.444	0.513	0.511	0.451	0.428	0.418	0.423	0.432	0.444	0.401	0.404
	taud		2.319	2.216	2.050	2.089	2.306	2.394	2.407	2.384	2.345	2.288	2.409	2.374
	Ebn at Noon		885	871	817	812	848	858	869	876	875	860	892	885
	Edh at Noon		127	145	175	168	132	120	119	123	128	134	115	117
(44) All-Sky Solar Radiation	RadAvg		4.55	5.52	5.66	5.83	5.38	4.89	4.69	4.59	4.56	4.41	4.01	3.81
(45)	RadStd		0.40	0.40	0.45	0.30	0.34	0.29	0.36	0.39	0.45	0.45	0.51	0.54

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.25	+0.47	N/A	N/A	+0.27	+0.28	N/A	N/A	N/A	N/A

Nomenclature: See separate page