

SONG TU TAY, Viet Nam

WMO: 488920

Lat: 11.428N

Lon: 114.331E

Elev: 16

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	75.8	76.7	68.6	105.2	78.8	70.0	110.6	79.3	20.9	80.7	20.1	79.8	8.4	20	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.3	92.5	82.6	91.2	82.0	90.2	81.6	83.5	90.2	82.8	89.0	82.3	88.4	5.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.7	165.3	88.0	81.0	161.2	87.1	80.6	159.1	86.7	47.5	90.8	46.8	89.6	46.2	88.7	88.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
20.5	18.1	16.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			73.9	95.9	2.4	2.8	72.2	97.9	70.8	99.6	69.5	101.2	67.8	103.2		
			68.7	84.7	3.4	1.4	66.3	85.7	64.3	86.5	62.3	87.3	59.8	88.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.8	81.8	82.1	84.0	86.0	86.7	84.7	83.7	83.9	83.5	83.6	83.6	82.2
	DBStd	2.60	1.97	1.87	1.90	2.21	2.60	2.33	2.02	2.06	2.15	2.29	2.44	2.28
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12340	985	898	1054	1079	1136	1042	1044	1051	1005	1041	1008	997
	CDD65	6865	520	478	589	629	671	592	579	586	555	576	558	532
	CDH74	79328	5138	4688	6490	7794	8820	7416	6914	6953	6520	6659	6378	5558
	CDH80	28535	1075	1041	2144	3510	4392	3142	2519	2563	2283	2314	2183	1369
Wind	WSAvg	7.5	10.0	8.7	7.0	4.7	5.0	7.3	8.4	8.7	7.9	5.7	7.5	9.7
Precipitation	PrecAvg	94.0	4.5	2.2	2.4	2.0	6.4	11.3	10.8	8.9	11.8	8.7	11.9	12.4
	PrecMax	163.1	24.2	13.2	17.6	14.6	20.7	25.5	25.7	27.5	22.8	19.4	42.2	45.0
	PrecMin	57.3	0.2	0.0	0.0	0.0	0.3	4.2	1.7	1.9	1.9	1.5	1.3	0.4
	PrecStd	24.4	5.2	3.1	4.1	3.0	5.3	5.6	5.8	5.3	5.7	4.5	8.5	11.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.7	89.0	91.3	93.6	94.5	92.5	90.2	90.0	90.2	90.8	90.9	89.4
		MCWB	80.1	79.7	81.2	82.3	84.0	82.7	81.3	82.0	82.1	82.1	82.2	81.2
	2%	DB	87.1	87.6	89.7	92.0	92.9	90.6	88.7	88.7	88.8	89.4	89.6	87.8
		MCWB	79.3	79.1	80.4	81.7	83.2	82.0	81.0	81.4	81.4	81.3	81.7	80.4
	5%	DB	85.8	86.4	88.5	90.7	91.6	89.1	87.5	87.6	87.6	88.1	88.2	86.4
		MCWB	78.8	78.7	79.9	81.3	82.6	81.5	80.8	81.0	80.8	80.8	81.2	79.9
	10%	DB	84.5	85.0	87.2	89.4	90.3	87.8	86.4	86.5	86.5	86.8	86.8	85.0
		MCWB	78.2	78.2	79.3	80.7	82.0	81.1	80.5	80.6	80.4	80.2	80.6	79.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	81.2	82.0	83.5	85.5	83.6	82.7	82.9	83.3	82.8	83.1	82.2
		MCDB	87.1	87.0	89.2	91.5	92.3	90.0	87.9	88.1	88.9	89.0	89.0	87.8
	2%	WB	80.2	80.1	81.0	82.5	83.9	82.6	81.8	81.9	82.1	81.9	82.2	81.0
		MCDB	85.5	85.5	88.1	90.1	91.0	88.4	86.8	86.7	87.2	87.9	88.2	86.2
	5%	WB	79.4	79.3	80.4	81.8	83.1	81.9	81.3	81.5	81.4	81.1	81.5	80.3
		MCDB	83.9	84.2	87.1	88.9	89.7	87.3	86.1	86.1	86.2	86.6	87.1	85.1
	10%	WB	78.9	78.8	79.7	81.1	82.5	81.5	80.9	81.0	80.8	80.5	80.8	79.7
		MCDB	82.9	83.3	85.8	87.8	88.7	86.8	85.4	85.3	85.2	85.7	85.9	84.0
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.0	8.1	8.4	7.3	5.6	5.5	5.3	5.7	6.6	6.5	5.6
		MCDBR	7.8	8.7	9.4	9.4	8.7	7.5	6.7	6.5	7.4	8.3	8.2	7.4
		MCWBR	3.7	3.9	3.9	3.4	3.2	2.7	2.8	2.6	3.2	3.6	3.8	3.6
	5% WB	MCDBR	6.9	7.8	9.0	9.3	8.4	6.3	6.2	5.9	6.8	7.7	8.0	7.0
		MCWBR	3.4	3.7	4.0	3.6	3.6	2.9	3.0	2.8	3.4	3.7	3.9	3.6
Clear-Sky Solar Irradiance	taub	0.472	0.438	0.449	0.437	0.427	0.440	0.461	0.467	0.452	0.452	0.474	0.512	
	taud	2.285	2.400	2.387	2.428	2.495	2.475	2.396	2.364	2.403	2.400	2.301	2.147	
	Ebn at Noon	265	279	277	278	275	269	264	266	272	272	262	249	
	Edh at Noon	42	39	40	38	35	35	38	40	39	38	41	47	
All-Sky Solar Radiation	RadAvg	1452	1815	1999	2136	1889	1559	1527	1652	1528	1596	1466	1262	
	RadStd	174	140	170	130	203	192	152	146	211	168	176	207	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page