

RACH GIA, Viet Nam

WMO: 489070

Lat: 10.000N

Lon: 105.083E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.0	22.9	17.1	12.2	23.5	18.4	13.2	24.9	6.7	27.0	5.5	27.2	1.7	20	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.4	33.3	26.3	32.6	26.3	32.1	26.3	28.0	31.2	27.7	30.8	27.5	30.5	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.8	30.1	26.7	22.3	29.9	26.5	22.1	29.7	89.5	31.4	88.3	31.0	87.2	30.7	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.2	7.3	DB	20.4	34.2	1.0	0.7	19.7	34.7	19.1	35.1	18.5	35.4	17.8	35.9
			WB	17.8	28.7	1.3	0.7	16.8	29.2	16.1	29.6	15.3	30.0	14.4	30.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	26.4	27.0	28.3	29.3	29.3	28.6	28.1	28.1	28.0	28.0	27.9	26.8
	DBStd	1.42	1.12	1.01	0.89	1.05	1.27	1.27	1.19	1.13	1.10	0.95	1.00	1.49
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6564	509	475	567	579	597	558	562	539	558	536	520	
	CDD18.3	3522	251	242	309	329	338	308	304	289	299	286	262	
	CDH23.3	40476	2236	2355	3621	4273	4411	3827	3618	3598	3357	3413	3217	2550
	CDH26.7	14232	503	698	1399	1938	1973	1506	1240	1206	1064	1069	998	639
Wind	WSAvg	3.2	2.1	2.2	2.6	2.6	3.3	4.3	4.8	4.9	4.3	2.4	2.1	2.2
Precipitation	PrecAvg	2156	12	9	23	80	225	298	358	310	289	307	189	57
	PrecMax	2898	46	42	101	404	368	489	711	522	494	554	398	153
	PrecMin	1576	0	0	0	0	81	155	139	141	113	102	59	4
	PrecStd	342	14	15	31	89	78	66	149	95	99	101	82	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.3	32.2	33.6	34.2	34.2	32.6	32.1	31.7	32.0	32.4	32.2	31.7
		MCWB	25.0	24.6	25.1	26.3	27.1	27.5	27.2	27.0	26.8	25.9	25.8	25.5
	2%	DB	30.5	31.3	32.7	33.4	33.1	31.8	31.1	30.9	31.1	31.5	31.4	30.7
		MCWB	24.8	24.6	25.1	26.3	27.2	27.3	27.0	26.9	26.6	25.9	25.7	25.2
	5%	DB	29.7	30.6	32.0	32.7	32.2	31.2	30.5	30.4	30.5	30.8	30.8	30.1
		MCWB	24.6	24.6	25.1	26.3	27.2	27.2	26.8	26.8	26.5	25.9	25.6	25.0
	10%	DB	29.1	29.9	31.3	32.0	31.6	30.6	30.0	29.9	29.9	30.2	30.2	29.5
		MCWB	24.3	24.5	25.1	26.3	27.2	27.0	26.7	26.6	26.4	25.9	25.5	24.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.1	27.2	28.2	28.4	28.2	27.7	27.7	27.6	27.2	26.8	26.2
		MCDB	29.4	29.7	31.1	31.3	31.7	31.0	30.5	30.4	30.6	29.9	30.0	29.5
	2%	WB	25.5	25.6	26.7	27.7	28.0	27.7	27.4	27.2	27.2	26.7	26.5	26.0
		MCDB	28.9	29.4	30.6	31.2	31.4	30.6	30.1	29.8	29.9	29.6	29.6	29.2
	5%	WB	25.1	25.2	26.3	27.3	27.7	27.5	27.1	27.1	26.9	26.6	26.2	25.6
		MCDB	28.5	29.2	30.1	30.9	31.0	30.4	29.7	29.6	29.5	29.4	29.3	28.8
	10%	WB	24.8	24.9	25.9	27.0	27.5	27.2	26.9	26.8	26.6	26.3	26.0	25.3
		MCDB	28.1	28.9	29.7	30.7	30.7	30.0	29.5	29.3	29.2	29.1	29.0	28.4
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.5	6.4	5.4	4.1	3.3	3.0	2.8	3.1	4.0	4.4	4.8
		MCDBR	6.1	7.1	7.3	6.5	5.2	3.9	3.5	3.4	4.1	5.2	5.3	5.5
		MCWBR	2.0	2.1	1.8	1.7	1.7	1.7	1.7	1.6	1.7	1.6	1.6	1.6
	5% WB	MCDBR	5.5	6.3	5.7	4.9	4.1	3.5	3.2	3.1	3.4	4.2	4.7	5.0
		MCWBR	2.1	2.3	2.1	2.0	1.9	1.9	1.8	1.7	1.7	1.7	1.6	1.7
Clear-Sky Solar Irradiance	taub	0.522	0.531	0.553	0.515	0.453	0.451	0.454	0.453	0.451	0.494	0.488	0.501	
	taud	2.053	2.023	2.008	2.144	2.369	2.401	2.382	2.378	2.377	2.245	2.233	2.149	
	Ebn at Noon	790	799	787	809	845	836	837	849	860	821	816	799	
	Edh at Noon	168	178	184	159	124	118	121	124	125	141	139	150	
All-Sky Solar Radiation	RadAvg	5.06	5.69	5.89	5.86	5.10	4.78	4.56	4.67	4.63	4.68	4.83	4.75	
	RadStd	0.27	0.23	0.27	0.29	0.43	0.28	0.35	0.33	0.36	0.37	0.29	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)		+0.23	+0.35	N/A	N/A	N/A	+0.19	N/A	N/A	N/A	N/A

Nomenclature: See separate page