

CA MAU, Viet Nam

WMO: 489140

Lat: 9.183N

Lon: 105.150E

Elev: 7

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.1	73.4	64.2	90.0	77.8	66.3	97.1	79.6	14.0	84.8	12.5	84.5	2.1	0	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.5	93.1	79.3	91.9	79.1	91.0	79.0	81.3	87.1	80.9	86.7	80.5	86.3	5.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	155.9	83.4	79.6	153.6	83.1	79.1	151.3	82.7	45.0	87.7	44.5	87.1	44.1	86.7	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.7	10.0	9.2	69.4	95.4	2.6	2.0	67.6	96.8	66.0	97.9	64.6	99.0	62.7	100.5
			65.1	83.8	2.8	2.0	63.0	85.3	61.4	86.5	59.8	87.6	57.7	89.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	80.3	81.3	83.6	85.4	85.0	83.5	82.7	82.7	82.4	82.3	82.3	80.7	
	DBStd	2.61	1.96	1.69	1.70	1.84	2.48	2.44	2.40	2.37	2.40	1.97	1.76	2.49	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11934	940	878	1041	1063	1086	1005	1014	1013	971	1002	968	953	
	CDD65	6459	475	458	576	613	621	555	549	548	521	537	518	488	
	CDH74	68982	4167	4339	6417	7556	7499	6244	5937	5864	5403	5498	5436	4622	
	CDH80	23466	1064	1315	2404	3376	3211	2265	1947	1903	1622	1567	1595	1197	
Wind	WSAvg	3.5	4.1	4.3	4.1	3.2	2.8	3.2	3.3	3.6	3.3	2.9	3.6	4.1	
Precipitation	PrecAvg	92.1	0.8	0.6	1.1	3.5	8.3	12.4	13.3	12.4	14.0	14.6	8.6	2.6	
	PrecMax	131.8	4.3	3.7	9.1	16.7	15.8	21.0	20.0	20.0	25.0	28.5	14.6	10.0	
	PrecMin	73.3	0.0	0.0	0.0	0.0	3.5	6.7	6.5	5.8	7.2	4.9	2.0	0.0	
	PrecStd	11.9	1.1	0.9	2.1	3.5	2.9	3.7	3.8	3.4	4.5	5.9	3.5	2.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	90.4	92.6	94.3	95.0	92.6	91.6	91.3	91.2	90.5	89.8	89.2	
		MCWB	76.7	76.7	77.5	79.3	79.8	79.8	79.4	79.4	79.2	78.8	78.4	77.6	
	2%	DB	87.7	88.7	91.0	93.0	93.3	91.2	90.2	90.2	89.9	89.2	88.7	88.0	
		MCWB	76.2	76.3	77.6	79.1	79.7	79.8	79.3	79.3	79.1	78.7	78.2	77.0	
	5%	DB	86.4	87.6	89.9	91.9	91.8	90.0	89.1	89.1	88.8	88.1	87.8	86.8	
		MCWB	75.7	76.0	77.4	78.8	79.8	79.6	79.2	79.2	79.0	78.6	78.1	76.8	
	10%	DB	85.2	86.5	88.8	90.9	90.3	88.6	87.8	87.7	87.3	86.9	86.7	85.6	
		MCWB	75.3	75.7	77.2	78.7	79.7	79.4	79.1	79.1	78.8	78.6	77.9	76.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.6	78.7	80.1	81.7	82.1	81.8	81.0	81.0	80.7	80.6	80.1	79.6
			MCDB	86.2	87.1	86.9	88.7	88.0	86.8	86.1	86.7	86.4	86.1	85.9	86.1
2%		WB	77.6	77.7	79.2	80.7	81.4	81.0	80.6	80.2	80.0	80.0	79.5	78.8	
		MCDB	84.3	85.4	86.2	87.7	87.3	86.3	85.8	85.7	85.4	85.1	85.0	84.5	
5%		WB	77.0	77.2	78.7	80.1	80.9	80.6	80.1	80.0	79.7	79.6	79.1	78.2	
		MCDB	83.3	84.3	85.8	87.0	86.8	86.0	85.1	85.3	84.9	84.4	84.3	83.6	
10%		WB	76.4	76.5	78.1	79.8	80.6	80.1	79.8	79.6	79.2	79.1	78.8	77.6	
		MCDB	82.4	83.3	85.2	86.6	86.5	85.3	84.7	84.7	84.1	83.8	83.7	82.8	
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.9	11.2	11.5	10.7	9.8	9.5	9.5	9.1	9.0	8.9	9.1	
		MCDBR	11.3	11.9	12.3	12.5	12.3	11.3	11.0	10.9	10.9	10.6	10.2	10.4	
		MCWBR	3.4	3.0	2.7	2.6	2.9	3.0	3.1	2.9	2.9	3.0	2.7	2.9	
	5% WB	MCDBR	10.1	11.0	11.3	11.5	11.0	10.3	9.9	9.9	9.7	9.5	9.4	9.5	
		MCWBR	3.5	3.1	2.8	3.0	3.4	3.6	3.8	3.4	3.3	3.3	3.0	3.1	
Clear-Sky Solar Irradiance	taub	0.499	0.499	0.512	0.475	0.440	0.445	0.448	0.448	0.444	0.475	0.482	0.500		
	taud	2.162	2.153	2.158	2.291	2.433	2.438	2.419	2.404	2.408	2.319	2.265	2.175		
	Ebn at Noon	258	263	261	267	271	266	267	271	275	266	262	255		
	Edh at Noon	48	50	50	43	37	36	37	38	38	42	43	47		
All-Sky Solar Radiation	RadAvg	1611	1854	1941	1932	1612	1478	1422	1479	1442	1457	1500	1474		
	RadStd	99	85	98	106	139	103	121	107	117	138	106	112		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.67	+1.15	N/A	N/A	+0.32	+0.40	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.59	+1.06	N/A	+0.58	+0.31	+0.29	N/A	N/A	N/A	N/A

Nomenclature: See separate page