

CON SON, Viet Nam

WMO: 489180

Lat: 8.683N

Lon: 106.600E

Elev: 30

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.3	73.9	65.6	94.5	77.3	66.7	98.4	77.4	18.8	79.7	17.7	78.8	1.8	320	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.7	90.1	80.4	89.3	80.1	88.6	79.8	81.3	88.0	80.9	87.4	80.5	86.9	5.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	152.4	85.0	79.0	150.7	84.8	78.6	148.5	84.5	45.0	88.6	44.5	88.0	44.1	87.3	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	14.2	12.6	68.7	93.9	3.5	3.7	66.2	96.6	64.2	98.7	62.2	100.8	59.7	103.4		
			65.9	82.5	2.8	1.0	63.8	83.2	62.1	83.8	60.5	84.3	58.5	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	78.8	79.4	81.1	83.3	84.0	83.2	82.6	82.6	82.3	81.8	81.5	79.9
	DBStd	2.45	1.73	1.75	1.90	1.85	2.07	2.11	1.91	1.95	1.90	1.70	1.59	2.04
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11575	892	822	963	999	1055	995	1011	1012	968	985	945	928
	CDD65	6100	427	402	498	549	590	545	546	547	518	520	495	463
	CDH74	65764	3271	3313	5041	6587	7393	6533	6387	6365	5834	5600	5230	4210
	CDH80	19407	254	417	1248	2520	3089	2426	2164	2126	1779	1575	1232	577
Wind	WSAvg	5.4	7.6	6.9	5.4	3.7	3.6	4.4	5.3	5.8	5.1	3.9	6.0	7.5
Precipitation	PrecAvg	79.3	0.4	0.2	0.7	1.8	7.9	10.9	11.8	11.4	12.9	12.8	5.6	2.4
	PrecMax	105.1	2.4	1.9	5.3	11.8	14.8	19.2	20.8	23.0	21.6	23.7	13.1	9.7
	PrecMin	57.2	0.0	0.0	0.0	0.0	0.9	5.0	5.1	3.9	3.9	2.6	0.6	0.0
	PrecStd	12.0	0.6	0.4	1.2	2.7	3.6	3.9	4.3	4.6	4.5	5.6	3.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	86.1	88.1	90.5	91.9	90.6	89.6	89.1	89.1	88.4	87.0	86.3
		MCWB	77.6	77.6	78.8	80.2	81.1	80.6	79.7	79.8	79.9	79.5	79.0	78.2
	2%	DB	83.6	84.8	87.0	89.4	90.6	89.3	88.2	88.1	88.1	87.4	86.1	84.8
		MCWB	76.4	76.9	78.4	79.9	80.7	80.2	79.5	79.5	79.5	79.2	78.8	77.5
	5%	DB	82.4	83.6	86.1	88.5	89.7	88.4	87.4	87.3	87.2	86.5	85.3	83.6
		MCWB	75.4	76.2	78.0	79.6	80.4	80.0	79.3	79.3	79.2	79.0	78.4	76.9
	10%	DB	81.4	82.5	85.0	87.7	88.6	87.5	86.5	86.4	86.2	85.6	84.4	82.7
		MCWB	74.9	75.7	77.5	79.3	80.2	79.8	79.1	79.1	79.0	78.7	78.0	76.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.4	78.5	80.0	81.2	82.2	81.8	80.9	80.9	80.9	80.7	80.2	79.4
		MCDB	83.7	84.5	86.1	88.1	89.5	88.0	87.2	87.6	87.3	86.2	85.2	84.5
	2%	WB	77.4	77.4	79.2	80.7	81.6	81.0	80.1	80.1	80.1	80.0	79.6	78.4
		MCDB	82.1	82.9	85.1	87.6	88.6	87.2	86.2	86.2	86.1	85.4	84.5	83.2
	5%	WB	76.7	76.9	78.7	80.1	81.0	80.5	79.8	79.8	79.7	79.6	79.1	77.9
		MCDB	81.0	82.2	84.5	86.8	87.7	86.8	85.8	85.7	85.5	84.7	83.8	82.5
	10%	WB	76.0	76.3	78.1	79.8	80.6	80.0	79.4	79.2	79.2	79.1	78.6	77.2
		MCDB	80.3	81.4	83.7	86.2	87.1	85.9	85.1	84.9	84.6	84.0	83.2	81.8
Mean Daily Temperature Range	5% DB	MDBR	5.1	6.1	7.4	8.6	8.7	7.8	7.3	7.0	7.0	7.2	5.6	4.6
		MCDBR	6.1	7.3	8.6	9.2	9.5	8.7	8.1	7.6	8.0	8.3	6.6	5.5
		MCWBR	2.8	3.1	3.4	3.3	3.2	3.3	3.3	3.2	3.4	3.3	2.9	2.7
	5% WB	MCDBR	5.6	7.0	8.1	8.7	9.0	8.1	7.7	7.5	7.7	7.8	6.4	5.0
		MCWBR	3.1	3.2	3.4	3.4	3.5	3.6	3.7	3.6	3.6	3.5	3.0	2.8
Clear-Sky Solar Irradiance	taub	0.469	0.461	0.474	0.447	0.427	0.437	0.442	0.447	0.440	0.463	0.475	0.493	
	taud	2.297	2.301	2.304	2.394	2.479	2.481	2.456	2.425	2.435	2.368	2.308	2.220	
	Ebn at Noon	268	274	271	275	275	269	268	271	277	270	264	258	
	Edh at Noon	42	43	43	39	35	35	36	37	37	40	41	45	
All-Sky Solar Radiation	RadAvg	1609	1920	2028	2162	1765	1611	1544	1617	1572	1530	1501	1406	
	RadStd	121	109	126	125	149	133	113	105	126	150	116	161	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.68	+1.31	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+0.68	+1.22	N/A	+0.54	+0.32	+0.31	N/A	N/A	N/A	N/A

Nomenclature: See separate page