

CON SON, Viet Nam

WMO: 489180

Lat: 8.683N

Lon: 106.600E

Elev: 9

StdP: 101.22

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	23.3	18.7	13.5	25.2	19.3	14.1	25.2	8.4	26.5	7.9	26.0	0.8	320	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.8	32.3	26.9	31.8	26.7	31.4	26.6	27.4	31.1	27.2	30.8	26.9	30.5	2.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	29.4	26.1	21.5	29.3	25.9	21.2	29.2	86.8	31.4	85.7	31.1	84.7	30.7	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
7.3	6.3	5.6	DB	20.4	34.4	1.9	2.0	19.0	35.9	17.9	37.1	16.8	38.2	15.4	39.7	
			WB	18.8	28.0	1.6	0.5	17.7	28.4	16.7	28.8	15.9	29.1	14.7	29.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.0	26.3	27.3	28.5	28.9	28.4	28.1	28.1	27.9	27.7	27.5	26.6
	DBStd	1.36	0.96	0.97	1.05	1.03	1.15	1.17	1.06	1.09	1.05	0.94	0.88	1.13
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6431	496	457	535	555	586	553	562	562	538	547	525	516
	CDD18.3	3389	237	223	277	305	328	303	303	304	288	289	275	257
	CDH23.3	36536	1817	1841	2801	3659	4107	3629	3548	3536	3241	3111	2906	2339
(14) Wind	WSAvg	2.4	3.4	3.1	2.4	1.7	1.6	2.0	2.3	2.6	2.3	1.7	2.7	3.3
	PrecAvg	2014	9	5	17	46	200	276	300	290	327	324	141	60
	PrecMax	2670	62	49	134	300	375	488	528	585	548	601	333	246
	PrecMin	1452	0	0	0	0	23	128	129	100	98	67	14	0
	PrecStd	305	15	11	30	68	92	98	108	118	115	143	78	61
	DB	29.6	30.1	31.2	32.5	33.3	32.6	32.0	31.7	31.7	31.3	30.6	30.2	
	MCWB	25.3	25.3	26.0	26.8	27.3	27.0	26.5	26.5	26.6	26.4	26.1	25.7	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	28.7	29.3	30.6	31.9	32.6	31.8	31.2	31.2	31.2	31.1	30.8	30.1	29.3
	MCWB	24.7	24.9	25.8	26.6	27.1	26.8	26.4	26.4	26.4	26.2	26.0	25.3	
	DB	28.0	28.7	30.0	31.4	32.0	31.3	30.8	30.7	30.7	30.3	29.6	28.7	
	MCWB	24.1	24.6	25.6	26.5	26.9	26.7	26.3	26.3	26.2	26.1	25.8	24.9	
	DB	27.4	28.1	29.4	30.9	31.5	30.8	30.3	30.2	30.1	29.8	29.1	28.2	
	MCWB	23.8	24.3	25.3	26.3	26.8	26.5	26.1	26.1	26.1	26.0	25.5	24.6	
	WB	25.8	25.8	26.7	27.4	27.9	27.6	27.2	27.2	27.2	27.1	26.8	26.3	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	28.7	29.2	30.1	31.2	31.9	31.1	30.6	30.9	30.7	30.1	29.6	29.2	
	WB	25.2	25.2	26.2	27.1	27.5	27.2	26.7	26.7	26.7	26.7	26.5	25.8	
	MCDB	27.8	28.3	29.5	30.9	31.4	30.7	30.1	30.1	30.1	29.6	29.2	28.4	
	WB	24.8	25.0	25.9	26.7	27.2	27.0	26.6	26.5	26.5	26.4	26.2	25.5	
	MCDB	27.2	27.9	29.1	30.4	30.9	30.4	29.9	29.8	29.7	29.3	28.8	28.1	
	WB	24.4	24.6	25.6	26.5	27.0	26.7	26.3	26.2	26.2	26.2	25.9	25.1	
	MCDB	26.8	27.4	28.7	30.1	30.6	30.0	29.5	29.4	29.2	28.9	28.4	27.7	
(35) Mean Daily Temperature Range	MDBR	2.9	3.4	4.1	4.8	4.8	4.3	4.1	3.9	3.9	4.0	3.1	2.6	
	5% DB	3.4	4.1	4.8	5.1	5.3	4.8	4.5	4.2	4.5	4.6	3.7	3.1	
	MCWBR	1.6	1.7	1.9	1.9	1.8	1.8	1.8	1.8	1.9	1.9	1.6	1.5	
	5% WB	3.1	3.9	4.5	4.8	5.0	4.5	4.3	4.1	4.3	4.3	3.6	2.8	
	MCWBR	1.7	1.8	1.9	1.9	2.0	2.0	2.1	2.0	2.0	2.0	1.7	1.6	
(40) Clear-Sky Solar Irradiance	taub	0.469	0.461	0.474	0.447	0.427	0.437	0.442	0.447	0.440	0.463	0.475	0.493	
	taud	2.297	2.301	2.304	2.394	2.479	2.481	2.456	2.425	2.435	2.368	2.308	2.220	
	Ebn at Noon	845	864	855	866	866	847	846	855	872	851	833	812	
	Edh at Noon	133	136	137	124	111	109	112	118	118	125	130	141	
(44) All-Sky Solar Radiation	RadAvg	5.07	6.05	6.39	6.82	5.56	5.08	4.87	5.10	4.96	4.82	4.73	4.43	
	RadStd	0.38	0.34	0.40	0.40	0.47	0.42	0.36	0.33	0.40	0.47	0.37	0.51	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.38	+0.73	N/A	+0.43	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.38	+0.68	N/A	+0.30	+0.18	N/A	N/A	N/A	N/A

Nomenclature: See separate page