

HUYEN TRAN ALEXANDRA BANK, Viet Nam

WMO: 489190

Lat: 8.017N

Lon: 110.617E

Elev: 62

StdP: 14.66

Time Zone: 7.00 (E07)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	75.8	76.6	67.6	101.5	78.3	68.6	105.3	78.6	N/A	N/A	N/A	N/A	N/A	N/A	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	3.5	88.1	79.7	87.2	79.5	86.5	79.3	81.1	85.7	80.8	85.4	80.2	85.0	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.3	84.5	79.2	151.8	84.2	78.9	150.1	84.0	44.9	86.0	44.4	85.8	44.0	85.4	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	72.9	92.4	1.9	4.8	71.6	95.9	70.4	98.7	69.4	101.4	68.0	105.0	
			WB	69.8	82.4	1.2	1.2	69.0	83.2	68.2	83.9	67.6	84.6	66.7	85.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	79.6	79.4	81.1	83.4	84.5	83.5	82.5	82.5	82.5	82.4	81.6	80.6
	DBStd	2.23	1.68	1.20	1.51	1.90	1.90	1.81	1.63	1.44	1.73	1.57	1.55	1.91
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11670	919	823	963	1002	1068	1004	1008	1008	974	1004	948	949
	CDD65	6195	454	403	498	552	603	554	543	543	524	539	498	484
	CDH74	70491	4248	3641	5244	6729	7796	6929	6481	6406	6169	6254	5600	4994
	CDH80	20332	428	194	955	2474	3353	2659	2110	2020	1948	1864	1431	896
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	81.5	3.8	2.0	2.1	1.7	5.3	8.1	9.8	7.2	9.1	8.2	10.7	12.5
	PrecMax	99.8	15.3	6.4	12.7	4.2	12.1	16.4	16.5	11.3	20.3	19.2	19.7	33.6
	PrecMin	58.6	0.1	0.0	0.0	0.0	0.8	2.1	3.0	3.9	2.5	2.3	3.7	2.4
	PrecStd	11.1	3.5	2.1	3.1	1.2	2.9	3.3	3.1	2.3	4.3	4.0	4.3	8.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.4	82.8	86.3	89.0	89.9	89.0	87.1	86.4	87.9	88.0	86.1	85.5
		MCWB	77.3	77.0	79.0	79.9	80.2	79.7	79.2	79.1	79.2	79.1	78.8	78.2
	2%	DB	83.5	81.9	84.6	87.3	88.1	87.2	86.0	85.3	86.3	86.2	85.0	84.5
		MCWB	77.2	76.7	78.1	79.2	79.9	79.7	78.9	78.9	78.7	78.5	78.5	78.0
	5%	DB	82.8	81.5	83.5	86.3	87.2	86.4	85.3	84.6	85.3	85.2	84.4	84.0
		MCWB	77.1	76.5	77.6	79.0	79.7	79.5	78.8	78.7	78.5	78.3	78.4	77.9
	10%	DB	82.3	81.0	82.8	85.5	86.6	86.0	84.6	84.4	84.6	84.5	84.0	83.3
		MCWB	77.1	76.3	77.2	78.7	79.6	79.5	78.6	78.7	78.3	78.1	78.2	77.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	79.9	80.6	81.6	81.9	81.9	80.6	81.0	80.1	80.0	80.1	80.0
		MCDB	81.8	81.2	83.6	85.5	87.6	85.9	84.8	84.5	85.2	85.0	83.6	83.1
	2%	WB	78.5	78.6	79.4	80.6	81.0	81.3	80.0	80.0	79.6	79.5	79.6	79.4
		MCDB	81.5	80.7	83.0	85.2	86.5	85.6	84.4	84.0	84.6	84.3	83.4	82.8
	5%	WB	78.1	77.9	78.7	80.0	80.7	80.7	79.7	79.7	79.2	79.1	79.1	78.9
		MCDB	81.2	80.6	82.5	84.8	86.1	85.2	84.3	83.8	84.1	83.9	83.2	82.6
	10%	WB	77.5	77.3	78.1	79.5	80.3	80.1	79.2	79.2	78.9	78.8	78.9	78.4
		MCDB	80.9	80.4	82.1	84.5	85.7	84.9	84.0	83.5	83.8	83.6	83.0	82.2
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.9	2.4	3.0	3.5	3.4	3.5	2.9	3.7	3.6	3.4	2.4
		MCDBR	2.3	2.3	3.3	4.2	4.2	3.8	3.7	3.1	4.3	4.5	3.9	2.6
		MCWBR	1.2	1.4	1.9	2.1	2.0	2.1	2.1	1.7	2.0	2.0	1.8	1.5
	5% WB	MCDBR	2.4	2.1	2.9	3.6	3.7	3.3	3.5	2.7	4.0	3.9	3.5	2.7
		MCWBR	1.5	1.5	1.8	2.2	2.2	2.3	2.5	2.1	2.2	2.1	1.9	1.7
Clear-Sky Solar Irradiance	taub	0.475	0.443	0.439	0.422	0.414	0.428	0.440	0.455	0.441	0.445	0.460	0.518	
	taud	2.295	2.396	2.434	2.487	2.531	2.506	2.457	2.396	2.427	2.427	2.368	2.143	
	Ebn at Noon	267	280	281	282	278	271	269	269	276	276	269	251	
	Edh at Noon	43	39	38	36	33	34	36	39	38	37	39	49	
All-Sky Solar Radiation	RadAvg	1409	1806	1951	2054	1846	1594	1549	1640	1583	1573	1392	1158	
	RadStd	208	190	226	136	172	106	156	123	180	176	107	238	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page