

TRUONG SA, Viet Nam

WMO: 489200

Lat: 8.650N

Lon: 111.917E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.8	74.9	67.6	101.5	74.8	69.4	108.1	76.7	32.2	76.9	30.8	77.6	14.3	50	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.7	92.3	82.1	91.0	81.6	90.0	81.2	82.9	89.9	82.5	89.2	81.9	88.2	6.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	160.9	87.7	80.5	158.4	87.2	80.0	156.0	86.5	46.9	90.6	46.3	89.6	45.8	88.8	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.0	25.9	23.1	DB	69.3	95.0	5.6	3.2	65.2	97.3	62.0	99.2	58.8	101.0	54.7	103.4	
			WB	67.4	84.1	4.6	0.7	64.1	84.6	61.4	85.0	58.8	85.4	55.5	85.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	80.1	81.1	82.8	84.9	85.5	84.3	83.3	83.7	83.3	83.0	82.6	81.0
	DBStd	2.73	2.47	2.04	2.48	2.08	2.43	2.31	2.10	1.96	2.03	2.33	2.18	2.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12037	932	871	1016	1048	1101	1028	1033	1046	1000	1023	978	961
	CDD65	6562	467	451	551	598	636	578	568	581	550	558	528	496
	CDH74	75506	4286	4400	6103	7445	8262	7215	6767	7025	6546	6458	5954	5045
	CDH80	26040	682	895	1952	3216	3843	2955	2415	2639	2324	2191	1857	1071
Wind	WSAvg	11.7	17.1	15.0	11.7	8.1	7.4	9.6	11.2	11.2	11.3	8.9	12.3	16.7
Precipitation	PrecAvg	107.1	6.7	3.3	4.1	2.4	5.4	8.3	11.1	9.6	10.6	9.3	14.2	20.8
	PrecMax	159.2	20.4	15.4	27.8	8.3	10.4	15.1	27.5	20.6	18.8	18.8	27.4	51.3
	PrecMin	77.3	0.0	0.0	0.0	0.0	0.6	2.5	3.4	2.6	1.6	2.6	4.9	2.1
	PrecStd	21.3	4.8	4.1	6.6	2.0	3.2	3.4	5.4	4.6	4.7	3.6	5.2	12.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	88.9	90.8	93.1	94.7	92.8	91.2	90.4	90.4	90.4	89.6	88.1
		MCWB	80.0	79.9	81.0	82.4	83.5	81.9	81.3	81.6	81.7	81.5	81.6	81.1
	2%	DB	86.2	87.2	89.4	91.7	92.9	90.8	89.3	89.1	89.1	89.0	88.2	86.4
		MCWB	79.2	79.3	80.3	81.8	82.6	81.5	81.0	81.1	81.0	80.9	81.0	80.0
	5%	DB	84.7	85.8	88.2	90.5	91.3	89.4	88.1	88.2	88.1	88.0	87.1	85.3
		MCWB	78.4	78.8	79.8	81.2	81.8	81.2	80.6	80.8	80.7	80.5	80.6	79.5
	10%	DB	83.3	84.5	87.0	89.2	89.8	88.0	86.9	87.2	86.9	86.8	86.0	84.1
		MCWB	77.9	78.3	79.4	80.7	81.4	80.9	80.2	80.4	80.3	80.0	80.1	78.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	81.2	82.1	83.6	84.2	83.0	82.6	82.5	82.7	82.6	82.7	81.8
		MCDB	86.4	86.4	88.9	90.8	93.0	89.7	88.9	88.8	88.9	89.0	88.0	86.7
	2%	WB	79.9	80.4	81.3	82.6	83.1	82.4	81.8	81.8	81.7	81.6	81.7	80.8
		MCDB	84.6	85.3	87.7	89.8	90.9	88.8	87.6	87.6	87.8	87.7	86.8	85.2
	5%	WB	79.2	79.6	80.6	81.8	82.4	81.8	81.1	81.3	81.0	80.9	80.9	80.0
		MCDB	83.1	84.1	86.7	88.7	89.6	87.8	86.6	86.8	86.6	86.6	85.9	84.1
	10%	WB	78.6	79.0	79.9	81.2	81.8	81.2	80.6	80.8	80.6	80.3	80.4	79.5
		MCDB	82.2	83.0	85.5	87.7	88.4	86.9	85.8	86.0	85.9	85.7	85.1	83.2
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.9	7.2	8.1	7.7	6.8	6.3	6.2	6.3	6.7	6.3	4.9
		MCDBR	6.7	7.7	8.9	9.5	9.4	8.4	7.6	7.3	7.7	7.9	7.6	6.2
		MCWBR	3.4	3.7	4.1	3.9	3.6	3.6	3.5	3.4	3.7	3.8	3.9	3.3
	5% WB	MCDBR	5.9	7.0	7.9	8.8	8.5	7.6	7.0	6.8	7.0	7.4	7.0	5.8
		MCWBR	3.4	3.8	4.1	4.1	3.9	3.8	3.7	3.6	3.7	3.9	4.0	3.4
Clear-Sky Solar Irradiance	taub	0.470	0.441	0.440	0.427	0.416	0.430	0.444	0.459	0.444	0.442	0.457	0.515	
	taud	2.314	2.408	2.430	2.471	2.525	2.503	2.449	2.388	2.423	2.436	2.378	2.154	
	Ebn at Noon	268	280	280	280	278	271	268	268	275	276	270	251	
	Edh at Noon	42	39	38	36	34	34	36	39	38	37	39	48	
All-Sky Solar Radiation	RadAvg	1412	1800	1962	2072	1853	1590	1564	1667	1563	1598	1425	1166	
	RadStd	213	203	226	133	191	121	164	112	196	172	131	236	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page