

XIAO'ERGOU, China

WMO: 505480

Lat: 49.1980N

Lon: 123.7220E

Elev: 945

StdP: 14.20

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.9	-27.7	-38.2	0.6	-31.7	-33.9	0.8	-27.0	14.9	3.2	12.9	4.6	1.0	20	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	88.8	68.1	85.3	67.4	82.2	66.5	72.8	81.9	71.0	79.8	69.4	78.1	6.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.0	114.5	77.7	68.2	107.1	75.7	66.4	100.8	74.1	37.3	81.9	35.6	80.0	34.2	78.1	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	14.1	11.9	-36.5	95.1	5.5	3.6	-40.4	97.7	-43.6	99.8	-46.7	101.9	-50.7	104.5
			-36.6	76.1	5.5	2.4	-40.6	77.8	-43.8	79.2	-46.8	80.6	-50.8	82.3
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	34.2	-7.5	0.6	19.7	39.4	53.9	66.0	70.5	66.1	53.7	36.7	13.4	-4.9	(6)
(7)		DBStd	28.88	8.16	9.41	11.41	7.96	7.13	6.03	4.39	5.42	7.34	8.25	11.71	8.56	(7)
(8)		HDD50	7734	1783	1383	938	330	38	0	0	1	44	417	1098	1702	(8)
(9)		HDD65	11624	2248	1803	1403	767	352	58	7	51	344	876	1548	2167	(9)
(10)		CDD50	1948	0	0	0	13	159	480	637	499	155	5	0	0	(10)
(11)		CDD65	365	0	0	0	0	8	88	179	84	6	0	0	0	(11)
(12)		CDH74	3784	0	0	0	16	235	1160	1517	754	102	0	0	0	(12)
(13)		CDH80	1179	0	0	0	3	62	433	484	180	17	0	0	0	(13)
(14)	Wind	WSAvg	4.0	2.2	2.7	4.5	6.1	5.9	4.5	3.9	3.6	4.0	4.5	3.2	2.3	(14)
(15)	Precipitation	PrecAvg	19.3	0.1	0.1	0.2	0.9	1.4	3.1	6.1	4.4	2.3	0.6	0.2	0.2	(15)
(16)		PrecMax	31.1	0.2	0.6	0.6	2.6	4.1	5.7	14.3	9.0	5.0	2.1	0.9	0.5	(16)
(17)		PrecMin	11.5	0.0	0.0	0.0	0.0	0.1	0.7	1.3	1.4	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	4.0	0.1	0.1	0.2	0.7	1.0	1.5	2.8	1.9	1.4	0.6	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	34.4	54.6	76.0	86.6	94.5	92.9	89.1	82.2	68.4	47.6	23.6	(19)
(20)		MCWB	15.9	26.6	40.1	51.6	60.0	67.2	71.1	69.0	64.6	51.2	37.1	20.4	(20)	
(21)		2%	DB	13.9	27.2	48.5	68.0	80.4	89.2	88.9	84.6	76.4	61.4	40.6	18.0	(21)
(22)		MCWB	10.9	21.6	36.5	48.2	57.7	66.3	70.3	69.8	61.2	47.4	32.9	15.2	(22)	
(23)		5%	DB	10.4	22.2	43.2	62.3	75.4	84.9	85.3	81.6	72.8	56.6	34.4	13.5	(23)
(24)		MCWB	8.1	17.9	33.0	45.1	54.9	64.6	69.7	68.2	58.7	44.3	28.6	11.3	(24)	
(25)		10%	DB	6.8	18.3	38.4	56.5	70.8	80.9	82.0	78.5	68.9	51.6	29.9	9.2	(25)
(26)		MCWB	4.8	14.9	30.3	41.7	52.4	63.1	68.8	66.6	57.0	41.1	25.8	7.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	27.0	41.1	53.1	63.5	71.3	76.0	75.3	68.2	53.5	38.2	20.7	(27)
(28)		MDCB	20.1	34.4	53.9	74.2	81.8	86.0	85.6	83.9	74.1	66.2	46.2	23.2	(28)	
(29)		2%	WB	10.8	21.8	36.8	48.8	59.1	69.0	73.7	72.1	64.5	48.8	32.9	15.4	(29)
(30)		MDCB	13.5	26.9	47.1	64.5	76.7	83.6	83.0	80.2	71.7	59.2	40.1	18.0	(30)	
(31)		5%	WB	8.0	18.1	33.5	45.6	56.6	66.9	71.9	70.2	61.7	45.2	29.3	11.2	(31)
(32)		MDCB	10.3	22.0	42.1	60.6	70.2	79.2	80.5	77.8	69.7	54.0	33.9	13.6	(32)	
(33)		10%	WB	4.9	14.9	30.7	42.5	54.4	65.2	70.4	68.4	58.9	42.4	26.0	7.3	(33)
(34)		MDCB	6.7	18.3	37.9	55.1	67.2	76.9	78.8	76.0	66.0	50.6	29.7	9.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	25.8	29.0	26.7	25.0	25.8	22.8	19.6	20.8	25.1	23.3	21.9	22.6	(35)	
(36)		5% DB	MCDBR	27.2	31.0	28.8	36.0	35.2	32.1	27.1	26.5	31.4	31.2	25.7	23.9	(36)
(37)		MCWBR	24.4	26.0	18.4	19.8	16.2	12.2	11.5	12.9	16.4	18.2	18.6	21.3	(37)	
(38)		5% WB	MCDBR	26.9	30.4	27.5	33.6	29.4	25.4	21.2	21.0	24.4	27.1	24.8	23.3	(38)
(39)		MCWBR	24.2	25.5	17.5	18.7	14.5	10.4	10.9	11.6	14.0	16.7	18.2	20.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.272	0.296	0.354	0.446	0.517	0.508	0.479	0.433	0.377	0.353	0.302	0.280	(40)	
(41)		taud	2.253	2.204	2.114	1.967	1.847	1.981	2.119	2.226	2.319	2.270	2.286	2.205	(41)	
(42)		Ebn at Noon	247	268	267	252	239	243	248	255	259	242	232	222	(42)	
(43)		Edh at Noon	23	31	41	53	62	55	47	40	33	29	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	571	946	1400	1628	1763	1839	1705	1552	1284	901	567	439	(44)	
(45)		RadStd	17	31	72	116	141	203	171	147	103	57	36	27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page