

SUNWU, China

WMO: 505640

Lat: 49.4169N

Lon: 127.3314E

Elev: 771

StdP: 14.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-30.1	-25.8	-34.7	0.8	-29.6	-30.7	1.0	-25.3	16.3	0.0	13.8	2.4	1.6	220	0.594

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	87.2	68.7	84.1	68.5	81.2	67.2	73.5	80.7	71.6	79.4	70.0	77.6	9.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.1	118.1	77.2	69.3	110.7	75.8	67.5	103.9	74.0	37.7	80.4	36.1	79.3	34.6	77.7	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.3	16.5	14.2	-32.7	92.5	5.0	3.3	-36.3	94.9	-39.2	96.9	-42.0	98.7	-45.7	101.1		
			-32.9	76.3	5.0	2.0	-36.5	77.7	-39.4	78.9	-42.2	80.0	-45.8	81.4		

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	34.0	-6.8	0.9	18.2	38.9	53.5	65.1	70.3	66.1	53.7	36.8	13.6	-4.4	(6)
(7)		DBStd	28.68	8.22	9.05	11.41	8.38	7.45	6.34	4.55	5.51	7.42	8.60	12.14	8.54	(7)
(8)		HDD50	7755	1762	1374	986	347	46	0	0	0	45	415	1093	1687	(8)
(9)		HDD65	11671	2227	1794	1451	785	366	75	7	53	345	873	1543	2152	(9)
(10)		CDD50	1911	0	0	0	13	153	453	631	498	156	7	0	0	(10)
(11)		CDD65	352	0	0	0	0	9	78	173	86	6	0	0	0	(11)
(12)		CDH74	3282	0	0	0	8	205	938	1385	669	76	1	0	0	(12)
(13)		CDH80	894	0	0	0	1	46	328	388	121	10	0	0	0	(13)
(14)	Wind	WSAvg	5.8	4.0	4.6	6.2	7.8	7.7	6.2	5.7	5.5	5.9	6.0	5.4	4.2	(14)
(15)	Precipitation	PrecAvg	21.5	0.2	0.2	0.2	0.9	1.9	3.4	5.7	4.8	2.8	0.8	0.4	0.2	(15)
(16)		PrecMax	29.7	0.4	0.5	0.7	4.1	4.0	6.7	10.9	9.5	5.7	2.4	0.9	0.5	(16)
(17)		PrecMin	14.1	0.0	0.0	0.0	0.1	0.7	0.9	1.0	1.1	0.6	0.0	0.0	0.0	(17)
(18)		PrecStd	4.5	0.1	0.1	0.2	0.7	0.9	1.7	2.4	2.0	1.3	0.5	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	33.5	51.4	74.2	85.2	93.1	91.3	86.5	81.0	68.3	46.8	23.3	(19)
(20)			MCWB	15.4	28.0	38.5	51.5	59.1	66.9	70.3	71.6	64.3	52.7	38.3	20.4	(20)
(21)		2%	DB	13.3	27.3	45.1	65.9	80.1	87.9	87.3	83.2	75.9	60.7	40.2	16.7	(21)
(22)			MCWB	10.8	23.1	35.5	47.7	57.8	66.2	71.2	70.8	61.7	48.3	34.4	14.3	(22)
(23)		5%	DB	9.6	21.5	40.4	60.0	74.9	83.5	84.3	80.7	72.4	55.7	35.1	12.6	(23)
(24)			MCWB	7.7	18.2	32.4	45.1	55.2	65.2	70.1	69.1	59.5	45.6	30.7	10.7	(24)
(25)		10%	DB	6.2	16.8	35.9	55.0	69.9	79.4	81.3	77.9	68.4	51.1	30.8	9.1	(25)
(26)			MCWB	4.8	14.0	29.9	42.2	53.4	63.8	69.5	67.4	57.6	42.3	27.3	7.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.9	28.2	39.9	53.4	62.2	71.9	76.6	75.6	68.0	54.4	39.0	20.9	(27)
(28)			MCDWB	18.2	32.7	49.0	70.2	77.3	86.0	84.5	81.7	75.9	64.9	45.5	23.1	(28)
(29)		2%	WB	11.0	23.2	35.9	49.2	59.6	69.0	74.3	72.9	64.5	50.0	34.3	14.5	(29)
(30)			MCDWB	13.2	27.3	44.2	63.2	74.4	81.3	81.9	79.8	71.6	58.2	39.6	16.6	(30)
(31)		5%	WB	7.7	18.2	32.8	46.0	57.3	67.2	72.6	71.0	62.1	46.5	30.9	10.8	(31)
(32)			MCDWB	9.4	21.5	39.3	58.7	71.2	78.4	79.9	77.9	69.5	54.2	34.8	12.5	(32)
(33)		10%	WB	4.8	14.0	30.2	42.8	54.9	65.6	71.0	69.2	59.4	43.1	27.4	7.5	(33)
(34)			MCDWB	6.2	16.7	36.0	54.0	67.6	76.2	78.4	75.6	66.3	50.2	30.8	9.1	(34)
(35)	Mean Daily Temperature Range		MDBR	21.6	25.3	22.6	21.6	23.0	21.3	18.0	18.9	22.9	20.0	18.5	19.3	(35)
(36)		5% DB	MCDBR	23.4	28.0	23.9	31.1	32.5	29.6	23.8	23.1	28.4	27.8	20.9	21.3	(36)
(37)			MCWBR	21.2	23.9	15.7	17.0	14.7	11.7	9.9	11.3	14.6	16.7	15.5	19.1	(37)
(38)		5% WB	MCDBR	23.1	27.8	22.1	28.4	27.8	23.1	18.5	18.6	22.9	24.4	20.2	20.9	(38)
(39)			MCWBR	21.0	23.8	14.9	16.1	13.5	10.4	9.4	10.1	12.9	16.0	15.4	18.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.309	0.375	0.491	0.558	0.519	0.495	0.442	0.403	0.396	0.326	0.288	(40)	
(41)		taud	2.159	2.087	1.973	1.832	1.749	1.950	2.070	2.200	2.221	2.087	2.154	2.128	(41)	
(42)		Ebn at Noon	238	259	258	238	227	239	244	252	249	221	214	213	(42)	
(43)		Edh at Noon	25	35	47	61	69	56	49	42	36	35	25	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	562	949	1409	1564	1716	1811	1687	1518	1245	831	539	430	(44)	
(45)		RadStd	19	37	89	167	149	236	148	121	103	50	40	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page