

BUGT, China

WMO: 506320

Lat: 48.7594N

Lon: 121.9140E

Elev: 2425

StdP: 13.45

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.7	-18.4	-30.6	1.1	-20.3	-27.1	1.3	-17.5	23.9	-4.1	20.8	-4.0	6.3	290	0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	84.0	63.9	80.5	63.3	77.3	62.2	68.6	77.2	66.8	74.8	65.2	73.0	8.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	105.1	72.1	64.1	98.2	70.5	62.4	92.2	69.1	34.4	77.5	32.9	74.6	31.6	73.3	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	19.2	16.8	-24.4	89.6	3.7	3.7	-27.1	92.2	-29.2	94.4	-31.3	96.4	-34.1	99.1
			-24.7	72.0	3.7	2.4	-27.3	73.7	-29.5	75.1	-31.5	76.4	-34.2	78.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.4	-3.8	4.0	17.6	35.9	49.7	60.0	65.4	61.6	50.1	33.9	13.2	-0.4
	DBStd	25.64	7.74	9.33	10.40	8.54	7.17	6.17	4.37	5.34	6.99	8.86	10.92	8.18
	HDD50	7738	1669	1288	1003	429	94	4	0	2	83	501	1103	1562
	HDD65	12002	2134	1708	1468	873	477	171	47	131	450	963	1553	2027
	CDD50	1320	0	0	0	6	84	304	477	362	85	2	0	0
	CDD65	106	0	0	0	0	1	20	59	25	1	0	0	0
	CDH74	1521	0	0	0	8	107	448	616	304	38	0	0	0
	CDH80	352	0	0	0	1	24	120	145	57	5	0	0	0
Wind	WSAvg	6.5	6.9	6.8	7.6	8.2	7.9	5.5	4.9	4.9	5.9	6.7	6.3	6.4
Precipitation	PrecAvg	18.9	0.1	0.1	0.2	0.6	1.2	3.2	6.1	4.5	2.0	0.5	0.2	0.1
	PrecMax	25.0	0.2	0.4	0.7	1.5	3.9	6.8	12.2	11.8	4.8	2.2	0.5	0.6
	PrecMin	12.3	0.0	0.0	0.0	0.0	0.1	0.6	2.1	1.5	0.2	0.0	0.0	0.0
	PrecStd	3.1	0.1	0.1	0.2	0.4	0.9	1.6	2.5	2.3	1.2	0.5	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	33.9	51.7	71.8	83.3	88.9	88.8	86.0	79.8	66.2	46.2	25.1
		MCWB	15.4	26.5	37.4	48.6	56.0	63.3	66.7	65.5	60.6	48.2	35.2	21.3
	2%	DB	14.1	27.4	44.1	64.1	76.6	83.2	83.9	80.7	73.3	59.0	39.1	19.1
		MCWB	11.3	22.1	32.8	44.4	53.7	62.0	66.5	65.6	57.0	44.3	31.0	16.0
	5%	DB	10.3	22.7	38.4	57.9	71.3	78.9	80.3	77.1	69.0	53.3	33.5	14.5
		MCWB	8.1	18.3	29.5	41.3	51.0	60.6	65.5	63.4	55.1	40.9	28.0	12.3
	10%	DB	7.1	18.3	33.7	52.3	66.4	75.3	77.1	73.9	64.7	48.0	28.7	11.3
		MCWB	5.2	14.9	26.8	38.3	48.7	59.1	64.7	62.2	52.7	37.9	24.5	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	26.8	38.1	49.2	58.4	67.8	72.2	70.6	63.9	49.1	35.8	21.8
		MCDB	18.9	33.7	51.6	69.7	76.3	80.7	80.8	79.9	71.8	63.1	45.5	24.9
	2%	WB	11.5	22.0	33.3	45.2	55.0	65.2	69.4	67.7	60.3	45.0	31.4	16.1
		MCDB	14.1	27.0	43.1	62.2	71.8	77.3	78.0	74.8	69.6	57.2	38.2	18.9
	5%	WB	8.2	18.4	29.9	41.8	52.5	63.0	67.9	65.8	57.2	41.8	28.2	12.3
		MCDB	10.2	22.5	37.6	56.3	67.6	73.9	76.2	73.0	64.7	52.0	33.6	14.5
	10%	WB	5.2	15.0	27.1	38.9	50.2	61.2	66.3	64.0	54.4	39.0	24.6	9.4
		MCDB	7.0	18.3	33.5	51.3	63.8	71.3	73.6	71.1	62.7	46.9	28.6	11.2
Mean Daily Temperature Range	5% DB	MDBR	14.7	18.5	19.9	21.6	24.3	23.1	19.9	20.7	23.5	20.2	16.7	14.0
		MCDBR	18.1	23.2	24.8	32.7	35.0	31.9	27.4	27.8	31.4	29.4	21.5	17.3
		MCWBR	15.8	18.6	16.0	17.6	16.4	14.0	12.2	13.6	16.1	16.7	15.0	14.9
	5% WB	MCDBR	18.0	22.9	23.7	30.5	29.5	25.5	21.4	21.2	24.9	26.9	20.9	17.2
		MCWBR	15.8	18.4	15.6	17.0	15.0	12.5	11.4	11.9	14.3	16.0	14.9	14.8
Clear-Sky Solar Irradiance	taub	0.262	0.285	0.336	0.417	0.487	0.476	0.446	0.410	0.355	0.331	0.289	0.270	
	taud	2.259	2.199	2.116	2.017	1.897	2.041	2.191	2.271	2.370	2.324	2.309	2.210	
	Ebn at Noon	255	274	274	262	247	252	258	262	268	253	241	231	
	Edh at Noon	23	31	41	50	59	52	44	39	32	28	22	21	
All-Sky Solar Radiation	RadAvg	580	961	1412	1659	1799	1851	1733	1587	1296	911	575	441	
	RadStd	23	31	75	106	136	183	167	140	108	63	34	30	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	-3.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page