

BUGT, China

WMO: 506320

Lat: 48.7594N

Lon: 121.9140E

Elev: 739

StdP: 92.76

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.8	(c) -28.0	(d) -34.8	(e) 0.2	(f) -29.0	(g) -32.8	(h) 0.2	(i) -27.5	(j) 10.7	(k) -20.1	(l) 9.3	(m) -20.0	(n) 2.8	(o) 290	(p) 0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.0	(c) 28.9	(d) 17.7	(e) 26.9	(f) 17.4	(g) 25.2	(h) 16.8	(i) 20.3	(j) 25.1	(k) 19.3	(l) 23.8	(m) 18.4	(n) 22.8	(o) 3.8	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	15.0	22.3	17.9	14.0	21.4	16.9	13.2	20.6	62.2	25.3	58.7	23.6	55.5	23.0	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 8.6	(c) 7.5	(e) -31.3	(f) 32.0	(g) 2.1	(h) 2.0	(i) -32.8	(j) 33.5	(k) -34.0	(l) 34.7	(m) -35.2	(n) 35.8	(o) -36.7	(p) 37.3		
(a) 10.0	(b) 8.6	(c) 7.5	(e) -31.5	(f) 22.2	(g) 2.0	(h) 1.3	(i) -33.0	(j) 23.2	(k) -34.2	(l) 23.9	(m) -35.3	(n) 24.7	(o) -36.8	(p) 25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.2	-19.9	-15.6	-8.0	2.2	9.8	15.5	18.6	16.4	10.0	1.1	-10.4	-18.0	(6)
(7)		DBStd	14.25	4.30	5.18	5.78	4.75	3.98	3.43	2.43	2.97	3.88	4.92	6.07	4.54	(7)
(8)		HDD10.0	4299	927	716	557	238	52	2	0	1	46	278	613	868	(8)
(9)		HDD18.3	6668	1186	949	816	485	265	95	26	73	250	535	863	1126	(9)
(10)		CDD10.0	733	0	0	0	3	47	169	265	201	47	1	0	0	(10)
(11)		CDD18.3	59	0	0	0	0	1	11	33	14	1	0	0	0	(11)
(12)		CDH23.3	845	0	0	0	4	59	249	342	169	21	0	0	0	(12)
(13)		CDH26.7	196	0	0	0	1	13	67	81	32	3	0	0	0	(13)
(14)	Wind	WSAvg	2.9	3.1	3.1	3.4	3.7	3.6	2.4	2.2	2.2	2.6	3.0	2.8	2.9	(14)
(15)	Precipitation	PrecAvg	479	2	3	5	15	31	81	156	115	51	12	5	3	(15)
(16)		PrecMax	636	6	11	18	38	98	172	309	300	123	56	12	14	(16)
(17)		PrecMin	313	0	0	0	1	3	16	53	37	4	1	0	0	(17)
(18)		PrecStd	78	2	3	4	9	22	40	64	59	31	12	3	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.2	1.0	11.0	22.1	28.5	31.6	31.5	30.0	26.6	19.0	7.9	-3.9	(19)
(20)			MCWB	-9.2	-3.1	3.0	9.2	13.3	17.4	19.3	18.6	15.9	9.0	1.8	-6.0	(20)
(21)		2%	DB	-9.9	-2.5	6.7	17.8	24.8	28.5	28.8	27.0	23.0	15.0	3.9	-7.2	(21)
(22)			MCWB	-11.5	-5.5	0.4	6.9	12.0	16.7	19.2	18.6	13.9	6.8	-0.6	-8.9	(22)
(23)		5%	DB	-12.0	-5.2	3.5	14.4	21.8	26.1	26.9	25.1	20.6	11.8	0.8	-9.7	(23)
(24)			MCWB	-13.3	-7.6	-1.4	5.2	10.6	15.9	18.6	17.5	12.9	4.9	-2.2	-11.0	(24)
(25)		10%	DB	-13.8	-7.6	1.0	11.3	19.1	24.0	25.1	23.3	18.2	8.9	-1.8	-11.5	(25)
(26)			MCWB	-14.9	-9.5	-2.9	3.5	9.3	15.0	18.2	16.8	11.5	3.3	-4.1	-12.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.2	-2.9	3.4	9.6	14.6	19.9	22.4	21.5	17.7	9.5	2.1	-5.7	(27)
(28)			MCDWB	-7.3	1.0	10.9	21.0	24.6	27.0	27.1	26.6	22.1	17.3	7.5	-3.9	(28)
(29)		2%	WB	-11.4	-5.6	0.7	7.3	12.8	18.4	20.8	19.8	15.7	7.2	-0.3	-8.9	(29)
(30)			MCDWB	-9.9	-2.8	6.2	16.8	22.1	25.1	25.6	23.8	20.9	14.0	3.4	-7.3	(30)
(31)		5%	WB	-13.2	-7.5	-1.2	5.5	11.4	17.2	19.9	18.8	14.0	5.4	-2.1	-10.9	(31)
(32)			MCDWB	-12.1	-5.3	3.1	13.5	19.8	23.3	24.5	22.8	18.2	11.1	0.9	-9.7	(32)
(33)		10%	WB	-14.9	-9.4	-2.7	3.8	10.1	16.2	19.0	17.8	12.4	3.9	-4.1	-12.6	(33)
(34)			MCDWB	-13.9	-7.6	0.8	10.7	17.7	21.8	23.1	21.7	17.1	8.3	-1.9	-11.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.2	10.3	11.1	12.0	13.5	12.8	11.0	11.5	13.0	11.2	9.3	7.8	(35)
(36)			MCDBR	10.0	12.9	13.8	18.1	19.5	17.7	15.2	15.4	17.4	16.3	11.9	9.6	(36)
(37)			MCWBR	8.8	10.3	8.9	9.8	9.1	7.8	6.8	7.6	8.9	9.3	8.3	8.3	(37)
(38)		5% WB	MCDBR	10.0	12.7	13.1	17.0	16.4	14.1	11.9	11.8	13.8	14.9	11.6	9.5	(38)
(39)			MCWBR	8.8	10.2	8.7	9.4	8.3	7.0	6.3	6.6	7.9	8.9	8.3	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.285	0.336	0.417	0.487	0.476	0.446	0.410	0.355	0.331	0.289	0.270	(40)	
(41)		taud	2.259	2.199	2.116	2.017	1.897	2.041	2.191	2.271	2.370	2.324	2.309	2.210	(41)	
(42)		Ebn at Noon	803	863	865	825	779	793	813	827	845	798	759	727	(42)	
(43)		Edh at Noon	73	99	128	159	187	163	138	122	100	88	70	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.83	3.03	4.45	5.23	5.67	5.83	5.46	5.00	4.09	2.87	1.81	1.39	(44)	
(45)		RadStd	0.07	0.10	0.24	0.33	0.43	0.58	0.53	0.44	0.34	0.20	0.11	0.10	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	-1.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page