

KESHAN, ChinaWMO: **506580**Lat: **48.0842N**Lon: **125.7880E**Elev: **958**StdP: **14.19**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.1	-20.1	-29.8	1.1	-23.0	-26.0	1.3	-19.1	16.1	3.8	14.1	2.2	1.5	340	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	87.7	68.0	84.6	67.9	82.0	67.5	74.3	80.6	72.4	79.3	70.9	78.0	8.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.3	123.7	77.7	70.4	115.8	76.4	68.4	108.3	75.0	38.7	80.4	37.0	78.7	35.5	78.3	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	15.7	13.4	DB	-27.6	93.2	6.7	3.6	-32.4	95.9	-36.3	98.0	-40.0	100.0	-44.9	102.7	(4)
(5)			WB	-27.8	76.7	6.6	2.0	-32.6	78.2	-36.4	79.3	-40.2	80.4	-45.0	81.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	-5.5	3.3	21.5	41.9	56.8	68.3	72.5	68.4	57.2	40.2	16.9	-1.4
	DBStd	28.79	8.27	9.49	11.49	8.46	7.56	6.50	4.38	4.88	6.84	8.51	11.76	8.14
	HDD50	7127	1721	1307	883	270	20	0	0	0	17	321	993	1595
	HDD65	10815	2186	1727	1348	695	275	39	3	22	247	770	1443	2060
	CDD50	2319	0	0	0	26	230	548	697	570	232	16	0	0
	CDD65	532	0	0	0	1	20	137	235	127	12	0	0	0
	CDH74	4032	0	0	0	10	273	1237	1626	767	118	1	0	0
	CDH80	1065	0	0	0	1	69	422	434	122	17	0	0	0
Wind	WSAvg	5.6	3.8	4.4	6.3	7.7	7.5	6.1	5.5	5.2	5.6	6.0	5.1	4.2
Precipitation	PrecAvg	20.6	0.1	0.1	0.3	0.8	1.5	3.5	6.5	4.2	2.2	0.7	0.3	0.2
	PrecMax	33.8	0.4	0.6	1.1	3.1	3.5	10.8	13.9	10.4	4.8	1.6	1.2	0.7
	PrecMin	13.1	0.0	0.0	0.0	0.1	0.2	0.9	0.6	1.5	0.2	0.0	0.0	0.0
	PrecStd	5.3	0.1	0.1	0.3	0.7	0.9	2.0	3.3	2.2	1.4	0.5	0.3	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	35.9	54.6	74.2	86.4	94.4	91.7	86.2	82.1	69.2	48.8	24.7
		MCWB	16.7	28.8	40.7	51.8	59.4	67.0	71.1	71.0	65.1	54.5	40.1	21.9
	2%	DB	14.2	28.7	47.7	67.8	81.4	88.4	87.6	83.3	77.2	62.6	42.8	18.0
		MCWB	12.1	24.2	36.9	48.5	57.9	65.8	71.0	70.5	62.6	50.0	35.9	15.9
	5%	DB	9.8	23.0	42.7	62.4	76.4	84.7	84.6	80.9	73.7	57.9	37.3	14.2
		MCWB	8.1	19.5	33.9	46.1	55.8	65.1	70.8	69.5	60.4	47.6	31.8	12.4
	10%	DB	6.4	18.1	38.2	57.3	71.8	81.1	81.9	78.6	70.0	53.7	32.7	10.7
		MCWB	4.9	15.5	31.2	43.5	53.6	64.0	70.0	68.0	58.7	44.8	28.6	9.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.7	29.8	42.5	53.9	62.8	72.1	77.5	75.9	68.5	56.6	40.5	22.1
		MCDB	19.0	34.7	52.2	68.7	79.1	83.5	83.5	80.8	78.5	64.0	46.6	23.8
	2%	WB	12.2	24.0	37.6	50.1	60.0	69.8	75.2	73.6	65.7	52.2	36.2	16.0
		MCDB	14.1	28.8	46.2	64.6	74.7	81.7	81.7	79.7	73.1	60.0	42.4	17.7
	5%	WB	8.2	19.5	34.4	47.1	57.9	67.9	73.4	71.8	62.9	48.9	32.2	12.6
		MCDB	9.8	22.9	41.6	60.6	72.2	79.2	79.8	78.2	69.9	55.7	36.4	14.2
	10%	WB	5.0	15.5	31.6	44.5	55.7	66.2	71.9	70.0	60.5	45.6	28.8	9.2
		MCDB	6.4	18.0	37.6	55.6	69.1	76.6	78.7	76.0	68.0	53.2	32.5	10.6
Mean Daily Temperature Range	5% DB	MDBR	15.9	18.7	18.1	19.5	19.9	17.8	14.9	15.9	19.5	17.5	15.5	14.3
		MCDBR	17.3	21.7	22.2	27.4	27.1	23.6	19.7	19.1	24.8	23.8	20.7	16.7
		MCWBR	15.6	18.1	14.1	14.8	11.7	8.9	7.9	8.6	11.6	13.9	14.8	15.0
	5% WB	MCDBR	17.3	21.1	20.4	24.6	22.4	18.6	14.6	15.1	19.3	20.7	19.8	16.5
		MCWBR	15.7	17.7	13.5	14.2	11.0	8.2	7.9	8.2	10.6	14.0	14.6	14.9
Clear-Sky Solar Irradiance	taub	0.289	0.311	0.369	0.464	0.533	0.547	0.519	0.462	0.413	0.389	0.324	0.295	
	taud	2.179	2.125	2.036	1.919	1.811	1.881	1.986	2.117	2.175	2.123	2.219	2.163	
	Ebn at Noon	242	263	263	248	235	233	238	247	247	229	225	220	
	Edh at Noon	26	35	45	56	65	61	54	45	39	35	25	23	
All-Sky Solar Radiation	RadAvg	610	985	1394	1606	1794	1850	1725	1580	1323	913	572	454	
	RadStd	37	61	98	128	146	213	180	120	106	53	43	42	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page