

SANJIAZI, China

WMO: 507450

Lat: 47.3761N

Lon: 123.9236E

Elev: 486

StdP: 14.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-14.5	-26.0	1.3	-15.3	-22.6	1.6	-12.3	17.7	6.8	15.3	6.2	2.6	250	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	89.9	69.6	86.8	68.9	84.2	68.4	75.2	82.4	73.5	81.0	71.9	80.0	8.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.0	124.6	79.6	71.1	116.7	77.9	69.3	109.5	76.6	39.2	82.6	37.6	80.7	36.1	80.2	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.3	14.1	DB	-21.6	95.1	5.6	3.7	-25.7	97.7	-29.0	99.9	-32.1	102.0	-36.2	104.7	(4)
(5)			WB	-21.9	77.7	5.6	2.1	-25.9	79.2	-29.1	80.4	-32.2	81.5	-36.3	83.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	0.2	9.6	25.9	44.8	59.4	70.6	74.9	71.2	59.9	43.1	21.1	4.0
	DBStd	27.50	7.61	9.24	10.61	8.67	7.64	6.54	4.75	4.88	7.07	8.37	10.92	8.15
	HDD50	6178	1544	1131	746	204	10	0	0	0	7	245	866	1425
	HDD65	9688	2009	1551	1211	608	209	21	1	8	184	680	1316	1890
	CDD50	2730	0	0	1	47	302	618	771	658	303	30	0	0
	CDD65	764	0	0	0	2	36	188	307	201	30	0	0	0
	CDH74	6170	0	0	0	22	384	1704	2511	1349	198	2	0	0
	CDH80	1834	0	0	0	4	109	601	792	296	32	0	0	0
Wind	WSAvg	6.4	4.8	5.6	7.2	8.3	8.0	6.6	6.0	5.8	6.4	6.5	6.0	5.0
Precipitation	PrecAvg	17.3	0.1	0.1	0.2	0.7	1.2	2.8	5.4	3.6	1.8	0.7	0.2	0.2
	PrecMax	25.7	0.3	0.6	0.9	3.6	4.3	8.9	10.9	8.8	4.8	2.8	1.0	0.6
	PrecMin	9.8	0.0	0.0	0.0	0.0	0.0	0.3	0.4	0.2	0.2	0.0	0.0	0.0
	PrecStd	3.8	0.1	0.1	0.2	0.6	1.0	1.6	2.6	2.0	1.3	0.6	0.2	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.6	40.8	59.7	76.9	88.3	95.0	93.8	89.1	84.1	71.6	52.4	30.5
		MCWB	20.1	31.3	42.9	53.3	61.3	68.5	72.0	70.8	66.3	55.2	40.7	25.0
	2%	DB	19.5	34.0	52.1	70.6	83.0	90.3	90.1	85.7	79.1	65.3	46.0	24.4
		MCWB	15.7	26.4	39.0	49.7	59.3	67.5	72.1	71.3	63.9	51.8	36.9	20.3
	5%	DB	15.7	28.9	47.0	65.7	78.0	86.3	86.9	83.3	75.7	60.3	40.4	20.0
		MCWB	12.8	23.2	35.4	47.8	57.2	66.4	71.2	70.2	61.7	48.3	33.3	16.8
	10%	DB	12.1	24.7	42.6	60.9	73.7	83.0	84.3	81.0	72.4	56.4	35.7	16.4
		MCWB	9.8	20.2	32.8	45.3	55.0	65.3	70.6	69.1	59.8	46.1	29.8	13.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.8	30.7	43.7	54.8	64.4	72.8	78.6	76.4	70.8	57.9	41.4	25.8
		MCDB	24.4	39.9	57.3	72.0	79.9	86.4	85.5	82.6	78.6	67.1	50.2	30.0
	2%	WB	16.0	26.7	39.3	51.5	61.5	70.7	76.0	74.5	67.0	53.6	37.1	20.5
		MCDB	19.3	33.4	51.0	66.9	76.4	83.6	83.4	81.3	74.6	62.4	45.7	24.1
	5%	WB	12.7	23.4	36.2	48.6	59.3	69.2	74.5	72.7	64.3	50.2	33.5	16.9
		MCDB	15.5	28.8	46.1	63.6	73.7	80.5	81.8	80.0	72.3	59.0	39.7	19.8
	10%	WB	9.8	20.2	33.1	46.0	57.2	67.7	72.9	71.1	61.8	46.8	30.4	13.7
		MCDB	12.1	24.7	41.8	59.6	71.5	78.4	80.4	78.5	69.8	55.1	35.1	16.3
Mean Daily Temperature Range	5% DB	MDBR	17.9	20.0	19.7	20.8	19.7	17.2	14.5	15.1	18.1	17.7	15.5	16.1
		MCDBR	20.6	23.2	24.2	26.5	25.0	22.0	18.3	17.5	20.9	23.2	20.0	18.9
		MCWBR	17.6	17.6	14.6	13.5	10.5	7.6	6.5	6.9	9.5	12.5	13.0	15.4
	5% WB	MCDBR	20.2	22.7	23.2	23.9	20.8	17.4	13.8	14.3	16.2	20.4	19.2	18.7
		MCWBR	17.4	17.4	14.3	13.0	10.1	7.3	7.1	6.9	9.0	12.9	12.7	15.3
Clear-Sky Solar Irradiance	taub	0.289	0.311	0.373	0.465	0.532	0.564	0.529	0.473	0.413	0.384	0.325	0.299	
	taud	2.216	2.181	2.075	1.912	1.811	1.843	1.976	2.103	2.181	2.133	2.211	2.176	
	Ebn at Noon	246	266	264	249	236	230	236	245	249	233	228	223	
	Edh at Noon	26	33	43	56	65	63	55	46	39	35	26	24	
All-Sky Solar Radiation	RadAvg	617	986	1386	1656	1840	1835	1749	1621	1368	967	608	466	
	RadStd	53	70	93	107	138	191	187	121	116	52	41	45	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page