

FUJIN, China

WMO: 507880

Lat: 47.2278N

Lon: 131.9990E

Elev: 213

StdP: 14.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.8	-14.6	-24.7	1.4	-16.8	-21.8	1.7	-13.7	22.8	0.0	20.9	-0.2	6.7	270	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	87.2	70.5	84.4	70.5	81.7	69.7	75.5	82.3	73.8	80.5	72.2	78.4	8.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	125.6	79.6	71.8	118.3	77.4	70.2	111.8	75.8	39.3	82.6	37.7	80.4	36.2	78.3	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	19.1	16.9	DB	-23.6	93.1	4.0	3.2	-26.4	95.4	-28.8	97.3	-31.0	99.1	-34.0	101.4	(4)
(5)			WB	-23.8	78.1	3.9	1.7	-26.7	79.4	-29.0	80.4	-31.2	81.4	-34.1	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.4	-1.6	6.2	22.6	42.3	57.0	67.4	72.4	69.3	58.5	42.2	20.0	2.0		
	DBStd	27.41	7.34	8.53	10.34	7.82	7.45	6.52	4.51	4.71	6.31	8.33	11.35	8.07		
	HDD50	6612	1598	1226	850	256	20	0	0	0	8	266	899	1489		
	HDD65	10261	2063	1646	1315	682	267	49	3	16	209	708	1349	1954		
	CDD50	2361	0	0	0	24	236	523	694	598	262	24	0	0		
	CDD65	534	0	0	0	0	18	122	232	148	14	0	0	0		
	CDH74	3757	0	0	0	14	243	999	1568	815	116	2	0	0		
	CDH80	957	0	0	0	2	63	319	429	129	15	0	0	0		
	WSAvg	8.1	8.7	8.4	8.6	9.1	9.1	7.7	6.7	6.3	6.8	8.2	8.7	8.5		
	PrecAvg	20.2	0.2	0.2	0.4	1.1	1.8	3.2	4.1	4.9	2.5	1.2	0.4	0.3		
(15) Precipitation	PrecMax	28.0	0.5	0.8	0.9	5.5	5.2	6.0	7.2	9.1	7.0	4.1	1.2	0.9		
	PrecMin	13.3	0.0	0.0	0.0	0.1	0.3	1.0	0.8	0.6	0.4	0.1	0.0	0.0		
	PrecStd	4.6	0.1	0.2	0.2	0.9	1.0	1.3	1.6	2.2	1.7	1.0	0.3	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.8	36.5	52.8	74.9	86.8	92.6	91.5	86.5	82.0	70.8	51.7	30.4		
		MCWB	19.0	30.2	42.7	53.1	61.8	69.7	73.5	75.4	67.7	56.2	43.1	27.3		
	2%	DB	16.4	30.7	46.6	67.4	80.5	87.3	87.4	83.4	77.1	64.4	45.1	22.7		
		MCWB	14.3	26.6	38.0	50.4	59.8	68.2	72.9	73.4	64.9	52.3	38.8	20.7		
	5%	DB	12.8	24.9	41.7	61.2	75.5	83.5	84.5	81.0	73.9	59.5	39.9	17.8		
		MCWB	10.9	21.7	34.4	47.1	57.5	66.9	72.5	71.7	63.1	49.5	34.8	15.8		
	10%	DB	9.4	19.9	37.4	56.1	70.9	79.8	81.9	78.7	70.6	55.0	35.6	14.1		
		MCWB	7.9	17.3	32.1	44.9	56.0	65.4	71.7	70.3	61.3	46.9	31.5	12.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	31.5	43.7	55.8	65.2	73.7	77.9	77.7	70.8	58.3	44.4	27.6		
		MCDB	21.7	36.0	51.6	71.5	80.4	84.8	84.8	83.8	77.2	67.3	50.3	30.5		
	2%	WB	14.4	26.5	39.0	51.7	62.1	71.4	76.0	75.3	67.6	54.6	39.2	20.8		
		MCDB	16.3	30.9	45.1	64.8	76.0	81.5	83.0	81.1	73.8	61.6	44.5	22.7		
	5%	WB	10.9	21.7	35.1	48.5	59.6	69.5	74.5	73.5	65.1	51.0	35.3	15.9		
		MCDB	12.6	24.9	40.5	59.5	72.2	78.9	81.6	79.1	71.8	57.6	39.3	17.7		
	10%	WB	7.9	17.3	32.2	45.5	57.6	67.5	73.1	71.9	62.6	47.8	32.2	12.5		
		MCDB	9.4	19.9	36.9	54.1	68.2	76.3	79.7	76.9	68.6	53.8	35.3	14.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	18.3	17.5	18.5	18.5	16.6	14.6	14.8	19.0	17.6	14.7	13.6		
		MCDBR	16.6	21.4	20.1	27.8	26.7	23.3	19.4	18.4	24.1	24.8	19.8	17.0		
		MCWBR	15.0	18.2	13.2	14.5	11.2	8.6	8.0	9.4	12.1	14.0	14.3	15.4		
		MCDBR	16.7	21.0	18.5	25.0	22.7	19.6	16.0	16.0	20.0	22.2	18.7	16.7		
	5% WB	MCWBR	15.1	17.9	12.8	14.0	10.4	8.6	8.3	8.8	11.3	13.7	14.1	15.4		
(40) Clear-Sky Solar Irradiance	taub		0.302	0.338	0.422	0.547	0.583	0.552	0.520	0.473	0.431	0.448	0.372	0.314		
	taud		2.119	1.996	1.848	1.723	1.718	1.887	2.005	2.117	2.140	1.945	2.048	2.087		
	Ebn at Noon		238	252	245	226	224	233	239	245	243	208	204	214		
	Edh at Noon		28	40	55	69	71	61	53	46	41	42	31	26		
(44) All-Sky Solar Radiation	RadAvg		639	1034	1433	1522	1684	1772	1662	1518	1281	878	585	493		
	RadStd		48	43	116	157	143	218	170	98	119	59	44	38		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	+1.03	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page