

TAILAI, China

WMO: 508440

Lat: 46.4012N

Lon: 123.4530E

Elev: 456

StdP: 14.46

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.4	-13.5	-26.5	1.3	-14.4	-22.5	1.6	-9.8	19.0	12.1	16.7	12.4	3.5	290	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	90.9	69.1	87.7	68.9	85.1	68.3	75.9	83.0	74.1	81.5	72.4	80.0	9.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	128.0	80.0	71.8	119.5	78.5	70.0	112.1	76.9	39.9	82.8	38.2	81.1	36.6	80.1	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.9	17.7	15.5	DB	-20.5	96.8	7.1	3.6	-25.6	99.4	-29.8	101.4	-33.7	103.5	-38.9	106.0
(5)				WB	-20.9	78.0	6.8	2.2	-25.8	79.6	-29.8	80.9	-33.6	82.1	-38.5	83.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	2.8	11.9	27.5	45.8	60.1	71.0	75.2	71.7	60.7	43.9	22.8	6.2	(6)
(7)		DBStd	26.80	8.06	9.44	10.27	8.76	7.59	6.38	4.61	4.82	7.03	8.65	10.82	8.50	(7)
(8)		HDD50	5823	1462	1066	700	182	7	0	0	0	6	227	816	1357	(8)
(9)		HDD65	9275	1927	1486	1164	576	192	17	1	6	164	654	1266	1822	(9)
(10)		CDD50	2829	0	0	1	57	322	630	782	673	326	38	0	0	(10)
(11)		CDD65	808	0	0	0	1	41	198	318	215	35	0	0	0	(11)
(12)		CDH74	6891	0	0	0	34	482	1834	2662	1578	293	8	0	0	(12)
(13)		CDH80	2193	0	0	0	8	160	686	883	404	51	1	0	0	(13)
(14)	Wind	WSAvg	7.1	5.7	6.5	8.2	9.3	9.1	7.4	6.6	6.2	6.7	7.1	6.6	5.9	(14)
(15)	Precipitation	PrecAvg	15.4	0.0	0.1	0.2	0.5	1.0	2.8	5.1	3.3	1.6	0.6	0.2	0.1	(15)
(16)		PrecMax	26.5	0.2	0.3	0.8	3.3	3.1	6.7	13.9	7.9	3.3	2.5	0.6	0.3	(16)
(17)		PrecMin	8.9	0.0	0.0	0.0	0.0	0.0	0.0	1.3	0.5	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	3.9	0.0	0.1	0.2	0.7	0.7	1.7	2.6	2.0	0.9	0.6	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	43.5	62.3	78.6	90.8	97.1	95.2	90.4	85.4	73.8	55.1	33.7	(19)
(20)		MCWB	22.1	32.4	43.8	53.3	60.7	67.4	72.3	71.4	66.3	55.2	41.7	27.6	(20)	
(21)		2%	DB	22.2	36.7	54.2	72.0	84.7	91.3	90.7	86.9	80.6	67.2	48.2	27.0	(21)
(22)		MCWB	17.8	28.1	39.3	50.1	59.1	66.9	71.8	70.8	63.7	52.2	37.5	22.4	(22)	
(23)		5%	DB	18.3	31.5	48.8	67.3	79.4	87.2	87.7	84.3	77.3	61.9	42.4	22.6	(23)
(24)		MCWB	14.8	25.0	36.3	48.1	57.5	66.1	71.7	70.2	61.9	48.9	34.4	18.8	(24)	
(25)		10%	DB	14.7	27.2	44.1	62.3	74.8	83.9	84.8	81.9	73.9	57.8	37.5	18.8	(25)
(26)		MCWB	11.8	21.8	33.3	45.5	55.3	65.0	71.1	69.1	59.9	46.6	30.8	15.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	32.5	44.3	55.3	64.8	73.1	79.0	77.2	71.0	58.4	42.1	28.4	(27)
(28)		MCDWB	27.8	42.9	60.2	73.4	80.9	85.4	85.2	83.9	78.9	68.3	53.6	33.7	(28)	
(29)		2%	WB	18.0	28.5	39.9	52.1	61.9	70.8	76.8	75.3	67.5	54.6	38.3	22.4	(29)
(30)		MCDWB	22.0	36.3	52.9	68.0	76.7	82.2	84.0	82.1	75.5	63.7	47.3	26.9	(30)	
(31)		5%	WB	14.9	25.1	36.8	49.1	59.6	69.3	75.1	73.5	64.8	51.0	34.8	18.9	(31)
(32)		MCDWB	18.3	31.4	47.7	65.5	74.4	80.4	82.3	80.7	73.1	59.7	42.1	22.3	(32)	
(33)		10%	WB	12.0	21.9	33.6	46.4	57.6	67.9	73.5	71.6	62.2	47.7	31.3	15.7	(33)
(34)		MCDWB	14.7	27.1	43.2	60.4	72.6	78.8	80.8	78.7	70.8	56.7	36.9	18.7	(34)	
(35)	Mean Daily Temperature Range		MDBR	18.9	20.6	20.6	21.6	20.3	17.7	15.2	16.5	20.0	19.0	17.1	17.3	(35)
(36)		5% DB	MCDBR	21.7	23.2	26.2	28.0	27.3	23.3	19.4	19.7	23.6	24.8	21.4	19.9	(36)
(37)			MCWBR	18.0	17.2	15.8	14.2	10.9	7.8	7.4	7.8	10.4	13.0	13.9	16.0	(37)
(38)			MCDBR	21.5	23.1	25.2	25.2	22.0	17.7	14.9	15.4	19.0	21.5	20.9	19.6	(38)
(39)		5% WB	MCWBR	17.9	17.4	15.5	13.5	10.4	7.2	7.5	7.8	10.0	13.1	13.7	15.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.312	0.377	0.466	0.538	0.590	0.543	0.483	0.424	0.390	0.328	0.300	(40)	
(41)		taud	2.212	2.187	2.073	1.896	1.786	1.772	1.933	2.067	2.139	2.109	2.192	2.176	(41)	
(42)		Ebn at Noon	249	269	265	250	236	224	233	243	247	234	230	228	(42)	
(43)		Edh at Noon	27	34	44	58	67	69	57	48	41	36	27	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	628	990	1395	1724	1907	1869	1802	1703	1440	1026	657	501	(44)	
(45)		RadStd	66	73	80	104	125	165	172	105	109	52	44	38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	-4.61	-2.70	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page