

BAOQING, China

WMO: 508880

Lat: 46.3883N

Lon: 132.1650E

Elev: 272

StdP: 14.55

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-11.9	-23.2	1.5	-13.6	-19.9	1.9	-9.8	26.1	6.5	22.7	8.9	2.6	180	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	87.9	70.9	85.1	70.3	82.5	69.4	75.4	83.0	73.8	81.4	72.1	79.2	7.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.1	124.2	80.2	71.3	116.5	78.4	69.7	110.3	76.4	39.3	83.0	37.7	81.5	36.2	79.3	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.8	19.2	16.5	DB	-20.5	93.5	6.0	3.0	-24.9	95.7	-28.4	97.4	-31.8	99.1	-36.2	101.3	(4)
(5)			WB	-20.9	77.8	5.9	2.3	-25.1	79.4	-28.6	80.8	-31.9	82.0	-36.2	83.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.4	2.4	9.9	25.3	43.7	57.6	67.8	72.9	70.0	59.6	44.2	23.2	6.0		
	DBStd	26.21	8.10	8.99	10.07	8.38	7.65	6.79	4.68	5.10	6.59	8.63	11.61	8.50		
	HDD50	6002	1475	1124	766	226	17	0	0	0	6	220	804	1364		
	HDD65	9590	1940	1544	1231	641	253	48	3	15	186	647	1253	1829		
	CDD50	2486	0	0	0	37	253	533	710	619	293	40	1	0		
	CDD65	597	0	0	0	2	24	130	247	170	23	1	0	0		
	CDH74	4349	0	0	0	21	261	1104	1758	1033	166	6	0	0		
	CDH80	1153	0	0	0	3	66	353	504	203	23	1	0	0		
(14) Wind	WSAvg	6.9	6.4	7.2	8.3	8.6	7.9	6.5	5.7	5.3	6.0	7.4	7.6	6.6		
(15) Precipitation	PrecAvg	20.5	0.1	0.2	0.3	0.9	1.9	3.1	4.2	5.0	2.8	1.3	0.5	0.2		
	PrecMax	32.6	0.5	0.6	1.7	3.0	4.0	7.2	8.3	10.8	8.0	3.5	1.5	0.7		
	PrecMin	12.8	0.0	0.0	0.0	0.0	0.6	0.5	1.1	0.9	0.4	0.0	0.0	0.0		
	PrecStd	5.5	0.1	0.2	0.3	0.6	0.9	1.9	1.8	2.4	1.9	0.9	0.4	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.3	40.3	56.2	77.0	87.3	92.4	92.5	87.8	83.0	73.3	56.0	36.5		
		MCWB	23.1	31.8	43.4	54.6	61.7	69.3	73.3	75.1	68.0	56.5	45.3	30.8		
	2%	DB	22.1	35.0	49.4	69.6	81.0	87.5	88.1	84.7	78.4	66.9	50.6	27.7		
		MCWB	18.5	28.9	39.3	50.5	59.7	67.2	73.1	73.3	64.7	53.3	41.9	24.3		
	5%	DB	17.9	29.9	44.8	63.7	76.3	84.1	85.4	82.1	75.1	62.0	44.5	23.1		
		MCWB	15.2	24.7	35.8	47.8	57.3	66.4	72.4	71.9	63.2	50.5	37.1	20.0		
	10%	DB	14.5	24.7	40.4	58.4	72.0	80.5	82.6	79.7	71.9	57.9	39.4	19.2		
		MCWB	12.2	20.6	33.0	45.1	55.7	65.4	71.6	70.4	61.4	48.7	33.5	16.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	33.8	44.4	54.9	64.8	73.9	78.6	77.4	70.8	58.8	46.7	31.0		
		MCDB	27.4	39.7	54.7	73.7	79.9	86.2	86.3	84.6	77.2	69.3	53.9	36.2		
	2%	WB	18.6	29.1	39.9	51.4	61.8	71.4	76.1	75.1	67.9	55.4	42.0	24.4		
		MCDB	21.9	35.5	48.3	65.7	75.7	81.3	83.7	82.4	74.4	63.5	49.7	27.3		
	5%	WB	15.3	24.9	36.5	48.7	59.5	69.2	74.5	73.5	65.4	52.4	37.7	20.2		
		MCDB	17.9	29.8	43.5	61.9	72.4	79.4	82.1	80.3	72.9	60.2	43.8	23.1		
	10%	WB	12.2	20.6	33.6	46.0	57.6	67.3	72.9	71.9	63.0	49.3	33.8	16.4		
		MCDB	14.6	24.7	39.6	57.0	69.2	77.1	80.3	78.0	69.7	57.0	38.3	19.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	17.7	16.5	18.1	17.8	16.4	14.4	15.1	19.1	17.8	14.4	13.9		
		MCDBR	18.5	21.9	21.5	25.9	25.2	22.0	19.3	18.2	22.9	24.3	20.1	17.6		
		MCWBR	15.8	17.4	13.8	13.4	11.0	8.4	8.4	9.0	11.3	13.4	13.8	15.3		
	5% WB	MCDBR	18.5	21.2	19.9	22.8	20.7	18.4	16.1	15.7	19.2	21.7	19.1	17.1		
		MCWBR	15.8	17.1	13.1	12.7	10.2	8.2	8.6	8.2	10.6	13.3	13.8	15.1		
(40) Clear-Sky Solar Irradiance	taub		0.307	0.343	0.424	0.538	0.574	0.556	0.519	0.477	0.431	0.443	0.372	0.320		
	taud		2.107	1.987	1.868	1.745	1.737	1.876	2.012	2.113	2.146	1.969	2.056	2.080		
	Ebn at Noon		239	252	246	229	227	233	240	245	245	213	208	215		
	Edh at Noon		30	41	54	68	70	62	53	46	41	42	31	27		
(44) All-Sky Solar Radiation	RadAvg		667	1055	1436	1498	1655	1754	1636	1501	1291	892	604	519		
	RadStd		49	46	108	155	139	213	166	103	116	58	45	34		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page