

BAOQING, China

WMO: 508880

Lat: 46.3883N

Lon: 132.1650E

Elev: 83

StdP: 100.33

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.6	-24.4	-30.7	0.2	-25.3	-28.8	0.3	-23.2	11.7	-14.1	10.2	-12.8	1.1	180	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	31.0	21.6	29.5	21.3	28.1	20.8	24.1	28.3	23.2	27.4	22.3	26.2	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.7	26.8	21.8	16.6	25.8	20.9	15.8	24.7	73.5	28.3	69.8	27.5	66.2	26.3	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.6	7.4	-29.2	34.2	3.3	1.7	-31.6	35.4	-33.6	36.3	-35.4	37.3	-37.9	38.5		
(5)			-29.4	25.5	3.3	1.3	-31.7	26.4	-33.7	27.1	-35.5	27.8	-37.9	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.6	-16.4	-12.3	-3.7	6.5	14.2	19.9	22.7	21.1	15.3	6.8	-4.9	-14.4	(6)
(7)		DBStd	14.56	4.50	4.99	5.60	4.66	4.25	3.77	2.60	2.84	3.66	4.79	6.45	4.72	(7)
(8)		HDD10.0	3334	819	624	426	126	9	0	0	0	3	122	447	758	(8)
(9)		HDD18.3	5328	1078	858	684	356	141	27	2	8	103	359	696	1016	(9)
(10)		CDD10.0	1381	0	0	0	21	141	296	394	344	163	22	1	0	(10)
(11)		CDD18.3	332	0	0	0	1	13	72	137	94	13	1	0	0	(11)
(12)		CDH23.3	2416	0	0	0	12	145	613	977	574	92	3	0	0	(12)
(13)		CDH26.7	641	0	0	0	2	37	196	280	113	13	1	0	0	(13)
(14)	Wind	WSAvg	3.1	2.9	3.2	3.7	3.8	3.5	2.9	2.5	2.4	2.7	3.3	3.4	3.0	(14)
(15)	Precipitation	PrecAvg	521	3	4	8	24	48	78	106	128	72	32	12	6	(15)
(16)		PrecMax	828	12	14	43	77	101	182	212	274	202	90	37	18	(16)
(17)		PrecMin	324	0	0	1	1	14	13	27	24	9	0	0	0	(17)
(18)		PrecStd	140	3	4	8	16	24	47	46	60	48	24	10	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.6	4.6	13.5	25.0	30.7	33.6	33.6	31.0	28.3	22.9	13.3	2.5	(19)
(20)			MCWB	-4.9	-0.1	6.3	12.6	16.5	20.7	23.0	23.9	20.0	13.6	7.4	-0.7	(20)
(21)		2%	DB	-5.5	1.7	9.6	20.9	27.2	30.9	31.2	29.3	25.8	19.4	10.3	-2.4	(21)
(22)			MCWB	-7.5	-1.7	4.0	10.3	15.4	19.6	22.8	22.9	18.2	11.8	5.5	-4.3	(22)
(23)		5%	DB	-7.8	-1.2	7.1	17.6	24.6	28.9	29.7	27.9	24.0	16.7	6.9	-4.9	(23)
(24)			MCWB	-9.3	-4.1	2.1	8.8	14.1	19.1	22.4	22.2	17.3	10.3	2.8	-6.7	(24)
(25)		10%	DB	-9.7	-4.0	4.6	14.7	22.2	27.0	28.1	26.5	22.2	14.4	4.1	-7.1	(25)
(26)			MCWB	-11.0	-6.4	0.6	7.3	13.2	18.6	22.0	21.4	16.3	9.3	0.8	-8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.0	1.0	6.9	12.7	18.2	23.3	25.9	25.2	21.6	14.9	8.2	-0.6	(27)
(28)			MCDWB	-2.6	4.3	12.6	23.2	26.6	30.1	30.2	29.2	25.1	20.7	12.2	2.3	(28)
(29)		2%	WB	-7.4	-1.6	4.4	10.8	16.6	21.9	24.5	24.0	19.9	13.0	5.5	-4.2	(29)
(30)			MCDWB	-5.6	1.9	9.0	18.7	24.3	27.4	28.7	28.0	23.6	17.5	9.8	-2.6	(30)
(31)		5%	WB	-9.3	-4.0	2.5	9.3	15.3	20.7	23.6	23.0	18.6	11.3	3.2	-6.5	(31)
(32)			MCDWB	-7.8	-1.2	6.4	16.6	22.5	26.3	27.8	26.8	22.7	15.7	6.6	-5.0	(32)
(33)		10%	WB	-11.0	-6.3	0.9	7.8	14.2	19.6	22.7	22.1	17.2	9.6	1.0	-8.7	(33)
(34)			MCDWB	-9.7	-4.1	4.2	13.9	20.6	25.1	26.8	25.5	21.0	13.9	3.5	-7.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.8	9.2	10.0	9.9	9.1	8.0	8.4	10.6	9.9	8.0	7.7	(35)
(36)			MCDBR	10.3	12.2	12.0	14.4	14.0	12.2	10.7	10.1	12.7	13.5	11.2	9.8	(36)
(37)			MCWBR	8.8	9.7	7.7	7.4	6.1	4.7	4.7	5.0	6.3	7.5	7.7	8.5	(37)
(38)		5% WB	MCDBR	10.3	11.8	11.0	12.7	11.5	10.2	9.0	8.7	10.6	12.0	10.6	9.5	(38)
(39)			MCWBR	8.8	9.5	7.3	7.0	5.6	4.6	4.8	4.6	5.9	7.4	7.7	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.343	0.424	0.538	0.574	0.556	0.519	0.477	0.431	0.443	0.372	0.320	(40)	
(41)		taud	2.107	1.987	1.868	1.745	1.737	1.876	2.012	2.113	2.146	1.969	2.056	2.080	(41)	
(42)		Ebn at Noon	753	795	776	723	715	733	756	773	771	672	656	679	(42)	
(43)		Edh at Noon	93	130	171	213	222	194	168	146	129	132	99	86	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.10	3.33	4.53	4.72	5.22	5.53	5.16	4.73	4.07	2.81	1.91	1.64	(44)	
(45)		RadStd	0.15	0.15	0.34	0.49	0.44	0.67	0.52	0.32	0.37	0.18	0.14	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page