

HULIN, China

WMO: 509830

Lat: 45.7606N

Lon: 132.8831E

Elev: 328

StdP: 14.52

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-12.8	-22.8	1.6	-14.6	-19.7	1.9	-11.4	21.3	8.2	19.3	6.9	2.6	290	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	84.9	72.6	82.5	71.4	80.0	70.0	75.5	81.6	73.8	79.5	72.2	77.6	5.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.6	126.5	79.1	71.9	119.5	77.5	70.3	113.1	75.9	39.4	81.7	37.7	79.9	36.3	77.6	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
18.8	16.0	13.7	DB	-20.4	89.6	4.8	3.5	-23.9	92.1	-26.6	94.1	-29.3	96.0	-32.8	98.6	
			WB	-20.7	77.7	4.7	2.0	-24.1	79.1	-26.8	80.3	-29.5	81.4	-32.9	82.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.6	0.8	8.9	25.1	42.8	56.3	66.2	72.1	70.2	59.6	43.8	22.7	4.8
	DBStd	26.25	7.79	8.57	9.61	7.43	6.56	5.82	4.28	4.75	6.20	8.15	11.25	8.43
	HDD50	6154	1526	1150	771	238	19	0	0	0	5	223	819	1403
	HDD65	9785	1991	1570	1236	665	278	54	3	13	182	656	1269	1868
	CDD50	2358	0	0	0	23	213	487	686	625	292	32	0	0
	CDD65	513	0	0	0	0	8	91	223	172	19	0	0	0
	CDH74	2822	0	0	0	2	84	546	1248	854	88	0	0	0
	CDH80	536	0	0	0	0	10	118	268	132	8	0	0	0
	WSAvg	5.6	4.7	5.5	6.7	6.9	6.6	5.5	4.9	4.6	4.8	5.9	5.8	4.9
	PrecAvg	21.9	0.2	0.3	0.5	1.3	2.1	3.2	4.1	4.6	3.0	1.7	0.7	0.3
Precipitation	PrecMax	33.4	0.5	0.9	1.7	3.5	4.5	7.6	7.7	8.4	9.1	4.4	1.8	0.9
	PrecMin	14.1	0.0	0.0	0.0	0.2	0.7	0.8	1.1	0.6	0.4	0.0	0.1	0.0
	PrecStd	4.6	0.1	0.2	0.4	0.7	0.9	1.7	1.8	2.1	1.8	1.2	0.4	0.2
	PrecStd	4.6	0.1	0.2	0.4	0.7	0.9	1.7	1.8	2.1	1.8	1.2	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	37.6	52.2	71.6	81.0	87.5	88.9	86.0	80.5	69.2	53.0	35.0
		MCWB	25.1	32.2	41.9	52.7	62.1	70.4	73.8	75.3	68.7	56.2	46.4	32.6
	2%	DB	19.8	32.7	46.7	65.6	76.1	83.3	85.5	83.4	76.2	64.5	46.9	27.3
		MCWB	17.1	28.8	37.9	49.8	58.9	68.2	73.9	73.6	65.8	54.7	41.7	24.8
	5%	DB	16.0	27.8	42.7	60.2	72.2	79.9	82.9	81.1	73.2	60.2	42.5	22.1
		MCWB	13.9	24.4	35.7	47.1	57.1	66.8	72.6	71.7	63.4	51.6	37.9	20.0
	10%	DB	12.5	22.9	38.5	55.8	68.6	76.7	80.5	78.7	70.6	56.6	38.2	17.5
		MCWB	10.6	19.7	32.7	44.7	55.7	65.9	71.4	70.3	62.2	49.6	34.2	15.3
	0.4%	WB	25.4	33.7	43.5	54.1	64.4	73.7	78.6	77.2	71.5	59.6	47.6	32.8
		MCDB	27.0	37.0	51.0	67.7	77.3	82.3	84.6	83.0	76.6	66.1	52.6	34.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	17.2	28.8	38.9	51.2	61.2	71.1	76.0	75.4	68.5	56.4	42.5	25.1
		MCDB	19.5	32.7	45.4	63.7	72.3	79.5	82.2	81.0	73.5	61.6	45.8	27.1
	5%	WB	14.0	24.4	35.9	48.4	59.1	69.0	74.3	73.8	66.1	53.6	38.2	20.0
		MCDB	16.0	27.7	41.3	58.0	69.2	76.8	80.3	79.0	71.7	58.7	42.2	22.0
	10%	WB	10.6	19.7	33.3	45.7	57.1	67.0	72.7	72.2	63.5	50.5	34.4	15.3
		MCDB	12.4	22.6	38.1	54.3	65.5	74.5	78.3	76.8	68.9	55.9	37.7	17.4
Mean Daily Temperature Range	5% DB	MDBR	15.5	17.3	15.8	17.3	16.8	14.7	13.0	13.9	18.0	17.4	14.3	14.0
		MCDBR	17.6	19.0	19.0	24.4	23.2	19.3	16.9	16.5	20.6	22.4	17.9	17.2
	5% WB	MCWBR	15.6	15.9	12.2	12.9	10.2	8.1	7.7	7.7	10.4	13.2	13.2	15.7
		MCDWR	17.8	18.6	17.8	22.2	20.0	16.9	14.5	13.9	16.7	19.5	17.2	17.3
	5% WB	MCWBR	15.9	15.8	12.0	12.7	9.8	8.1	7.5	7.4	9.4	13.2	13.6	16.1
		MCDWR	17.8	18.6	17.8	22.2	20.0	16.9	14.5	13.9	16.7	19.5	17.2	17.3
Clear-Sky Solar Irradiance	taub		0.310	0.354	0.433	0.547	0.573	0.552	0.512	0.474	0.429	0.447	0.380	0.325
	taud		2.079	1.945	1.842	1.730	1.748	1.888	2.036	2.130	2.160	1.962	2.034	2.047
	Ebn at Noon		240	249	245	228	228	234	242	247	246	213	207	216
	Edh at Noon		31	43	56	69	70	61	52	46	41	43	33	29
All-Sky Solar Radiation	RadAvg		670	1031	1396	1497	1669	1781	1617	1490	1293	903	620	523
	RadStd		33	45	90	152	130	210	158	106	110	63	45	29

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page