

BAYTIK SHAN, China

WMO: 512880

Lat: 45.3601N

Lon: 90.5707E

Elev: 5417

StdP: 12.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-6.0	-24.5	1.7	-3.1	-20.7	2.2	-0.8	17.6	16.9	15.1	14.2	4.2	70	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	82.7	55.3	79.9	54.2	77.1	53.3	58.1	73.3	56.7	72.0	55.6	71.2	10.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.8	75.5	60.3	51.7	69.6	60.1	49.7	64.7	60.2	27.6	73.2	26.6	72.0	25.7	71.5	64.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.6	19.0	16.3	DB	-16.5	87.3	5.8	3.1	-20.7	89.6	-24.0	91.4	-27.3	93.1	-31.5	95.4
(5)				WB	-17.1	60.4	5.6	2.1	-21.1	61.9	-24.4	63.2	-27.5	64.4	-31.6	65.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	38.8	9.8	14.4	25.6	41.1	51.9	62.2	65.8	63.5	53.3	39.2	24.0	13.6	(6)
(7)		DBStd	21.70	8.52	8.77	11.12	10.19	8.62	6.50	5.88	6.68	8.37	9.53	10.26	8.40	(7)
(8)		HDD50	5696	1247	997	756	290	82	4	0	2	61	348	779	1130	(8)
(9)		HDD65	9757	1712	1417	1221	718	412	125	60	109	359	800	1229	1595	(9)
(10)		CDD50	1615	0	0	0	23	139	370	491	420	159	13	0	0	(10)
(11)		CDD65	198	0	0	0	0	4	41	86	61	6	0	0	0	(11)
(12)		CDH74	1372	0	0	0	1	27	271	617	419	37	0	0	0	(12)
(13)		CDH80	240	0	0	0	0	0	35	133	70	2	0	0	0	(13)
(14)	Wind	WSAvg	6.7	4.2	4.4	5.8	8.5	9.3	8.9	8.3	8.0	7.7	6.2	5.0	4.4	(14)
(15)	Precipitation	PrecAvg	6.5	0.2	0.2	0.3	0.5	0.6	0.9	1.5	0.8	0.6	0.4	0.4	0.2	(15)
(16)		PrecMax	11.3	0.5	0.4	0.7	1.4	1.7	3.2	4.5	2.0	2.0	1.1	1.1	0.6	(16)
(17)		PrecMin	3.3	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.0	0.0	0.1	0.1	0.0	(17)
(18)		PrecStd	2.2	0.1	0.1	0.2	0.3	0.5	0.8	1.1	0.5	0.5	0.3	0.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	38.1	55.3	69.0	77.2	83.8	87.9	85.5	78.7	65.7	51.9	34.1	(19)
MCWB			27.1	29.4	39.0	46.2	50.3	55.1	57.4	55.9	52.0	44.5	37.6	26.7	(20)	
2%		DB	28.4	32.4	49.4	63.7	73.4	80.1	83.5	81.9	73.7	60.5	46.6	30.5	(21)	
		MCWB	23.1	25.5	36.4	43.4	49.1	53.5	56.2	54.5	49.9	41.8	34.5	24.4	(22)	
5%		DB	24.4	29.2	44.5	59.6	69.7	77.1	80.5	78.7	70.0	56.6	42.1	27.7	(23)	
		MCWB	19.7	23.2	34.1	41.4	47.8	52.7	55.2	53.5	48.2	40.1	32.1	22.4	(24)	
10%		DB	21.2	26.2	40.7	55.6	66.0	74.2	77.2	75.6	66.5	52.9	37.7	24.8	(25)	
		MCWB	17.2	21.0	32.0	39.9	46.3	52.1	54.4	52.7	46.6	38.8	29.5	20.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	29.8	40.5	48.0	53.1	58.1	61.1	59.2	53.7	46.0	38.5	28.1	(27)
MDCB			33.6	36.9	52.7	63.4	71.5	71.7	75.7	73.3	70.4	61.4	48.2	32.0	(28)	
2%		WB	23.5	26.1	37.5	45.4	50.9	56.5	58.9	56.7	51.4	43.4	35.3	25.1	(29)	
		MDCB	27.6	31.8	47.8	58.5	68.8	71.4	74.6	73.0	69.1	56.2	45.4	30.1	(30)	
5%		WB	20.2	23.6	34.9	43.3	49.3	55.2	57.5	55.4	49.7	41.3	32.5	22.6	(31)	
		MDCB	24.2	28.7	43.6	55.7	65.3	70.5	72.7	72.8	66.8	54.0	41.4	27.2	(32)	
10%		WB	17.1	21.2	32.4	41.3	47.7	54.0	56.4	54.3	48.0	39.6	29.9	20.1	(33)	
		MDCB	21.2	25.9	39.9	53.1	62.7	69.3	71.4	71.0	63.8	51.7	36.8	24.6	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.2	14.9	15.8	16.6	17.1	16.8	16.5	16.9	17.5	15.6	13.4	12.6	(35)
MCDBR			14.7	16.9	17.6	20.7	19.9	19.5	19.3	19.5	20.0	19.2	16.9	14.8	(36)	
MCWBR			11.6	13.0	10.8	9.6	8.8	7.6	7.2	7.5	9.1	10.4	10.4	11.5	(37)	
5% WB		MCDBR	14.4	16.4	16.6	17.9	17.2	15.8	16.1	16.8	17.7	17.9	15.9	14.5	(38)	
		MCWBR	11.7	12.9	10.7	9.2	8.3	6.4	6.6	6.7	8.4	10.2	10.2	11.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.320	0.358	0.404	0.397	0.409	0.395	0.373	0.346	0.337	0.303	0.283	(40)	
(41)		taud	2.164	2.098	2.077	2.034	2.119	2.154	2.234	2.283	2.302	2.222	2.224	2.162	(41)	
(42)		Ebn at Noon	256	267	272	270	276	272	275	277	276	258	246	241	(42)	
(43)		Edh at Noon	29	37	44	51	48	47	43	39	35	33	27	26	(43)	
(44)	All-Sky Solar Radiation	RadAvg	594	917	1393	1865	2229	2262	2173	1962	1651	1126	670	483	(44)	
(45)		RadStd	38	40	102	98	113	124	86	72	68	51	65	40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page