

BAYTIK SHAN, China

WMO: 512880

Lat: 45.3601N

Lon: 90.5707E

Elev: 1651

StdP: 83.00

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.2	-21.1	-31.4	0.2	-19.5	-29.3	0.3	-18.2	7.8	-8.4	6.7	-9.9	1.9	70	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	28.2	12.9	26.6	12.3	25.1	11.8	14.5	23.0	13.7	22.2	13.1	21.8	4.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.1	10.8	15.7	10.9	9.9	15.6	9.8	9.2	15.6	46.3	22.9	43.9	22.2	42.0	22.0	17.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	8.5	7.3	DB	-27.0	30.7	3.2	1.7	-29.3	32.0	-31.1	33.0	-32.9	34.0	-35.3	35.2
			WB	-27.3	15.8	3.1	1.2	-29.5	16.6	-31.3	17.3	-33.1	18.0	-35.3	18.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-12.3	-9.8	-3.6	5.0	11.0	16.8	18.8	17.5	11.8	4.0	-4.4	-10.2	(6)
(7)		DBStd	12.05	4.74	4.87	6.18	5.66	4.79	3.61	3.26	3.71	4.65	5.30	5.70	4.67	(7)
(8)		HDD10.0	3164	693	554	420	161	46	2	0	1	34	193	433	628	(8)
(9)		HDD18.3	5421	951	787	678	399	229	69	33	61	199	444	683	886	(9)
(10)		CDD10.0	897	0	0	0	13	77	206	273	233	88	7	0	0	(10)
(11)		CDD18.3	110	0	0	0	0	2	23	48	34	3	0	0	0	(11)
(12)		CDH23.3	762	0	0	0	1	15	151	343	233	21	0	0	0	(12)
(13)		CDH26.7	133	0	0	0	0	0	19	74	39	1	0	0	0	(13)
(14)	Wind	WSAvg	3.0	1.9	2.0	2.6	3.8	4.1	4.0	3.7	3.6	3.4	2.8	2.3	2.0	(14)
(15)	Precipitation	PrecAvg	165	4	4	8	12	16	24	38	20	16	10	9	5	(15)
(16)		PrecMax	287	12	11	17	36	44	81	114	52	52	28	28	16	(16)
(17)		PrecMin	83	1	0	0	0	0	5	4	1	0	2	3	1	(17)
(18)		PrecStd	57	3	3	4	8	12	20	27	13	13	7	6	4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.9	3.4	13.0	20.5	25.1	28.8	31.0	29.7	25.9	18.7	11.0	1.2	(19)
(20)		MCWB	-2.7	-1.5	3.9	7.9	10.2	12.8	14.1	13.3	11.1	6.9	3.1	-3.0	(20)	
(21)		2%	DB	-2.0	0.2	9.6	17.6	23.0	26.7	28.6	27.7	23.2	15.8	8.1	-0.8	(21)
(22)		MCWB	-4.9	-3.6	2.5	6.3	9.5	12.0	13.5	12.5	10.0	5.4	1.4	-4.2	(22)	
(23)		5%	DB	-4.2	-1.5	7.0	15.3	20.9	25.1	26.9	25.9	21.1	13.7	5.6	-2.4	(23)
(24)		MCWB	-6.8	-4.9	1.1	5.2	8.8	11.5	12.9	11.9	9.0	4.5	0.0	-5.3	(24)	
(25)		10%	DB	-6.0	-3.2	4.8	13.1	18.9	23.4	25.1	24.2	19.2	11.6	3.2	-4.0	(25)
(26)		MCWB	-8.2	-6.1	0.0	4.4	8.0	11.2	12.5	11.5	8.1	3.8	-1.4	-6.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.2	-1.2	4.7	8.9	11.7	14.5	16.2	15.1	12.0	7.8	3.6	-2.2	(27)
(28)		MCDWB	0.9	2.7	11.5	17.5	22.0	22.0	24.3	22.9	21.3	16.3	9.0	0.0	(28)	
(29)		2%	WB	-4.7	-3.3	3.1	7.4	10.5	13.6	15.0	13.7	10.8	6.3	1.9	-3.8	(29)
(30)		MCDWB	-2.5	-0.1	8.8	14.7	20.4	21.9	23.6	22.8	20.6	13.5	7.5	-1.1	(30)	
(31)		5%	WB	-6.5	-4.7	1.6	6.3	9.6	12.9	14.2	13.0	9.8	5.2	0.3	-5.2	(31)
(32)		MCDWB	-4.3	-1.8	6.4	13.2	18.5	21.4	22.6	22.7	19.3	12.2	5.2	-2.7	(32)	
(33)		10%	WB	-8.3	-6.0	0.2	5.2	8.7	12.2	13.6	12.4	8.9	4.2	-1.2	-6.6	(33)
(34)		MCDWB	-6.0	-3.4	4.4	11.7	17.1	20.7	21.9	21.6	17.7	10.9	2.7	-4.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	7.4	8.3	8.8	9.2	9.5	9.3	9.2	9.4	9.7	8.7	7.5	7.0	(35)	
(36)		5% DB	MCDBR	8.2	9.4	9.8	11.5	11.0	10.9	10.7	10.9	11.1	10.7	9.4	8.2	(36)
(37)		MCWBR	6.4	7.2	6.0	5.4	4.9	4.2	4.0	4.2	5.0	5.8	5.8	6.4	(37)	
(38)		5% WB	MCDBR	8.0	9.1	9.2	9.9	9.6	8.8	8.9	9.4	9.9	9.9	8.8	8.0	(38)
(39)		MCWBR	6.5	7.2	5.9	5.1	4.6	3.5	3.7	3.7	4.7	5.6	5.7	6.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.320	0.358	0.404	0.397	0.409	0.395	0.373	0.346	0.337	0.303	0.283	(40)	
(41)		taud	2.164	2.098	2.077	2.034	2.119	2.154	2.234	2.283	2.302	2.222	2.224	2.162	(41)	
(42)		Ebn at Noon	808	841	859	851	870	859	867	874	869	814	777	760	(42)	
(43)		Edh at Noon	90	118	139	160	152	147	134	123	110	103	84	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.87	2.89	4.39	5.88	7.03	7.13	6.85	6.18	5.20	3.55	2.11	1.52	(44)	
(45)		RadStd	0.12	0.12	0.32	0.31	0.36	0.39	0.27	0.23	0.21	0.16	0.20	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page