

KUQA, China

WMO: 516440

Lat: 41.717N

Lon: 82.950E

Elev: 1084

StdP: 88.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-14.5	-20.4	0.7	-10.1	-18.7	0.8	-8.3	4.2	-3.1	3.5	-4.3	1.1	0	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	34.1	18.2	32.9	17.7	31.7	17.3	20.1	29.7	19.3	29.1	18.7	28.5	2.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	14.1	24.0	16.2	13.2	23.4	15.2	12.3	22.9	63.1	29.6	60.2	29.0	57.8	28.6	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.2	4.3	-17.4	36.8	2.8	1.3	-19.4	37.7	-21.0	38.5	-22.5	39.2	-24.5	40.2		
(5)			-17.8	22.2	2.7	1.1	-19.7	23.0	-21.3	23.6	-22.8	24.2	-24.8	25.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-7.3	-0.7	7.9	15.3	19.8	23.4	24.9	23.8	19.1	12.0	3.7	-4.9	(6)
(7)		DBStd	11.54	3.19	3.89	3.99	3.90	3.38	2.78	2.43	2.61	2.73	3.47	3.74	3.24	(7)
(8)		HDD10.0	1603	537	298	90	7	0	0	0	0	0	19	189	463	(8)
(9)		HDD18.3	3161	795	532	323	104	24	2	0	1	23	198	438	721	(9)
(10)		CDD10.0	2144	0	0	25	164	305	403	463	429	272	81	1	0	(10)
(11)		CDD18.3	659	0	0	0	12	71	155	205	171	45	1	0	0	(11)
(12)		CDH23.3	7178	0	0	1	163	736	1667	2271	1828	486	26	0	0	(12)
(13)		CDH26.7	2824	0	0	0	25	208	681	1039	756	114	2	0	0	(13)
(14)	Wind	WSAvg	1.9	1.4	1.7	2.1	2.3	2.3	2.1	2.0	1.8	1.6	1.5	1.3	(14)	
(15)	Precipitation	PrecAvg	62	1	2	3	3	5	13	13	9	5	4	2	1	(15)
(16)		PrecMax	124	6	16	16	15	27	65	52	38	27	27	29	8	(16)
(17)		PrecMin	31	0	0	0	0	0	0	1	0	0	0	0	0	(17)
(18)		PrecStd	22	2	3	4	4	6	16	11	10	6	7	6	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	11.6	22.5	29.1	32.2	34.6	36.6	35.2	31.3	26.1	17.5	5.8	(19)
(20)			MCWB	-1.2	3.6	9.1	13.4	15.9	17.5	19.2	18.9	17.1	13.1	7.7	1.2	(20)
(21)		2%	DB	1.4	9.3	19.8	27.0	30.5	33.2	34.8	33.3	29.4	23.6	15.0	3.4	(21)
(22)			MCWB	-2.7	2.5	7.8	12.4	15.2	17.0	18.6	18.3	16.1	12.2	6.1	-0.5	(22)
(23)		5%	DB	-0.4	7.6	17.9	25.3	29.0	32.0	33.2	32.1	27.9	21.5	12.9	1.7	(23)
(24)			MCWB	-3.7	1.4	6.9	11.5	14.4	16.7	18.2	18.0	15.6	11.0	5.5	-1.7	(24)
(25)		10%	DB	-1.8	5.7	15.7	23.3	27.5	30.6	31.8	30.8	26.3	19.6	10.6	0.1	(25)
(26)			MCWB	-4.6	0.2	5.9	10.6	13.7	16.3	17.7	17.7	15.0	10.1	4.4	-2.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.0	4.1	9.4	14.1	17.6	19.7	21.7	21.2	18.8	14.0	8.1	1.7	(27)
(28)			MCDWB	3.3	10.5	21.2	27.8	28.6	29.3	30.7	30.0	28.4	23.5	16.5	5.5	(28)
(29)		2%	WB	-2.4	2.7	8.2	12.9	16.1	18.6	20.4	20.1	17.4	13.0	6.6	-0.3	(29)
(30)			MCDWB	0.9	8.7	18.7	25.5	28.4	28.9	30.0	29.5	26.6	21.8	13.9	3.0	(30)
(31)		5%	WB	-3.6	1.7	7.2	12.0	15.2	17.8	19.6	19.3	16.5	11.9	5.6	-1.6	(31)
(32)			MCDWB	-0.5	7.1	17.0	23.8	27.2	28.6	29.4	28.9	25.6	19.9	12.4	1.5	(32)
(33)		10%	WB	-4.5	0.5	6.2	11.0	14.3	17.2	18.8	18.7	15.7	10.9	4.6	-2.7	(33)
(34)			MCDWB	-1.9	5.2	15.1	22.3	25.9	28.1	28.8	28.2	24.4	17.8	10.3	-0.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.2	10.3	11.1	11.7	12.1	12.2	12.1	12.3	13.1	14.0	11.4	9.1	(35)
(36)			MCDBR	11.3	11.8	13.8	14.9	14.6	14.1	14.4	14.2	15.2	15.7	14.3	10.3	(36)
(37)			MCWBR	8.1	6.6	6.5	5.8	5.5	5.0	4.9	5.2	5.6	6.1	7.3	6.9	(37)
(38)		5% WB	MCDBR	11.0	11.2	13.2	14.0	13.2	12.6	12.6	12.7	13.9	14.9	14.0	9.9	(38)
(39)			MCWBR	8.0	6.3	6.3	5.5	5.7	5.0	5.0	5.3	5.6	5.8	7.3	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.397	0.492	0.543	0.556	0.576	0.536	0.571	0.579	0.490	0.399	0.353	(40)	
(41)		taud	2.119	1.983	1.765	1.684	1.713	1.718	1.837	1.745	1.685	1.805	1.979	2.062	(41)	
(42)		Ebn at Noon	777	776	738	736	741	726	752	706	654	661	681	710	(42)	
(43)		Edh at Noon	105	142	200	233	232	231	203	216	215	169	121	103	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.32	3.31	4.40	5.44	6.17	6.37	6.26	5.66	4.82	3.74	2.56	1.98	(44)	
(45)		RadStd	0.21	0.20	0.20	0.31	0.29	0.33	0.30	0.27	0.19	0.17	0.17	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	-0.44	N/A	N/A	N/A	N/A	-51	(46)
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	-0.50	N/A	N/A	N/A	N/A	-51	(47)

Nomenclature: See separate page