

KORLA, China

WMO: 516560

Lat: 41.7302N

Lon: 85.8180E

Elev: 2963

StdP: 13.19

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.6	7.9	-6.4	4.4	23.7	-2.6	5.3	20.9	14.4	21.7	12.9	23.2	1.9	90	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	96.0	65.5	93.7	64.6	91.5	63.9	69.4	88.4	67.8	86.9	66.5	85.4	5.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	97.8	78.1	61.5	91.1	76.6	59.7	85.3	76.3	35.5	88.6	34.1	87.0	32.9	85.3	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	14.6	12.5	1.3	100.0	4.3	2.0	-1.8	101.4	-4.3	102.6	-6.7	103.8	-9.9	105.2
			0.5	72.7	4.1	3.2	-2.4	74.9	-4.8	76.8	-7.1	78.6	-10.1	80.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.6	19.8	31.9	47.4	61.0	70.4	78.0	80.7	78.7	69.0	54.6	38.7	23.4
	DBStd	22.03	5.85	7.22	8.05	7.72	6.76	5.54	5.17	5.30	5.60	6.95	6.85	5.99
	HDD50	2799	935	506	150	11	0	0	0	0	0	33	340	824
	HDD65	5498	1400	926	548	163	29	1	0	1	24	329	788	1289
	CDD50	4467	0	0	68	341	631	840	953	889	569	175	1	0
	CDD65	1691	0	0	1	43	195	391	488	425	142	6	0	0
	CDH74	19053	0	0	4	421	1980	4463	5892	4976	1260	57	0	0
	CDH80	8285	0	0	0	87	659	1975	2948	2281	331	4	0	0
(14) Wind	WSAvg	5.1	3.9	4.8	5.8	6.5	6.4	5.9	5.7	5.4	5.0	4.4	3.9	3.7
(15) Precipitation	PrecAvg	3.1	0.1	0.1	0.1	0.2	0.3	0.6	0.7	0.5	0.2	0.1	0.1	0.2
	PrecMax	5.2	0.3	0.3	0.4	0.4	0.9	1.7	1.7	1.5	1.1	0.4	0.3	0.4
	PrecMin	1.6	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.7	0.1	0.1	0.1	0.1	0.2	0.4	0.4	0.4	0.2	0.1	0.1	0.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.5	53.3	73.8	87.0	92.3	96.5	100.3	97.7	90.0	79.4	63.0	42.4
		MCWB	29.5	38.8	49.0	57.2	60.1	64.2	66.1	66.6	63.6	56.0	45.5	34.1
	2%	DB	34.6	49.3	68.8	82.3	89.2	94.0	97.0	94.7	86.6	75.0	58.3	38.2
		MCWB	27.3	36.6	46.5	54.6	59.3	63.6	66.2	65.3	61.7	54.0	42.7	31.1
	5%	DB	31.7	46.4	65.3	78.8	86.6	91.8	94.6	92.3	83.9	71.6	54.8	35.2
		MCWB	25.5	34.9	45.1	53.2	58.3	63.1	65.6	64.8	60.6	52.2	41.6	29.1
	10%	DB	28.9	43.3	61.6	75.5	83.7	89.5	91.8	90.0	81.0	68.2	51.0	32.5
		MCWB	23.7	33.0	43.3	51.3	57.1	62.3	64.8	64.1	59.3	50.4	39.7	27.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.0	39.6	49.5	58.3	64.0	68.8	72.5	71.8	67.1	57.4	46.2	34.7
		MCDB	37.6	51.2	71.7	84.6	85.8	87.9	91.7	88.8	84.4	74.5	60.9	41.5
	2%	WB	27.6	37.2	47.1	55.5	61.0	66.5	69.8	69.3	64.2	55.4	43.6	31.6
		MCDB	34.1	48.4	67.3	80.1	85.5	87.3	89.4	87.8	81.4	72.2	56.5	37.2
	5%	WB	25.6	35.3	45.4	53.7	59.3	65.0	68.2	67.7	62.4	53.4	41.8	29.5
		MCDB	31.1	45.4	64.4	77.1	83.2	86.1	87.6	86.2	79.3	69.1	53.6	34.6
	10%	WB	23.9	33.5	43.6	52.0	57.9	63.8	66.8	66.3	60.8	51.5	40.1	27.4
		MCDB	28.7	42.6	61.0	73.6	80.9	84.8	85.9	84.4	77.6	66.2	50.3	32.1
(35) Mean Daily Temperature Range	MDBR		15.3	17.5	19.5	20.7	20.5	18.8	18.7	19.7	22.0	24.2	19.6	14.1
	5% DB	MCDBR	18.1	20.4	23.2	25.6	24.4	22.6	21.6	23.3	26.1	26.8	25.4	17.1
		MCWBR	12.5	11.5	10.5	9.4	8.9	8.2	8.3	9.3	10.0	10.4	12.6	11.4
	5% WB	MCDBR	17.2	19.5	22.9	24.5	22.2	20.6	21.1	22.7	25.2	25.8	24.6	16.4
		MCWBR	12.1	11.2	10.6	9.4	9.0	8.9	9.3	10.3	10.8	10.2	12.4	11.1
(40) Clear-Sky Solar Irradiance	taub		0.342	0.397	0.482	0.532	0.556	0.572	0.533	0.548	0.544	0.475	0.397	0.355
	taud		2.102	1.982	1.782	1.708	1.715	1.735	1.853	1.800	1.756	1.838	1.987	2.055
	Ebn at Noon		244	246	237	236	235	232	239	230	217	215	217	224
	Edh at Noon		34	45	62	72	73	72	63	65	63	52	38	33
(44) All-Sky Solar Radiation	RadAvg		721	1041	1441	1789	2036	2082	2052	1878	1622	1234	840	617
	RadStd		65	55	59	111	101	129	88	102	55	56	49	72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	-1.60	-1.96	N/A	N/A	+212	+108
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+106

Nomenclature: See separate page