

BACHU, ChinaWMO: **517160**Lat: **39.7975N**Lon: **78.5711E**Elev: **1117**StdP: **88.61**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-12.8	-19.3	0.8	-7.6	-17.5	0.9	-6.9	5.1	-1.4	4.3	-1.9	0.5	160	0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	35.8	18.6	34.5	18.0	33.2	17.6	20.6	31.4	19.8	30.6	19.2	29.9	1.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	14.1	25.0	16.4	13.4	24.2	15.5	12.6	23.9	64.9	31.2	62.1	30.5	59.6	30.1	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.7	4.0	-16.0	38.6	3.0	1.2	-18.2	39.4	-20.0	40.1	-21.6	40.8	-23.8	41.6		
(5)			-16.4	22.0	2.9	1.3	-18.4	22.9	-20.1	23.6	-21.7	24.3	-23.8	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-5.6	0.4	9.5	17.0	21.6	25.1	26.5	25.3	20.8	13.7	4.8	-3.3	(6)
(7)		DBStd	11.59	3.14	3.82	4.14	3.81	3.22	2.68	2.70	2.72	2.62	3.44	3.69	2.76	(7)
(8)		HDD10.0	1392	485	269	61	3	0	0	0	0	0	6	158	411	(8)
(9)		HDD18.3	2826	743	502	273	66	10	0	0	0	8	148	406	669	(9)
(10)		CDD10.0	2504	0	0	46	214	360	452	510	476	323	121	2	0	(10)
(11)		CDD18.3	896	0	0	0	27	112	203	252	217	81	4	0	0	(11)
(12)		CDH23.3	9683	0	0	12	362	1198	2233	2837	2234	736	71	0	0	(12)
(13)		CDH26.7	4326	0	0	1	104	461	1062	1431	1033	228	7	0	0	(13)
(14)	Wind	WSAvg	1.5	1.1	1.3	1.8	1.9	1.8	1.7	1.5	1.4	1.1	1.0	1.0	(14)	
(15)	Precipitation	PrecAvg	52	1	1	1	3	7	10	12	11	4	2	0	0	(15)
(16)		PrecMax	124	7	14	23	24	26	52	40	48	20	20	6	5	(16)
(17)		PrecMin	8	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	31	1	3	4	6	9	13	9	12	5	5	1	1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	13.3	24.9	32.0	34.2	36.6	38.3	36.7	32.9	27.5	19.0	7.6	(19)
(20)			MCWB	-0.3	4.1	10.0	13.5	15.7	17.8	19.5	19.6	17.4	13.3	7.9	1.8	(20)
(21)		2%	DB	3.5	10.8	22.0	29.5	32.6	35.0	36.5	34.9	30.9	25.3	16.5	5.2	(21)
(22)			MCWB	-1.5	3.1	8.7	12.6	14.9	17.0	19.1	19.1	16.4	12.8	6.6	0.2	(22)
(23)		5%	DB	1.5	9.2	19.9	27.4	31.1	33.7	34.8	33.4	29.3	23.3	14.4	3.4	(23)
(24)			MCWB	-2.7	2.3	7.8	11.7	14.4	16.8	18.6	18.8	16.1	12.0	5.8	-0.9	(24)
(25)		10%	DB	-0.1	7.1	17.5	25.2	29.4	32.3	33.3	32.0	27.6	21.2	11.9	1.7	(25)
(26)			MCWB	-3.7	1.1	6.8	10.7	13.8	16.5	18.3	18.5	15.5	10.8	4.9	-1.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.1	5.3	10.3	14.2	17.5	19.7	21.7	21.8	19.2	14.7	8.4	2.0	(27)
(28)			MCD B	5.4	11.4	23.6	30.1	30.1	31.7	32.1	32.2	29.3	24.1	17.5	6.8	(28)
(29)		2%	WB	-1.5	3.6	9.0	13.2	16.0	18.7	20.7	20.7	17.8	13.6	7.0	0.5	(29)
(30)			MCD B	3.2	10.0	20.8	27.5	29.3	30.8	31.4	31.5	27.4	23.6	15.2	4.7	(30)
(31)		5%	WB	-2.6	2.5	8.1	12.2	15.2	18.0	20.0	19.9	17.0	12.6	6.1	-0.8	(31)
(32)			MCD B	1.3	8.7	18.9	25.5	28.2	29.9	31.0	30.3	26.1	22.0	13.9	3.1	(32)
(33)		10%	WB	-3.6	1.3	7.1	11.3	14.6	17.3	19.3	19.2	16.2	11.6	5.0	-1.8	(33)
(34)			MCD B	-0.3	6.9	16.9	23.7	27.0	29.1	30.3	29.4	25.3	19.8	11.8	1.6	(34)
(35)	Mean Daily Temperature Range		MDBR	10.7	11.4	11.8	12.6	12.7	12.6	12.2	11.9	12.7	14.4	13.0	10.2	(35)
(36)		5% DB	MCD BR	13.1	13.4	14.9	16.6	16.0	14.5	14.3	14.1	15.6	16.1	16.2	12.4	(36)
(37)			MCWBR	8.9	7.5	6.4	6.1	5.4	4.6	4.8	5.2	5.8	6.6	8.0	8.1	(37)
(38)		5% WB	MCD BR	12.6	12.8	14.2	15.1	14.1	12.8	12.6	12.4	14.1	15.1	15.8	12.0	(38)
(39)			MCWBR	8.6	7.3	6.2	5.6	5.1	4.5	4.9	5.3	5.7	6.4	7.9	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.409	0.530	0.594	0.618	0.627	0.584	0.637	0.630	0.515	0.427	0.371	(40)	
(41)		taud	2.059	1.934	1.661	1.560	1.572	1.593	1.703	1.594	1.567	1.730	1.889	2.007	(41)	
(42)		Ebn at Noon	774	776	712	701	698	692	718	662	623	651	667	708	(42)	
(43)		Edh at Noon	117	154	226	266	269	263	234	254	246	187	139	115	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.50	3.36	4.53	5.67	6.60	6.87	6.56	5.86	5.04	4.11	2.90	2.27	(44)	
(45)		RadStd	0.31	0.29	0.31	0.24	0.36	0.33	0.36	0.35	0.28	0.17	0.16	0.20	(45)	

Historical Trends